

PISHAN, China

WMO: 518180

Lat: 37.6147N

Lon: 78.2760E

Elev: 4514

StdP: 12.45

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 6.4	(c) 10.2	(d) -4.8	(e) 5.0	(f) 23.0	(g) -1.7	(h) 5.9	(i) 25.2	(j) 10.0	(k) 34.1	(l) 9.1	(m) 30.9	(n) 1.5	(o) 270	(p) 0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	96.8	64.0	94.1	63.3	91.7	62.3	67.0	89.2	65.6	87.4	64.5	85.6	3.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	92.6	73.3	58.9	87.9	73.1	57.4	83.1	73.1	34.3	89.5	33.1	87.4	32.1	85.6	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 11.8	(b) 9.9	(c) 8.7	(e) 4.0	(f) 101.4	(g) 5.1	(h) 2.1	(i) 0.4	(j) 102.9	(k) -2.6	(l) 104.2	(m) -5.5	(n) 105.3	(o) -9.2	(p) 106.9		
			DB													
			WB													
				3.1			3.0	-0.4		72.3		-3.2		74.1		-5.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.7	23.3	33.6	49.8	62.2	70.2	76.4	79.3	77.2	69.1	56.7	41.9	27.6		
	DBStd	20.26	7.45	7.39	7.61	7.25	5.91	5.04	5.14	5.13	5.05	6.35	7.07	6.16		
	HDD50	2359	828	459	100	8	0	0	0	0	0	13	258	693		
	HDD65	4937	1293	879	472	130	24	1	0	1	18	267	694	1158		
	CDD50	4446	0	0	94	376	626	792	907	844	573	220	14	0		
	CDD65	1548	0	0	1	47	184	343	443	380	141	9	0	0		
	CDH74	17174	0	0	27	592	1977	3748	5242	4116	1357	115	0	0		
	CDH80	7527	0	0	3	151	685	1685	2684	1911	399	9	0	0		
(14) Wind	WSAvg	3.6	2.7	3.2	4.1	4.4	4.5	4.7	4.0	3.9	3.5	3.1	2.8	2.7		
(15) Precipitation	PrecAvg	2.0	0.0	0.2	0.1	0.2	0.4	0.2	0.3	0.2	0.2	0.1	0.0	0.0		
	PrecMax	4.3	0.3	0.8	0.9	1.5	2.0	0.9	1.3	0.7	1.1	0.7	0.3	0.2		
	PrecMin	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.0	0.1	0.2	0.2	0.4	0.6	0.3	0.4	0.2	0.3	0.2	0.0	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.5	59.0	77.1	89.1	93.0	97.9	100.8	99.4	90.9	81.0	69.1	53.6		
		MCWB	35.8	41.0	48.9	56.0	59.2	63.4	65.3	64.8	61.8	55.1	46.5	37.4		
	2%	DB	44.2	54.4	72.1	84.3	89.3	94.1	97.7	95.4	87.6	77.2	63.5	46.5		
		MCWB	31.3	38.3	46.8	54.2	57.5	61.9	64.5	64.1	60.2	53.9	43.6	33.5		
	5%	DB	39.0	50.1	68.6	80.8	86.7	91.8	95.1	92.6	84.6	73.8	59.3	42.1		
		MCWB	28.7	35.9	45.4	52.5	56.8	61.1	64.1	63.4	58.9	52.2	41.8	31.2		
	10%	DB	35.0	46.4	64.5	77.0	84.0	89.1	92.3	89.8	81.6	70.2	55.5	38.3		
		MCWB	26.5	33.8	43.6	51.1	55.9	60.5	63.4	62.9	58.2	50.4	40.1	29.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.9	42.5	50.0	57.4	61.4	66.4	70.0	69.0	65.3	57.1	47.6	37.5		
		MCDB	51.5	55.9	74.5	84.7	85.7	90.2	92.9	90.9	86.1	75.6	66.8	52.4		
	2%	WB	31.5	39.1	47.6	55.1	59.5	64.0	67.5	66.6	62.4	54.9	44.2	33.8		
		MCDB	43.4	52.4	69.9	81.3	83.5	87.4	89.6	88.9	80.3	74.8	62.0	45.8		
	5%	WB	29.0	36.5	45.9	53.5	58.3	62.7	66.1	65.4	60.9	53.1	42.1	31.4		
		MCDB	38.6	48.5	66.7	77.4	81.6	86.1	88.1	86.9	78.4	71.5	57.9	41.2		
	10%	WB	26.8	34.3	44.0	51.9	57.0	61.7	64.8	64.3	59.6	51.4	40.3	29.4		
		MCDB	34.7	45.5	62.8	74.3	79.7	84.2	86.2	84.8	77.1	68.3	54.7	37.9		
(35) Mean Daily Temperature Range	MDBR		18.5	18.5	20.8	21.6	22.0	21.1	21.6	20.7	22.1	24.9	23.1	18.4		
	5% DB	MCDBR	24.9	24.0	25.9	27.8	26.7	25.2	27.2	26.6	26.8	27.2	27.9	24.1		
		MCWBR	15.6	13.0	12.1	11.5	10.1	8.5	8.9	9.2	10.2	11.5	14.0	14.5		
	5% WB	MCDBR	23.8	22.5	24.2	24.2	23.8	22.3	22.7	22.4	23.0	25.0	26.5	22.9		
		MCWBR	15.1	12.3	11.4	10.2	9.0	7.8	8.5	8.5	9.5	11.0	13.5	14.0		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.401	0.521	0.600	0.616	0.626	0.616	0.659	0.615	0.471	0.388	0.350		
	taud		2.109	1.933	1.653	1.537	1.554	1.571	1.611	1.532	1.571	1.791	1.966	2.057		
	Ebn at Noon		260	254	232	223	223	221	222	207	205	226	234	243		
	Edh at Noon		37	50	74	87	87	86	82	87	79	57	42	36		
(44) All-Sky Solar Radiation	RadAvg		861	1141	1602	1917	2180	2236	2102	1869	1686	1434	1050	830		
	RadStd		128	109	107	81	111	98	139	147	102	46	56	65		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	-1.44	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.76	N/A	N/A	N/A	-1.87	-2.30	N/A	-238	+259	+121

Nomenclature: See separate page