

MAZONG SHAN, China

WMO: 523230

Lat: 41.8048N

Lon: 97.0320E

Elev: 5807

StdP: 11.86

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-7.0	-26.1	1.6	2.7	-21.8	2.1	4.7	29.6	19.5	26.6	18.8	7.6	270	0.668

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	87.4	56.1	84.8	54.8	82.4	54.0	59.5	75.7	57.9	74.9	56.6	74.5	11.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.8	79.3	63.6	52.3	72.4	63.5	49.7	65.7	63.2	28.9	76.0	27.6	74.6	26.7	74.3	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.4	23.7	20.9	DB	-18.9	91.9	5.7	2.3	-23.0	93.5	-26.4	94.9	-29.6	96.2	-33.7	97.9	(4)
(5)			WB	-19.5	62.2	5.6	3.3	-23.5	64.6	-26.7	66.5	-29.9	68.4	-33.9	70.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.0	11.5	18.6	30.2	44.2	55.4	65.7	70.5	67.3	55.9	41.4	27.2	15.1	(6)
(7)		DBStd	21.68	8.31	8.18	9.37	8.69	7.17	5.43	4.92	5.28	6.69	7.76	8.68	8.76	(7)
(8)		HDD50	4994	1192	878	614	210	32	1	0	0	22	280	684	1081	(8)
(9)		HDD65	8756	1657	1298	1079	625	303	55	10	37	280	732	1134	1546	(9)
(10)		CDD50	2091	0	0	0	35	201	472	636	536	198	13	0	0	(10)
(11)		CDD65	375	0	0	0	0	6	76	180	107	6	0	0	0	(11)
(12)		CDH74	4166	0	0	0	9	154	877	1846	1159	120	1	0	0	(12)
(13)		CDH80	1106	0	0	0	0	15	183	610	285	13	0	0	0	(13)
(14)	Wind	WSAvg	9.9	9.4	9.3	10.2	11.4	10.9	10.1	9.4	9.2	9.0	9.5	10.5	10.3	(14)
(15)	Precipitation	PrecAvg	3.0	0.0	0.0	0.1	0.1	0.2	0.6	0.9	0.6	0.2	0.1	0.0	0.0	(15)
(16)		PrecMax	6.2	0.2	0.2	0.6	0.5	0.9	2.1	3.9	1.2	0.7	0.6	0.2	0.2	(16)
(17)		PrecMin	1.4	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.1	0.0	0.0	0.1	0.2	0.2	0.5	0.8	0.4	0.2	0.1	0.1	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	47.6	61.5	74.6	82.1	87.7	92.1	89.3	81.7	70.1	56.3	41.4	(19)
MCWB			28.3	31.9	39.4	46.8	49.3	55.3	57.9	57.3	53.2	45.8	37.7	28.7	(20)	
2%		DB	34.5	41.9	56.1	69.1	78.3	84.5	89.0	85.7	77.3	65.1	51.2	36.9	(21)	
		MCWB	24.7	29.0	37.0	44.1	48.9	53.5	56.8	55.2	50.2	43.6	35.3	26.4	(22)	
5%		DB	29.6	38.0	51.8	64.9	74.9	81.9	86.2	83.2	74.1	61.1	46.9	32.5	(23)	
		MCWB	21.6	26.8	34.9	42.4	47.6	52.9	55.9	54.3	49.0	41.7	33.0	23.8	(24)	
10%		DB	25.2	34.0	47.6	61.0	71.4	79.4	83.4	80.6	70.8	57.2	42.3	28.4	(25)	
		MCWB	18.9	24.5	32.6	40.7	46.7	52.0	55.1	53.8	47.8	39.5	30.8	21.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.4	32.1	40.4	48.3	53.1	60.2	63.6	61.4	56.2	46.7	38.5	29.5	(27)
MCD B			39.7	46.0	58.3	70.8	72.9	73.9	83.6	79.1	72.4	66.2	54.5	40.5	(28)	
2%		WB	25.0	29.4	37.7	45.3	50.6	57.6	60.2	58.8	52.9	44.4	35.6	26.6	(29)	
		MCD B	34.2	41.1	54.4	66.4	72.9	73.2	76.8	73.8	70.5	63.1	50.2	36.3	(30)	
5%		WB	21.8	27.1	35.3	43.2	49.0	55.8	58.4	57.0	50.9	42.3	33.3	24.0	(31)	
		MCD B	29.3	37.2	50.7	62.5	71.5	72.9	76.0	75.3	69.4	59.3	46.2	32.0	(32)	
10%		WB	18.9	24.8	32.9	41.3	47.4	54.3	57.2	55.6	49.1	40.2	31.0	21.4	(33)	
		MCD B	25.1	33.7	46.8	59.1	69.1	72.9	74.8	75.1	68.0	55.7	42.0	28.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	24.0	25.8	26.3	24.5	23.8	22.0	21.2	22.0	24.2	25.4	23.3	22.7	(35)
MCDBR			28.2	30.1	30.9	29.8	29.0	26.1	25.4	25.9	28.1	30.0	28.6	26.4	(36)	
MCWBR			20.2	19.9	17.7	15.1	13.3	10.2	8.5	9.5	11.7	15.2	16.6	18.3	(37)	
5% WB		MCD BR	27.5	28.6	28.5	26.7	24.6	20.2	20.2	20.8	23.6	27.6	27.7	25.5	(38)	
		MCWBR	20.0	19.0	16.4	13.6	11.8	8.3	7.2	8.2	10.7	14.4	16.3	17.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.273	0.317	0.367	0.415	0.422	0.437	0.430	0.406	0.379	0.332	0.297	0.271	(40)	
taud		2.295	2.177	2.034	1.947	1.993	2.024	2.089	2.139	2.158	2.221	2.267	2.301	(41)		
Ebn at Noon		278	278	275	270	271	266	267	270	269	269	264	268	(42)		
Edh at Noon		28	37	48	56	56	54	50	46	42	35	28	25	(43)		
(44)	All-Sky Solar Radiation	RadAvg	803	1146	1608	1976	2275	2251	2168	1999	1721	1333	889	704	(44)	
(45)		RadStd	41	51	70	117	107	144	116	76	82	40	44	36	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	N/A

Nomenclature: See separate page