

JIUQUAN SUZHOU, China

WMO: 525330

Lat: 39.767N

Lon: 98.483E

Elev: 4849

StdP: 12.30

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	0.7	-14.6	3.0	7.4	-11.3	3.6	11.5	15.3	26.6	12.1	25.1	3.7	250	0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	89.6	62.7	87.1	61.3	84.8	60.3	66.3	82.5	64.7	80.9	63.2	78.7	6.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.4	97.4	71.2	59.6	91.5	70.4	57.9	85.8	70.1	33.9	82.4	32.5	81.1	31.3	79.0	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.5	13.9	11.4		-9.2	95.0	5.3	2.7	-13.0	96.9	-16.1	98.5	-19.1	100.0	-22.9	102.0	
				-9.9	71.5	5.1	2.1	-13.5	73.1	-16.5	74.3	-19.3	75.5	-23.0	77.1	
				DB												
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	16.8	25.5	38.2	52.1	61.7	69.8	72.9	70.3	60.8	47.9	34.0	20.3	(6)
(7)		DBStd	20.59	7.61	8.09	8.73	8.26	6.48	4.76	4.48	4.70	6.04	6.92	7.77	7.65	(7)
(8)		HDD50	3690	1030	685	372	74	4	0	0	2	120	482	921		(8)
(9)		HDD65	6987	1495	1105	831	392	139	15	2	152	529	931	1386		(9)
(10)		CDD50	2822	0	0	6	135	366	593	711	630	325	56	0	0	(10)
(11)		CDD65	645	0	0	0	3	36	158	248	175	25	0	0	0	(11)
(12)		CDH74	6477	0	0	0	63	475	1527	2414	1693	300	5	0	0	(12)
(13)		CDH80	2021	0	0	0	8	84	430	913	541	45	0	0	0	(13)
(14)	Wind	WSAvg	5.0	4.4	5.0	5.8	6.7	5.9	5.2	4.8	4.6	4.5	4.5	4.7	4.3	(14)
(15)	Precipitation	PrecAvg	3.4	0.1	0.1	0.2	0.2	0.3	0.6	0.8	0.7	0.4	0.1	0.1	0.1	(15)
(16)		PrecMax	6.5	0.5	0.3	0.9	0.8	2.5	2.6	3.7	2.7	1.9	0.7	0.5	0.5	(16)
(17)		PrecMin	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.3	0.1	0.1	0.2	0.2	0.5	0.5	0.7	0.6	0.5	0.2	0.1	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.5	52.0	67.2	80.4	85.7	90.2	94.0	91.7	84.9	74.1	59.5	44.7	(19)
(20)		0.4%	MCWB	30.5	35.4	43.5	50.6	55.2	60.9	65.5	63.8	57.3	49.9	41.2	32.3	(20)
(21)		2%	DB	37.7	46.8	62.0	74.9	82.3	87.1	90.7	88.3	80.5	69.6	55.5	39.7	(21)
(22)		2%	MCWB	27.4	32.6	41.1	48.2	54.2	59.5	63.8	61.6	55.3	48.0	39.3	29.3	(22)
(23)		5%	DB	33.3	43.2	57.7	71.2	79.4	84.7	88.0	85.6	77.4	65.6	51.8	35.9	(23)
(24)		5%	MCWB	24.8	30.8	39.2	46.6	52.7	58.9	63.1	60.8	54.9	46.5	37.5	27.0	(24)
(25)		10%	DB	29.5	39.6	53.6	67.6	76.1	82.4	85.4	83.0	74.3	61.8	47.6	32.5	(25)
(26)		10%	MCWB	22.4	28.9	37.5	45.1	51.5	58.1	62.5	60.4	54.0	44.7	35.4	25.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.0	35.9	44.7	52.1	58.3	65.8	70.0	68.2	62.0	52.9	42.8	32.8	(27)
(28)		0.4%	MCDWB	42.3	50.0	64.7	77.0	80.5	80.2	88.1	85.2	71.2	65.3	56.5	43.9	(28)
(29)		2%	WB	27.7	33.1	41.9	49.5	55.9	63.2	67.1	65.7	59.3	49.6	39.9	29.6	(29)
(30)		2%	MCDWB	37.1	45.8	59.7	71.1	78.3	79.7	84.2	80.8	73.5	66.4	54.1	39.3	(30)
(31)		5%	WB	25.1	31.1	39.9	47.6	54.0	61.7	65.4	63.9	57.2	47.6	37.8	27.3	(31)
(32)		5%	MCDWB	33.1	42.4	56.0	68.3	75.3	78.5	82.4	78.9	70.2	63.5	50.9	35.5	(32)
(33)		10%	WB	22.6	29.2	37.9	45.8	52.6	60.2	64.0	62.5	55.6	45.6	35.6	25.2	(33)
(34)		10%	MCDWB	29.2	39.2	52.9	65.1	72.5	77.0	80.6	77.1	69.7	60.5	47.4	32.3	(34)
(35)	Mean Daily Temperature Range		MDBR	20.9	22.0	22.5	22.4	22.1	21.4	21.3	22.2	22.8	23.2	20.2	19.6	(35)
(36)		5% DB	MCDBR	25.3	26.1	28.0	26.9	27.1	25.7	26.8	27.4	27.0	27.0	25.0	23.1	(36)
(37)			MCWBR	17.4	15.8	14.4	11.7	11.7	11.2	11.4	10.9	10.3	12.3	14.3	15.5	(37)
(38)			5% WB	MCDWB	24.7	24.6	26.1	24.6	24.2	22.3	23.4	23.1	22.2	25.3	24.0	22.4
(39)		MCWBR		17.1	15.1	13.7	10.9	11.3	10.7	11.1	10.2	9.5	11.7	13.9	15.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.356	0.420	0.473	0.479	0.488	0.474	0.461	0.432	0.386	0.338	0.305	(40)	
(41)		taud	2.210	2.073	1.912	1.818	1.866	1.915	2.024	2.038	2.051	2.073	2.145	2.218	(41)	
(42)		Ebn at Noon	268	267	260	255	256	254	256	256	254	252	250	258	(42)	
(43)		Edh at Noon	32	42	56	65	63	61	54	52	48	42	34	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	840	1143	1540	1889	2100	2085	2009	1854	1614	1330	948	755	(44)	
(45)		RadStd	48	48	108	112	99	156	109	130	106	61	43	52	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) +122	(m) N/A	(46)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+178	+81	(47)

Nomenclature: See separate page