

DELINGHA, China

WMO: 527370

Lat: 37.3745N

Lon: 97.3757E

Elev: 2982

StdP: 70.27

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.4	-16.5	-32.4	0.3	-9.5	-30.2	0.3	-8.9	6.6	-7.7	5.4	-8.9	0.7	40	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	27.2	12.3	25.4	11.4	23.8	10.6	14.1	23.1	13.2	21.3	12.4	20.3	2.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
11.5	12.2	16.6	10.3	11.3	16.2	9.2	10.5	15.8	51.0	22.7	47.9	21.3	45.1	20.3	17.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	6.5	5.4	4.7	DB	-21.8	30.0	2.0	1.7	-23.2	31.2	-24.4	32.2	-25.5	33.2	-26.9	34.4
(5)				WB	-22.5	15.3	1.8	1.1	-23.8	16.1	-24.9	16.7	-25.9	17.4	-27.2	18.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-8.6	-4.4	1.0	7.2	11.7	15.0	17.6	17.5	12.8	5.5	-1.6	-7.5	(6)
(7)		DBStd	9.82	3.53	4.08	3.84	3.78	3.22	3.09	3.31	2.96	3.20	3.44	3.77	3.12	(7)
(8)		HDD10.0	2428	577	403	279	101	19	3	0	0	8	145	349	543	(8)
(9)		HDD18.3	4730	836	637	537	336	206	106	54	53	169	398	599	801	(9)
(10)		CDD10.0	804	0	0	1	16	72	153	236	231	91	6	0	0	(10)
(11)		CDD18.3	67	0	0	0	0	1	6	32	26	3	0	0	0	(11)
(12)		CDH23.3	452	0	0	0	1	4	39	229	162	17	0	0	0	(12)
(13)		CDH26.7	72	0	0	0	0	0	2	45	23	2	0	0	0	(13)
(14)	Wind	WSAvg	1.8	1.4	1.7	1.9	2.2	2.3	2.2	2.0	1.7	1.5	1.4	1.3	(14)	
(15)	Precipitation	PrecAvg	159	3	3	4	7	22	36	35	26	16	6	1	2	(15)
(16)		PrecMax	284	13	10	32	41	76	104	102	72	46	33	8	11	(16)
(17)		PrecMin	81	0	0	0	0	0	5	2	1	0	0	0	0	(17)
(18)		PrecStd	47	4	3	7	9	20	22	21	19	13	8	2	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.4	9.5	16.0	20.8	23.8	26.5	30.4	29.0	25.6	18.7	10.7	5.2	(19)
(20)		MCWB	-3.6	-0.7	2.8	5.7	7.7	11.3	14.1	13.1	11.6	5.5	0.5	-2.9	(20)	
(21)		2%	DB	1.5	6.6	12.2	18.5	21.6	24.4	27.8	26.9	22.5	15.7	8.3	2.2	(21)
(22)		MCWB	-5.1	-2.2	0.8	4.6	6.7	10.2	12.6	12.2	10.2	4.2	-0.9	-4.6	(22)	
(23)		5%	DB	-0.5	4.5	10.1	16.5	19.9	22.8	25.8	25.1	20.4	13.9	6.6	0.1	(23)
(24)		MCWB	-6.3	-3.2	-0.2	3.6	6.1	9.1	11.7	11.4	8.7	3.2	-1.7	-5.8	(24)	
(25)		10%	DB	-2.4	2.3	8.2	14.6	18.3	21.3	24.1	23.4	18.7	12.2	4.8	-1.6	(25)
(26)		MCWB	-7.4	-4.4	-1.1	2.8	5.4	8.7	10.9	10.9	7.6	2.4	-2.6	-6.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.5	-0.6	3.0	6.6	9.0	13.7	15.4	15.4	13.4	7.3	0.8	-2.8	(27)
(28)		MCDWB	3.7	8.7	14.7	18.3	18.1	22.4	27.1	24.8	22.4	13.6	9.7	4.7	(28)	
(29)		2%	WB	-5.0	-1.9	1.3	5.1	8.0	12.1	14.3	14.2	11.7	5.4	-0.6	-4.5	(29)
(30)		MCDWB	1.1	6.0	10.8	16.8	17.7	20.6	24.1	22.4	19.4	13.5	7.6	1.9	(30)	
(31)		5%	WB	-6.2	-3.1	0.2	4.1	7.2	11.0	13.3	13.3	10.6	4.1	-1.6	-5.7	(31)
(32)		MCDWB	-0.9	4.2	9.2	15.0	16.6	19.1	21.6	21.1	17.8	12.2	6.1	-0.1	(32)	
(33)		10%	WB	-7.3	-4.3	-0.8	3.2	6.4	10.0	12.5	12.4	9.4	3.0	-2.5	-6.8	(33)
(34)		MCDWB	-2.6	2.0	7.7	13.5	15.7	17.9	20.4	20.2	16.5	11.3	4.6	-1.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.3	11.6	12.2	11.9	10.8	9.7	9.7	10.1	10.8	12.0	11.5	11.3	(35)	
(36)		5% DB	MCDBR	12.9	13.3	14.1	13.6	13.0	11.9	11.8	11.7	12.2	13.3	12.5	12.5	(36)
(37)		MCWBR	8.7	7.9	7.5	6.2	5.1	4.2	3.8	3.9	4.4	6.0	7.1	8.3	(37)	
(38)		5% WB	MCDBR	12.5	12.7	13.1	12.4	10.3	9.3	9.4	9.6	10.1	11.0	12.1	12.1	(38)
(39)		MCWBR	8.4	7.7	6.9	5.7	4.1	3.7	3.5	3.4	3.8	5.2	6.9	8.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.222	0.259	0.311	0.365	0.385	0.385	0.373	0.361	0.329	0.276	0.236	0.215	(40)	
(41)		taud	2.459	2.346	2.169	2.026	2.051	2.149	2.274	2.291	2.345	2.409	2.456	2.486	(41)	
(42)		Ebn at Noon	997	984	950	911	896	892	901	906	921	951	968	986	(42)	
(43)		Edh at Noon	80	103	137	168	167	152	133	128	114	95	79	72	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.01	3.89	5.28	6.39	6.72	6.46	6.42	6.05	5.24	4.55	3.40	2.86	(44)	
(45)		RadStd	0.22	0.22	0.31	0.31	0.41	0.44	0.46	0.40	0.32	0.22	0.22	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+0.27	N/A	N/A	N/A	N/A	N/A	-78	N/A	N/A	N/A

Nomenclature: See separate page