

WUSHAOLING, China

WMO: 527870

Lat: 37.1988N

Lon: 102.8680E

Elev: 9987

StdP: 10.11

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.0	-1.8	-23.3	2.2	16.8	-19.7	2.7	17.1	31.7	6.9	29.2	9.4	11.9	320	0.867

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	68.4	52.2	65.6	50.9	63.0	49.5	56.5	63.3	54.6	61.1	52.7	59.0	13.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.2	91.3	58.6	52.2	84.8	56.9	50.3	78.9	55.8	28.9	63.6	27.4	61.5	26.0	58.8	63.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	29.9	26.6	23.7	DB	-9.9	73.9	4.4	2.7	-13.1	75.8	-15.7	77.4	-18.1	78.9	-21.3	80.8
(5)				WB	-10.5	59.4	4.3	2.0	-13.6	60.8	-16.1	62.0	-18.5	63.1	-21.5	64.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.4	12.8	16.7	24.8	35.0	42.9	50.5	54.6	52.7	45.3	35.3	25.1	16.2	
	DBStd	15.94	7.82	8.10	8.56	8.29	6.69	4.86	4.71	4.53	5.36	6.59	7.43	7.28	
	HDD50	6043	1153	933	781	452	232	51	11	23	156	455	747	1049	
	HDD65	11162	1618	1353	1246	899	685	436	324	380	590	920	1197	1514	
	CDD50	358	0	0	0	3	12	65	153	108	16	1	0	0	
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH74	5	0	0	0	0	0	0	5	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	11.8	11.1	12.1	13.5	13.5	13.0	11.6	11.1	11.3	11.5	11.1	11.0	10.9	
Precipitation	PrecAvg	15.4	0.0	0.1	0.4	0.7	1.5	2.5	3.5	3.4	2.3	0.7	0.2	0.0	
	PrecMax	21.9	0.1	0.5	1.3	1.8	3.5	5.2	6.8	7.0	6.5	1.3	0.4	0.2	
	PrecMin	9.1	0.0	0.0	0.0	0.2	0.4	1.0	1.7	1.3	0.7	0.2	0.0	0.0	
	PrecStd	3.3	0.0	0.1	0.3	0.4	0.9	1.0	1.3	1.4	1.1	0.4	0.1	0.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.2	44.0	52.7	62.4	65.0	68.0	73.6	70.8	65.0	57.7	47.4	39.0	
		MCWB	24.6	27.7	32.8	39.6	43.8	47.7	55.0	54.9	48.9	41.4	30.6	24.9	
	2%	DB	33.2	37.7	45.7	56.0	60.5	64.7	69.8	66.9	60.1	52.5	42.7	34.1	
		MCWB	21.4	25.2	30.1	37.4	42.0	47.7	53.5	53.4	46.2	38.1	28.9	22.4	
	5%	DB	28.7	33.3	41.2	51.6	57.6	62.0	66.6	64.0	56.9	48.7	39.1	30.6	
		MCWB	18.8	22.8	28.1	35.5	40.8	46.6	52.3	51.9	45.7	36.5	27.2	20.4	
	10%	DB	24.7	29.2	36.9	47.6	54.6	59.5	63.7	61.2	53.9	45.0	35.8	27.3	
		MCWB	16.4	20.3	26.2	33.8	39.6	45.3	51.3	50.7	44.3	34.9	25.5	18.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	28.7	34.3	42.1	46.5	54.3	59.3	59.7	55.1	43.7	32.1	25.2
			MCDB	38.7	41.4	50.2	54.9	58.4	60.8	68.1	64.8	59.4	52.8	43.7	37.9
2%		WB	21.5	25.6	30.9	39.3	44.2	51.3	56.8	56.5	50.5	40.6	29.8	22.6	
		MCDB	32.9	37.2	43.5	52.5	56.1	58.0	65.3	62.1	55.1	48.5	40.6	33.4	
5%		WB	18.9	23.0	28.8	37.0	42.5	49.3	54.8	54.7	48.1	38.4	27.9	20.6	
		MCDB	28.3	32.8	39.4	48.7	53.6	56.6	62.7	60.4	53.2	45.5	37.6	30.0	
10%		WB	16.6	20.5	26.9	34.9	41.0	47.7	53.0	52.9	46.1	36.4	26.1	18.6	
		MCDB	24.4	28.6	35.8	45.6	51.7	55.8	60.3	58.2	51.2	43.5	34.3	26.9	
Mean Daily Temperature Range	5% DB	MDBR	16.4	17.0	15.7	15.5	15.3	13.6	13.2	13.1	13.1	14.2	15.7	16.3	
		MCDBR	20.5	22.2	20.8	20.6	20.1	17.7	18.1	17.6	17.2	18.4	19.1	19.3	
		MCWBR	13.1	13.7	11.4	10.5	9.8	8.4	8.7	8.9	9.2	9.6	10.3	12.1	
	5% WB	MCDBR	20.1	21.3	19.0	18.6	17.5	14.1	15.5	14.5	14.2	16.5	17.9	18.9	
		MCWBR	13.1	13.5	10.9	10.4	9.6	8.1	8.7	8.6	9.5	9.9	10.2	12.0	
Clear-Sky Solar Irradiance	taub	0.267	0.319	0.383	0.426	0.427	0.422	0.406	0.414	0.387	0.345	0.285	0.257		
	taud	2.343	2.161	1.985	1.912	1.989	2.068	2.188	2.142	2.176	2.212	2.334	2.390		
	Ebn at Noon	294	287	276	271	272	273	276	271	272	274	284	292		
	Edh at Noon	29	40	53	60	56	52	46	47	43	37	29	26		
All-Sky Solar Radiation	RadAvg	931	1197	1522	1776	1901	1875	1805	1646	1337	1232	1011	872		
	RadStd	65	59	93	98	104	107	159	114	103	97	53	36		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+146	+58

Nomenclature: See separate page