

YU ZHONG, China

WMO: 529830

Lat: 35.8664N

Lon: 104.1431E

Elev: 6152

StdP: 11.71

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.3	6.2	-7.2	4.7	13.1	-4.0	5.6	15.8	12.4	26.3	10.9	25.4	2.9	250	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	84.9	61.5	82.2	61.2	79.6	60.1	66.4	77.5	65.2	75.5	63.8	73.7	6.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.2	109.6	71.2	61.9	104.2	70.6	60.5	99.1	69.1	35.0	77.5	33.9	75.8	32.7	73.7	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	12.4	10.7	DB	-2.4	89.6	5.5	2.6	-6.3	91.5	-9.5	93.0	-12.6	94.5	-16.6	96.4
			WB	-3.4	68.4	5.1	1.5	-7.1	69.5	-10.1	70.4	-12.9	71.3	-16.7	72.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	20.6	28.1	39.9	50.6	57.5	64.0	67.6	66.4	57.5	47.6	34.7	23.3	(6)
(7)		DBStd	17.27	6.42	7.67	7.50	6.87	5.96	4.31	4.54	4.91	4.65	5.70	6.57	5.57	(7)
(8)		HDD50	3337	913	615	320	73	10	0	0	4	114	459	829		(8)
(9)		HDD65	6964	1378	1035	778	431	239	66	26	41	227	540	909	1294	(9)
(10)		CDD50	2083	0	0	7	92	242	420	545	508	230	39	0	0	(10)
(11)		CDD65	236	0	0	0	0	6	36	106	85	3	0	0	0	(11)
(12)		CDH74	2382	0	0	0	33	140	443	1013	711	39	3	0	0	(12)
(13)		CDH80	501	0	0	0	3	13	69	264	150	2	0	0	0	(13)
(14)	Wind	WSAvg	4.7	3.8	4.3	5.1	5.7	5.7	5.4	5.3	5.0	4.6	4.4	3.9	3.6	(14)
(15)	Precipitation	PrecAvg	13.9	0.1	0.2	0.4	0.8	1.9	2.0	2.8	2.7	1.9	1.0	0.1	0.0	(15)
(16)		PrecMax	19.8	0.4	0.5	1.1	3.3	3.9	5.4	5.7	5.3	3.4	2.2	0.4	0.2	(16)
(17)		PrecMin	9.6	0.0	0.0	0.0	0.1	0.5	0.7	0.6	0.9	0.7	0.0	0.0	0.0	(17)
(18)		PrecStd	2.3	0.1	0.1	0.2	0.6	1.0	1.1	1.3	1.2	0.8	0.5	0.1	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.5	56.5	68.9	78.4	81.6	85.2	90.0	87.6	78.1	70.9	58.4	45.5	(19)
(20)		MCWB	31.6	38.9	45.4	51.0	54.9	58.6	63.1	63.8	58.9	52.2	42.0	33.1		(20)
(21)		2%	DB	40.9	49.4	62.6	72.6	77.7	82.0	85.7	84.0	74.3	66.3	54.6	40.9	(21)
(22)		MCWB	28.6	35.0	42.9	49.2	53.6	58.3	62.1	63.2	57.2	51.1	40.6	30.5		(22)
(23)		5%	DB	36.6	45.1	58.1	68.3	74.7	79.1	82.9	81.1	71.1	62.4	50.6	37.7	(23)
(24)		MCWB	26.5	33.2	40.6	47.6	53.0	57.8	62.0	62.4	56.7	49.6	39.1	28.9		(24)
(25)		10%	DB	32.5	40.9	53.8	64.6	71.3	76.1	79.9	78.1	68.0	58.6	47.0	34.4	(25)
(26)		MCWB	24.2	31.1	38.9	45.9	52.2	57.2	61.7	61.6	56.2	47.7	37.3	26.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.2	41.5	48.5	54.3	59.7	64.9	68.7	67.7	63.8	55.6	44.1	34.0	(27)
(28)		MCDWB	45.6	54.2	63.7	69.5	73.3	75.3	82.6	80.8	70.6	65.2	54.6	42.7		(28)
(29)		2%	WB	29.2	36.4	44.2	51.3	57.4	63.0	66.9	66.3	61.0	53.2	42.0	31.3	(29)
(30)		MCDWB	40.4	47.5	58.1	66.4	69.5	72.9	78.6	77.2	67.9	61.8	51.1	39.6		(30)
(31)		5%	WB	26.7	33.6	41.7	49.5	55.5	61.2	65.5	65.3	59.1	51.4	40.3	29.2	(31)
(32)		MCDWB	36.0	44.0	55.8	64.6	68.1	71.0	76.2	75.5	66.0	59.3	49.3	37.1		(32)
(33)		10%	WB	24.5	31.2	39.6	47.5	54.0	59.7	64.0	64.2	57.4	49.4	38.0	27.2	(33)
(34)		MCDWB	32.0	39.9	52.5	61.4	67.3	70.4	74.4	73.6	64.9	57.0	46.2	34.0		(34)
(35)	Mean Daily Temperature Range	MDBR	21.4	21.2	21.1	22.8	22.2	21.5	21.0	19.9	17.9	19.1	20.3	20.6		(35)
(36)		5% DB	MCDBR	28.3	28.8	29.4	30.0	29.2	29.0	28.2	25.6	25.1	25.7	26.6	24.8	(36)
(37)		MCWBR	18.4	16.7	13.7	12.7	11.4	10.7	9.5	8.9	10.7	12.8	14.7	15.9		(37)
(38)		5% WB	MCDBR	27.3	27.1	26.6	26.3	23.4	20.5	21.3	19.6	18.3	21.6	24.0	23.2	(38)
(39)		MCWBR	17.9	16.1	13.0	11.8	10.3	8.8	8.5	7.5	9.4	11.6	14.0	15.1		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.403	0.465	0.499	0.494	0.479	0.462	0.474	0.451	0.418	0.357	0.327		(40)
(41)		taud	2.094	1.949	1.825	1.784	1.875	1.979	2.105	2.040	2.053	2.050	2.131	2.177		(41)
(42)		Ebn at Noon	261	257	252	251	255	258	261	255	254	249	255	260		(42)
(43)		Edh at Noon	38	50	62	69	64	57	50	53	49	45	37	33		(43)
(44)	All-Sky Solar Radiation	RadAvg	913	1155	1476	1752	1875	1848	1804	1660	1264	1145	980	879		(44)
(45)		RadStd	91	90	102	105	113	108	171	122	95	108	80	53		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+58	N/A

Nomenclature: See separate page