

HUAJIALING, China

WMO: 529960

Lat: 35.3861N

Lon: 105.0083E

Elev: 8038

StdP: 10.90

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	5.0	-13.1	3.6	19.8	-9.4	4.5	18.8	27.1	17.0	24.3	16.7	10.1	0	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	72.8	56.7	70.4	56.0	68.3	55.6	62.4	67.3	61.0	65.3	59.7	63.6	10.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.0	108.6	64.4	59.7	103.6	63.0	58.4	98.9	61.8	32.8	67.5	31.6	65.5	30.5	63.7	68.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.4	23.9	21.1		-3.1	77.4	4.4	4.1	-6.2	80.4	-8.8	82.8	-11.2	85.1	-14.4	88.1	
				DB												
				WB	-3.8	64.3	4.2	1.5	-6.8	65.4	-9.3	66.2	-11.7	67.1	-14.7	68.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.8	18.3	22.8	32.3	42.8	50.3	57.0	60.6	59.0	50.9	41.2	31.5	21.6
	DBStd	16.01	7.78	7.48	8.59	8.10	6.45	4.89	4.36	4.62	5.50	6.30	7.31	7.11
	HDD50	4385	984	762	549	238	77	7	0	2	53	280	554	879
	HDD65	8857	1449	1182	1013	667	455	243	148	190	423	739	1004	1344
	CDD50	1020	0	0	1	21	87	215	328	282	80	6	0	0
	CDD65	17	0	0	0	0	0	1	11	5	0	0	0	0
	CDH74	35	0	0	0	0	0	3	27	5	0	0	0	0
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	10.5	9.0	9.7	11.2	12.1	12.0	11.0	10.9	11.0	10.7	10.0	9.3	9.0
Precipitation	PrecAvg	20.2	0.2	0.2	0.6	1.3	2.2	2.6	3.7	4.1	3.2	1.5	0.4	0.1
	PrecMax	30.1	0.3	0.6	1.3	3.1	4.6	4.6	8.1	13.1	7.3	3.1	0.9	0.6
	PrecMin	11.5	0.0	0.0	0.0	0.2	0.2	0.6	0.9	1.2	0.7	0.4	0.0	0.0
	PrecStd	4.6	0.1	0.2	0.3	0.8	1.1	1.1	1.7	2.4	1.5	0.8	0.3	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.9	46.9	58.3	67.5	70.0	73.8	77.1	74.4	70.2	60.1	50.8	41.7
		MCWB	28.3	33.0	40.1	46.9	49.0	53.2	59.1	58.3	53.6	46.1	38.4	28.4
	2%	DB	35.8	40.7	52.5	61.6	66.4	70.5	73.5	71.6	64.9	55.7	46.8	37.1
		MCWB	25.5	29.4	37.7	44.6	48.1	52.7	58.0	58.0	52.5	44.9	36.3	26.2
	5%	DB	32.3	36.5	48.0	57.9	63.5	68.3	70.8	69.1	61.7	52.4	43.7	34.0
		MCWB	23.6	28.0	35.9	43.2	47.4	52.6	57.5	58.2	52.4	43.9	34.6	24.9
	10%	DB	29.0	32.8	44.0	54.6	60.8	65.9	68.5	66.7	58.9	49.4	40.7	31.1
		MCWB	21.9	26.3	33.9	41.5	46.6	52.4	57.4	57.2	51.8	43.2	33.1	23.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.4	34.1	44.8	51.6	55.2	60.9	64.6	63.8	60.8	50.5	41.5	30.1
		MCDB	38.4	42.1	52.7	60.5	62.9	64.5	71.3	69.0	62.2	54.3	47.0	38.1
	2%	WB	26.5	31.2	39.8	48.1	53.2	58.5	62.8	62.3	57.3	48.3	39.0	27.8
		MCDB	34.3	38.1	48.4	55.2	59.8	62.3	68.2	67.0	59.9	52.0	42.5	33.4
	5%	WB	24.3	29.1	37.1	46.0	51.3	56.9	61.3	61.1	54.8	46.5	37.1	26.1
		MCDB	31.2	34.6	45.1	53.9	57.5	61.9	66.0	65.3	58.2	49.8	40.5	31.8
	10%	WB	22.3	27.0	34.9	43.7	49.4	55.5	60.1	59.8	53.0	44.6	35.2	24.5
		MCDB	28.1	31.7	42.7	51.7	55.9	60.8	64.3	63.6	56.1	47.3	38.9	29.8
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.2	13.0	14.7	14.5	12.9	12.3	11.8	10.2	10.2	10.9	11.4
		MCDBR	15.5	16.4	18.3	18.5	17.8	16.4	16.2	14.8	13.8	14.0	14.2	14.5
		MCWBR	9.3	9.7	9.6	8.8	8.1	6.9	6.3	6.1	6.8	7.6	8.4	8.7
	5% WB	MCDBR	14.3	14.3	16.5	16.8	15.3	13.0	12.9	12.2	11.1	11.5	12.1	12.7
	MCWBR	9.3	9.1	10.2	9.3	8.8	6.8	6.3	6.0	6.8	7.5	8.2	8.4	
Clear-Sky Solar Irradiance	taub	0.326	0.374	0.422	0.442	0.432	0.419	0.411	0.429	0.404	0.383	0.332	0.303	
	taud	2.128	2.005	1.912	1.904	2.023	2.130	2.224	2.134	2.166	2.137	2.193	2.235	
	Ebn at Noon	271	268	266	267	272	274	276	268	269	263	266	273	
	Edh at Noon	37	48	57	61	55	49	45	48	44	41	35	31	
All-Sky Solar Radiation	RadAvg	862	1072	1400	1694	1819	1790	1720	1593	1187	1048	914	831	
	RadStd	91	115	115	121	121	119	191	132	96	115	105	76	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-184	+61	N/A

Nomenclature: See separate page