

HUAJIALING, China

WMO: 529960

Lat: 35.3861N

Lon: 105.0083E

Elev: 2450

StdP: 75.15

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.8	-15.0	-25.1	0.5	-6.8	-23.0	0.6	-7.3	12.1	-8.3	10.9	-8.5	4.5	0	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	22.6	13.7	21.3	13.3	20.2	13.1	16.9	19.6	16.1	18.5	15.4	17.6	4.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	15.5	18.0	15.4	14.8	17.2	14.7	14.1	16.5	58.3	19.7	55.5	18.6	53.0	17.6	20.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.2	10.7	9.4	DB	-19.5	25.2	2.4	2.3	-21.2	26.9	-22.6	28.2	-24.0	29.5	-25.8	31.1	
			WB	-19.9	18.0	2.3	0.8	-21.6	18.6	-22.9	19.0	-24.3	19.5	-26.0	20.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	-7.6	-5.1	0.2	6.0	10.2	13.9	15.9	15.0	10.5	5.1	-0.3	-5.8	(6)
(7)		DBStd	8.89	4.32	4.15	4.77	4.50	3.58	2.72	2.42	2.56	3.06	3.50	4.06	3.95	(7)
(8)		HDD10.0	2436	547	423	305	132	43	4	0	1	29	156	308	488	(8)
(9)		HDD18.3	4921	805	657	563	371	253	135	82	106	235	411	558	747	(9)
(10)		CDD10.0	567	0	0	1	12	48	119	182	157	44	3	0	0	(10)
(11)		CDD18.3	9	0	0	0	0	0	1	6	3	0	0	0	0	(11)
(12)		CDH23.3	19	0	0	0	0	0	2	15	3	0	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.7	4.0	4.4	5.0	5.4	5.4	4.9	4.9	4.8	4.5	4.1	4.0	(14)	
(15)	Precipitation	PrecAvg	513	4	6	15	34	56	66	95	105	81	38	10	3	(15)
(16)		PrecMax	764	8	14	32	78	116	117	206	333	186	79	24	14	(16)
(17)		PrecMin	293	0	1	1	5	4	15	23	30	18	10	0	0	(17)
(18)		PrecStd	117	3	4	8	20	27	28	44	60	39	20	7	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.0	8.3	14.6	19.7	21.1	23.2	25.1	23.5	21.2	15.6	10.5	5.4	(19)
(20)			MCWB	-2.0	0.5	4.5	8.3	9.5	11.8	15.1	14.6	12.0	7.8	3.5	-2.0	(20)
(21)		2%	DB	2.1	4.8	11.4	16.5	19.1	21.4	23.0	22.0	18.3	13.2	8.2	2.8	(21)
(22)			MCWB	-3.6	-1.5	3.2	7.0	8.9	11.5	14.4	14.4	11.4	7.2	2.4	-3.2	(22)
(23)		5%	DB	0.2	2.5	8.9	14.4	17.5	20.1	21.6	20.6	16.5	11.3	6.5	1.1	(23)
(24)			MCWB	-4.7	-2.2	2.2	6.2	8.6	11.4	14.1	14.5	11.3	6.6	1.4	-4.0	(24)
(25)		10%	DB	-1.7	0.4	6.7	12.5	16.0	18.8	20.3	19.3	15.0	9.7	4.9	-0.5	(25)
(26)			MCWB	-5.6	-3.2	1.0	5.3	8.1	11.3	14.1	14.0	11.0	6.2	0.6	-4.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.5	1.2	7.1	10.9	12.9	16.0	18.1	17.7	16.0	10.3	5.3	-1.1	(27)
(28)			MADB	3.6	5.6	11.5	15.9	17.2	18.1	21.8	20.5	16.8	12.4	8.3	3.4	(28)
(29)		2%	WB	-3.1	-0.4	4.3	8.9	11.8	14.7	17.1	16.8	14.1	9.1	3.9	-2.3	(29)
(30)			MADB	1.3	3.4	9.1	12.9	15.4	16.9	20.1	19.4	15.5	11.1	5.9	0.8	(30)
(31)		5%	WB	-4.3	-1.6	2.8	7.8	10.7	13.9	16.3	16.2	12.7	8.1	2.8	-3.3	(31)
(32)			MADB	-0.5	1.5	7.3	12.1	14.2	16.6	18.9	18.5	14.6	9.9	4.7	-0.1	(32)
(33)		10%	WB	-5.4	-2.8	1.6	6.5	9.7	13.0	15.6	15.4	11.7	7.0	1.8	-4.2	(33)
(34)			MADB	-2.1	-0.2	5.9	11.0	13.3	16.0	17.9	17.6	13.4	8.5	3.8	-1.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	6.2	7.2	8.2	8.1	7.2	6.8	6.5	5.7	6.1	6.3	(35)	
(36)			MADB	8.6	9.1	10.1	10.3	9.9	9.1	9.0	8.2	7.7	7.8	7.9	8.1	(36)
(37)			MCWBR	5.2	5.4	5.3	4.9	4.5	3.8	3.5	3.4	3.8	4.2	4.6	4.8	(37)
(38)		5% WB	MADB	8.0	7.9	9.2	9.3	8.5	7.2	7.2	6.8	6.2	6.4	6.7	7.1	(38)
(39)			MCWBR	5.2	5.1	5.7	5.2	4.9	3.8	3.5	3.3	3.8	4.2	4.5	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.374	0.422	0.442	0.432	0.419	0.411	0.429	0.404	0.383	0.332	0.303	(40)	
(41)		taud	2.128	2.005	1.912	1.904	2.023	2.130	2.224	2.134	2.166	2.137	2.193	2.235	(41)	
(42)		Ebn at Noon	853	846	838	843	856	864	869	846	849	829	840	861	(42)	
(43)		Edh at Noon	118	151	181	192	173	155	141	151	139	130	110	99	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.72	3.38	4.41	5.34	5.73	5.64	5.42	5.02	3.74	3.31	2.88	2.62	(44)	
(45)		RadStd	0.29	0.36	0.36	0.38	0.38	0.38	0.60	0.42	0.30	0.36	0.33	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-102	+34	N/A	N/A

Nomenclature: See separate page