

ERENHOT, China

WMO: 530680

Lat: 43.6304N

Lon: 111.9385E

Elev: 966

StdP: 90.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -27.7	(c) -25.6	(d) -32.4	(e) 0.2	(f) -23.6	(g) -30.4	(h) 0.3	(i) -22.1	(j) 11.2	(k) -6.6	(l) 10.0	(m) -8.7	(n) 2.2	(o) 270	(p) 0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.4	(c) 34.7	(d) 17.0	(e) 32.9	(f) 16.3	(g) 31.2	(h) 15.8	(i) 19.7	(j) 27.7	(k) 18.7	(l) 27.0	(m) 17.9	(n) 26.3	(o) 3.9	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	14.2	22.1	16.2	13.0	21.6	15.0	12.0	21.5	61.1	27.6	57.4	26.9	54.5	26.2	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	9.9	8.5	-30.1	37.3	2.6	2.0	-31.9	38.8	-33.4	40.0	-34.9	41.1	-36.8	42.5
			-30.2	21.4	2.6	1.8	-32.1	22.8	-33.6	23.9	-35.0	24.9	-36.9	26.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-16.3	-11.0	-1.7	8.0	15.1	21.3	24.5	22.4	15.8	6.4	-4.8	-13.6
	DBStd	14.91	5.02	6.01	5.82	5.46	4.79	3.80	3.06	3.29	4.44	5.12	6.08	5.14
	HDD10.0	3196	816	588	363	101	11	0	0	0	7	133	443	733
	HDD18.3	5124	1074	822	621	312	122	15	1	6	97	371	693	991
	CDD10.0	1587	0	0	1	40	170	339	451	383	182	21	0	0
	CDD18.3	474	0	0	0	2	23	104	193	131	22	1	0	0
	CDH23.3	5250	0	0	0	37	367	1174	2126	1294	246	6	0	0
	CDH26.7	2123	0	0	0	7	120	464	975	497	60	1	0	0
Wind	WSAvg	3.8	3.3	3.4	4.1	4.6	4.8	3.9	3.5	3.3	3.6	3.7	3.7	3.4
Precipitation	PrecAvg	135	1	1	2	5	11	21	33	34	16	6	2	1
	PrecMax	256	9	4	17	21	36	79	80	117	61	38	11	6
	PrecMin	39	0	0	0	0	0	1	3	0	0	0	0	0
	PrecStd	47	2	1	3	6	10	15	20	26	14	8	2	1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.3	8.2	18.0	27.5	32.7	35.8	38.0	35.4	30.9	23.9	13.1	2.5
		MCWB	-3.9	1.1	5.9	10.8	13.5	16.0	19.0	17.8	14.4	11.0	4.0	-2.1
	2%	DB	-3.2	4.4	14.0	23.7	30.0	33.5	35.5	33.1	28.3	20.4	9.8	-1.3
		MCWB	-6.3	-1.5	3.8	9.0	12.5	15.5	17.7	17.0	13.8	9.4	2.7	-4.8
	5%	DB	-5.8	1.5	11.1	20.8	27.4	31.3	33.5	31.3	26.1	17.7	6.9	-3.7
		MCWB	-8.2	-3.0	2.4	7.9	11.4	14.9	17.1	16.4	12.8	7.9	0.9	-6.5
	10%	DB	-8.2	-1.1	8.2	18.1	24.9	29.4	31.7	29.5	24.1	15.1	4.3	-5.8
		MCWB	-10.1	-4.7	0.8	6.6	10.4	14.4	16.7	15.8	12.2	6.3	-0.5	-8.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.7	1.6	6.3	11.7	14.9	18.6	21.7	21.1	17.4	12.6	5.1	-2.0
		MCDB	0.3	7.2	16.8	23.1	26.4	25.5	30.0	28.5	22.3	20.8	12.5	2.4
	2%	WB	-6.3	-1.0	4.2	9.9	13.7	17.2	20.1	19.5	15.5	10.1	2.7	-4.7
		MCDB	-3.4	4.1	13.2	21.5	26.0	26.4	28.3	27.0	23.8	18.8	9.3	-1.6
	5%	WB	-8.2	-2.8	2.6	8.4	12.5	16.5	19.1	18.5	14.3	8.5	1.2	-6.4
		MCDB	-5.9	1.6	10.5	20.0	24.6	26.5	27.9	26.2	23.2	16.1	6.6	-3.8
	10%	WB	-10.1	-4.7	0.9	6.9	11.3	15.7	18.3	17.6	13.2	6.9	-0.4	-8.1
		MCDB	-8.2	-1.0	8.1	17.4	23.2	26.0	27.1	25.7	21.9	14.1	4.2	-5.9
Mean Daily Temperature Range	5% DB	MDBR	11.3	13.4	13.8	13.7	13.5	12.2	11.4	11.5	12.4	12.3	11.4	10.4
		MCDBR	13.6	15.9	17.4	17.1	17.2	14.8	13.8	13.7	14.6	15.4	13.8	12.1
		MCWBR	11.1	11.4	10.3	8.7	7.5	5.0	4.2	4.5	5.8	7.9	8.7	9.4
	5% WB	MCDBR	13.6	15.6	16.9	16.0	14.5	11.7	10.8	10.7	11.9	14.0	13.4	11.9
		MCWBR	11.1	11.2	10.3	8.3	6.8	4.2	3.9	4.2	5.5	7.7	8.6	9.5
Clear-Sky Solar Irradiance	taub		0.271	0.303	0.343	0.395	0.440	0.468	0.438	0.423	0.384	0.336	0.290	0.272
	taud		2.278	2.192	2.119	2.023	1.952	1.973	2.122	2.129	2.167	2.234	2.273	2.249
	Ebn at Noon		858	883	887	865	834	810	831	829	834	830	821	812
	Edh at Noon		84	110	136	163	181	178	152	145	129	105	84	79
All-Sky Solar Radiation	RadAvg		2.17	3.32	4.96	6.24	6.88	6.65	6.58	6.10	5.08	3.78	2.57	1.85
	RadStd		0.26	0.25	0.32	0.30	0.35	0.39	0.27	0.23	0.20	0.19	0.19	0.24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	-1.53	N/A	N/A	-0.71	N/A	N/A	N/A	N/A
	N/A	N/A	-0.99	N/A	-0.53	-0.73	N/A	N/A	N/A	N/A

Nomenclature: See separate page