

ABAG QI, China

WMO: 531920

Lat: 44.0168N

Lon: 115.0033E

Elev: 3765

StdP: 12.80

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.4	-19.9	-29.6	1.2	-21.8	-26.3	1.5	-18.1	26.0	7.3	22.5	4.9	2.6	290	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	89.9	61.6	86.5	60.4	83.4	59.5	66.8	78.4	65.0	77.4	63.4	76.1	10.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.3	100.1	71.3	61.1	92.6	70.2	59.1	86.0	68.8	33.6	78.6	32.1	77.3	30.8	75.9	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.6	22.4	19.0	-27.0	94.9	4.9	3.3	-30.6	97.3	-33.5	99.3	-36.2	101.1	-39.8	103.6		
			-27.3	68.9	4.8	1.9	-30.8	70.3	-33.6	71.3	-36.4	72.4	-39.9	73.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	37.2	-3.5	6.0	23.8	41.7	54.9	65.7	71.5	67.8	56.3	39.2	18.8	1.7	(6)
(7)		DBStd	27.40	9.46	11.06	11.05	9.66	8.62	6.77	5.54	5.85	8.06	9.22	11.13	9.19	(7)
(8)		HDD50	6847	1658	1232	812	281	48	0	0	33	351	935	1497		(8)
(9)		HDD65	10617	2123	1652	1276	699	330	71	7	276	800	1385	1962		(9)
(10)		CDD50	2161	0	0	1	33	198	473	668	551	221	16	0	0	(10)
(11)		CDD65	455	0	0	0	0	15	94	210	122	14	0	0	0	(11)
(12)		CDH74	4690	0	0	0	20	291	1019	2030	1142	186	2	0	0	(12)
(13)		CDH80	1531	0	0	0	2	73	321	756	346	33	0	0	0	(13)
(14)	Wind	WSAvg	7.4	5.3	5.9	8.3	10.0	10.3	8.0	7.1	6.7	7.1	7.4	6.7	5.6	(14)
(15)	Precipitation	PrecAvg	9.5	0.0	0.1	0.1	0.3	0.7	1.6	2.7	2.3	1.0	0.4	0.1	0.1	(15)
(16)		PrecMax	12.0	0.2	0.3	0.5	1.2	2.7	3.0	6.0	5.6	2.7	1.5	0.5	0.4	(16)
(17)		PrecMin	5.0	0.0	0.0	0.0	0.0	0.1	0.3	0.9	0.4	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.9	0.0	0.1	0.1	0.3	0.6	0.7	1.2	1.5	0.6	0.3	0.1	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	41.5	60.3	76.9	87.6	91.5	95.1	92.7	84.1	70.2	51.4	32.6	(19)
(20)		MCWB	22.0	31.7	40.4	49.2	54.8	59.6	63.7	63.0	57.0	49.6	37.7	26.2		(20)
(21)		2%	DB	20.9	34.2	52.5	69.4	81.0	87.1	91.2	87.4	79.2	64.8	44.8	24.2	(21)
(22)		MCWB	17.0	26.7	36.6	45.8	52.5	58.5	63.2	61.5	55.1	47.3	34.3	20.1		(22)
(23)		5%	DB	15.9	29.3	46.7	64.4	76.7	83.7	87.6	83.6	75.2	59.5	40.0	19.4	(23)
(24)		MCWB	12.9	23.5	33.5	43.6	51.0	57.6	62.3	60.2	53.5	43.9	31.3	16.3		(24)
(25)		10%	DB	11.4	23.9	41.6	59.7	72.3	80.1	84.1	80.3	71.4	54.6	35.2	15.5	(25)
(26)		MCWB	9.3	19.4	30.9	41.1	49.3	56.7	61.3	59.5	52.5	41.5	28.6	13.0		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	31.8	41.5	50.9	57.3	63.5	70.1	68.6	61.7	52.4	39.1	26.4	(27)
(28)		MCDWB	27.5	39.3	56.2	73.1	73.8	78.0	80.2	79.6	74.2	66.6	49.6	32.2		(28)
(29)		2%	WB	17.1	27.6	37.5	47.2	54.8	62.0	67.7	66.2	58.2	48.5	34.7	20.2	(29)
(30)		MCDWB	20.7	33.7	51.3	64.9	74.5	77.2	79.2	77.6	71.0	61.7	43.7	24.0		(30)
(31)		5%	WB	13.0	23.5	34.1	44.6	53.0	60.6	66.0	64.4	56.4	45.5	31.7	16.3	(31)
(32)		MCDWB	15.9	29.2	45.9	62.2	71.3	75.7	78.6	75.1	69.9	56.9	39.4	19.2		(32)
(33)		10%	WB	9.3	19.5	31.0	42.0	50.8	59.2	64.4	62.8	54.5	42.5	28.7	13.0	(33)
(34)		MCDWB	11.4	23.9	41.1	58.6	69.0	73.7	78.2	74.3	68.0	53.9	35.4	15.4		(34)
(35)	Mean Daily Temperature Range		MDBR	19.0	22.1	22.5	23.4	23.8	21.2	19.9	20.6	22.3	21.7	19.8	17.8	(35)
(36)		5% DB	MCDBR	23.2	26.3	28.3	30.0	30.5	26.5	24.8	25.1	26.3	27.8	24.4	21.7	(36)
(37)			MCWBR	20.0	20.0	17.0	14.8	12.4	8.7	7.3	8.2	10.7	14.6	16.1	18.4	(37)
(38)			MCDBR	22.9	25.8	27.4	27.5	25.3	20.6	19.1	18.8	21.6	24.6	23.7	21.4	(38)
(39)		5% WB	MCWBR	19.8	19.9	16.9	14.4	11.3	7.4	7.3	7.8	10.4	14.4	16.0	18.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.262	0.296	0.338	0.391	0.452	0.473	0.436	0.423	0.373	0.335	0.287	0.268	(40)	
(41)		taud	2.296	2.209	2.140	2.046	1.923	1.972	2.150	2.147	2.223	2.251	2.284	2.263	(41)	
(42)		Ebn at Noon	275	282	283	275	261	255	264	263	268	263	261	259	(42)	
(43)		Edh at Noon	26	34	42	50	59	56	47	45	38	32	26	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	673	1039	1520	1889	2104	2047	2015	1871	1556	1133	755	558	(44)	
(45)		RadStd	77	82	102	110	127	131	70	62	84	71	60	56	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-1.17	N/A	N/A	+126	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	-3.01	N/A	-0.63	-1.15	N/A	N/A	N/A	N/A	

Nomenclature: See separate page