

JURH, China

WMO: 532760

Lat: 42.3979N

Lon: 112.9010E

Elev: 3780

StdP: 12.80

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-9.2	-24.8	1.6	1.5	-21.1	2.0	1.6	29.5	19.7	26.4	15.7	9.9	250	0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	91.7	61.5	88.6	60.5	85.7	59.6	67.2	79.9	65.4	78.0	63.8	77.4	10.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.7	101.6	72.3	61.3	93.3	70.9	59.1	86.2	69.7	34.0	80.0	32.5	77.4	31.2	77.6	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.6	24.5	21.8	DB	-17.9	96.3	4.6	3.2	-21.2	98.6	-23.9	100.4	-26.4	102.2	-29.8	104.5	
			WB	-18.4	69.0	4.5	2.0	-21.6	70.4	-24.2	71.6	-26.7	72.7	-30.0	74.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.2	8.3	16.1	30.3	46.2	58.6	68.7	74.1	70.5	59.8	44.7	26.7	12.6	(6)
		DBStd	24.49	9.54	10.80	10.82	10.32	8.94	6.75	5.39	5.77	8.14	9.56	10.93	9.70	
		HDD50	5165	1293	949	613	191	25	0	0	17	217	700	1160		
		HDD65	8660	1758	1369	1074	567	238	38	2	191	630	1150	1625		
		CDD50	2681	0	0	3	77	291	561	747	636	312	53	1	0	
		CDD65	700	0	0	0	3	39	149	284	188	36	1	0	0	
		CDH74	6884	0	0	0	57	511	1504	2827	1633	345	7	0	0	
		CDH80	2444	0	0	0	11	144	526	1160	525	78	0	0	0	
		WSAvg	10.9	11.1	10.9	12.1	12.9	12.6	10.1	9.0	8.6	9.2	10.7	11.5	11.6	
		PrecAvg	8.4	0.1	0.1	0.1	0.2	0.6	1.1	2.3	2.2	1.0	0.4	0.1	0.0	
(15)	Precipitation	PrecMax	13.6	0.4	0.4	0.6	0.9	2.0	2.8	5.9	4.7	3.1	1.5	0.6	0.3	(15)
(16)		PrecMin	3.6	0.0	0.0	0.0	0.0	0.0	0.2	0.6	0.3	0.1	0.0	0.0	0.0	
(17)		PrecStd	2.5	0.1	0.1	0.2	0.2	0.4	0.7	1.6	1.3	0.8	0.3	0.1	0.1	
(18)																
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	39.0	49.0	65.2	81.1	89.0	94.0	96.8	92.8	87.1	74.8	58.5	41.7		(19)
(20)		0.4% MCWB	28.4	34.7	43.1	50.1	54.9	59.3	64.5	63.0	57.2	51.7	40.7	30.0		
(21)		2% DB	32.0	41.9	58.1	74.0	84.2	89.3	92.9	88.9	81.6	69.2	51.8	35.6		
(22)		2% MCWB	24.2	30.4	39.6	47.7	53.5	58.0	63.1	61.9	55.7	49.0	37.3	27.0		
(23)		5% DB	27.5	37.4	52.9	68.8	79.6	85.9	89.7	85.5	77.8	64.3	47.2	30.7		
(24)		5% MCWB	21.2	28.0	36.6	45.5	51.8	57.8	62.5	60.5	54.5	46.3	35.2	24.1		
(25)		10% DB	22.8	32.9	47.8	64.1	75.6	82.5	86.5	82.5	74.2	60.0	42.8	27.1		
(26)		10% MCWB	17.9	25.4	33.9	43.4	50.4	56.8	61.4	59.6	53.3	44.1	32.7	21.3		
(27)		0.4% WB	29.1	35.8	44.6	52.8	58.1	64.1	69.8	69.3	62.9	53.6	42.5	30.6		
(28)		0.4% MCDB	38.4	46.8	61.4	72.4	79.8	76.7	84.3	81.9	74.7	70.4	52.9	40.9		
(29)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	24.3	31.5	40.1	49.3	55.6	62.1	67.7	67.1	59.4	50.4	38.7	27.3		(29)
(30)		2% MCDB	31.5	40.6	56.2	69.1	77.5	76.7	81.5	78.6	72.4	64.7	50.3	35.0		
(31)		5% WB	21.3	28.5	37.3	46.8	53.9	60.9	66.2	65.1	57.3	48.0	35.6	24.2		
(32)		5% MCDB	27.3	37.3	51.1	65.4	74.6	76.7	78.7	76.8	71.5	61.2	46.6	30.5		
(33)		10% WB	18.0	25.5	34.5	44.5	51.9	59.5	64.7	63.3	55.5	45.6	33.0	21.3		
(34)		10% MCDB	22.8	32.9	47.3	63.0	71.1	75.5	78.5	76.2	70.0	57.7	42.5	26.9		
(35)	Mean Daily Temperature Range	MDBR	18.6	20.7	21.9	22.3	22.2	20.5	19.8	19.5	20.3	19.8	18.4	17.4		(35)
(36)		5% DB MCDBR	22.8	24.2	27.2	27.5	27.1	24.6	24.1	23.0	24.0	23.9	22.3	21.3		
(37)		5% DB MCWBR	17.0	16.5	15.7	13.2	11.3	8.1	6.7	7.3	9.1	11.6	13.2	15.3		
(38)		5% WB MCDBR	22.8	23.0	25.4	24.3	23.1	19.7	18.2	17.6	19.7	21.3	21.4	21.2		
(39)		5% WB MCWBR	17.1	15.9	15.2	12.5	10.1	6.8	6.6	7.4	8.9	11.3	13.3	15.5		
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.276	0.318	0.358	0.411	0.455	0.492	0.460	0.449	0.407	0.355	0.303	0.284		(41)
(42)		taud	2.261	2.149	2.067	1.972	1.913	1.900	2.048	2.052	2.098	2.173	2.234	2.229		
(43)		Ebn at Noon	274	276	278	270	261	251	258	257	258	258	258	257		
(44)		Edh at Noon	28	37	46	55	60	61	52	50	44	36	29	27		
(45)	All-Sky Solar Radiation	RadAvg	739	1073	1570	1937	2159	2081	2051	1910	1588	1218	826	637		(45)
		RadStd	84	95	117	111	129	144	74	78	75	60	75	62		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-1.19	N/A	N/A	N/A	N/A	
(47)	Regional (4 neighbors)	N/A	N/A	-2.63	N/A	-0.85	-1.28	N/A	N/A	N/A	N/A	

Nomenclature: See separate page