

JURH, China

WMO: 532760

Lat: 42.3979N

Lon: 112.9010E

Elev: 1152

StdP: 88.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.8	-22.9	-31.5	0.2	-16.9	-29.5	0.3	-16.9	13.2	-6.8	11.8	-9.0	4.4	250	0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	33.2	16.4	31.4	15.8	29.8	15.3	19.6	26.6	18.6	25.5	17.7	25.2	4.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	14.5	22.4	16.3	13.3	21.6	15.1	12.3	20.9	61.3	26.7	57.8	25.2	54.7	25.3	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
12.3	10.9	9.7	DB	-27.7	35.7	2.5	1.8	-29.5	37.0	-31.0	38.0	-32.5	39.0	-34.3	40.3	
			WB	-28.0	20.5	2.5	1.1	-29.8	21.3	-31.2	22.0	-32.6	22.6	-34.4	23.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	-13.2	-8.8	-0.9	7.9	14.8	20.4	23.4	21.4	15.5	7.1	-3.0	-10.8
	DBStd	13.61	5.30	6.00	6.01	5.73	4.96	3.75	2.99	3.21	4.52	5.31	6.07	5.39
	HDD10.0	2869	718	527	341	106	14	0	0	0	9	121	389	644
	HDD18.3	4811	977	761	597	315	132	21	1	10	106	350	639	903
	CDD10.0	1489	0	0	2	43	162	312	415	353	173	29	1	0
	CDD18.3	389	0	0	0	2	22	83	158	104	20	1	0	0
	CDH23.3	3824	0	0	0	32	284	836	1571	907	192	4	0	0
	CDH26.7	1358	0	0	0	6	80	292	644	292	43	0	0	0
Wind	WSAvg	4.9	5.0	4.9	5.4	5.8	5.6	4.5	4.0	3.8	4.1	4.8	5.2	5.2
Precipitation	PrecAvg	213	2	2	3	6	14	28	58	56	25	11	3	1
	PrecMax	346	10	9	14	22	52	71	150	120	78	39	15	8
	PrecMin	91	0	0	0	0	0	5	14	7	2	0	0	0
	PrecStd	63	2	2	4	6	11	19	40	34	20	8	3	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.9	9.5	18.4	27.3	31.7	34.5	36.0	33.8	30.6	23.8	14.7	5.4
		MCWB	-2.0	1.5	6.2	10.1	12.7	15.2	18.0	17.2	14.0	11.0	4.9	-1.1
	2%	DB	0.0	5.5	14.5	23.3	29.0	31.8	33.8	31.6	27.6	20.7	11.0	2.0
		MCWB	-4.3	-0.9	4.2	8.7	11.9	14.4	17.3	16.6	13.1	9.5	2.9	-2.8
	5%	DB	-2.5	3.0	11.6	20.4	26.5	29.9	32.1	29.7	25.4	17.9	8.4	-0.7
		MCWB	-6.0	-2.2	2.5	7.5	11.0	14.4	16.9	15.8	12.5	7.9	1.8	-4.4
	10%	DB	-5.1	0.5	8.8	17.8	24.2	28.1	30.3	28.1	23.4	15.5	6.0	-2.7
		MCWB	-7.8	-3.7	1.0	6.3	10.2	13.8	16.3	15.3	11.8	6.7	0.4	-5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.6	2.1	7.0	11.6	14.5	17.8	21.0	20.7	17.2	12.0	5.8	-0.8
		MCDB	3.5	8.2	16.3	22.5	26.6	24.9	29.0	27.7	23.7	21.3	11.6	4.9
	2%	WB	-4.3	-0.3	4.5	9.6	13.1	16.7	19.9	19.5	15.2	10.2	3.7	-2.6
		MCDB	-0.3	4.8	13.5	20.6	25.3	24.8	27.5	25.9	22.5	18.2	10.2	1.7
	5%	WB	-6.0	-2.0	2.9	8.2	12.1	16.0	19.0	18.4	14.0	8.9	2.0	-4.3
		MCDB	-2.6	3.0	10.6	18.6	23.7	24.8	26.0	24.9	22.0	16.2	8.1	-0.8
	10%	WB	-7.8	-3.6	1.4	6.9	11.1	15.3	18.2	17.4	13.1	7.5	0.5	-5.9
		MCDB	-5.1	0.5	8.5	17.2	21.7	24.2	25.9	24.5	21.1	14.3	5.8	-2.9
Mean Daily Temperature Range	5% DB	MDBR	10.3	11.5	12.2	12.4	12.3	11.4	11.0	10.8	11.3	11.0	10.2	9.7
		MCDBR	12.7	13.4	15.1	15.3	15.0	13.7	13.4	12.8	13.3	13.3	12.4	11.8
		MCWBR	9.5	9.2	8.7	7.3	6.3	4.5	3.7	4.0	5.0	6.4	7.3	8.5
	5% WB	MCDBR	12.7	12.8	14.1	13.5	12.9	10.9	10.1	9.8	11.0	11.8	11.9	11.8
		MCWBR	9.5	8.8	8.4	7.0	5.6	3.8	3.7	4.1	4.9	6.3	7.4	8.6
Clear-Sky Solar Irradiance	taub	0.276	0.318	0.358	0.411	0.455	0.492	0.460	0.449	0.407	0.355	0.303	0.284	
	taud	2.261	2.149	2.067	1.972	1.913	1.900	2.048	2.052	2.098	2.173	2.234	2.229	
	Ebn at Noon	863	871	875	852	824	792	814	809	814	814	814	810	
	Edh at Noon	88	118	145	173	189	192	164	158	140	114	90	84	
All-Sky Solar Radiation	RadAvg	2.33	3.38	4.95	6.11	6.81	6.56	6.46	6.02	5.01	3.84	2.60	2.01	
	RadStd	0.27	0.30	0.37	0.35	0.41	0.45	0.23	0.25	0.24	0.19	0.23	0.19	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	-0.66	N/A	N/A	N/A	N/A
	Regional (4 neighbors)	N/A	N/A	-1.46	N/A	-0.47	-0.71	N/A	N/A	N/A	N/A

Nomenclature: See separate page