

BAILING-MIAO, China

WMO: 533520

Lat: 41.7036N

Lon: 110.4352E

Elev: 4518

StdP: 12.45

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.7	-10.9	-26.2	1.5	-6.2	-22.4	1.9	-2.6	21.9	17.3	19.0	15.9	3.7	140	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	88.8	60.1	86.2	59.1	83.5	58.3	66.1	78.5	64.2	76.2	62.6	75.2	8.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	99.4	71.0	60.2	92.0	69.7	58.2	85.7	68.6	33.5	79.0	31.9	76.0	30.6	75.1	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	18.6	16.3	DB	-22.1	93.1	5.4	3.0	-26.0	95.3	-29.1	97.0	-32.1	98.7	-36.0	100.8
			WB	-22.5	68.5	5.2	2.9	-26.3	70.6	-29.3	72.3	-32.2	74.0	-36.0	76.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.1	8.0	15.5	29.9	45.4	57.1	67.1	72.1	68.3	57.8	43.3	26.6	12.6	(6)
(7)		DBStd	23.58	9.16	9.97	10.10	9.55	8.01	5.99	4.84	5.38	7.40	8.64	9.67	9.28	(7)
(8)		HDD50	5237	1302	967	624	195	27	0	0	20	239	703	1160		(8)
(9)		HDD65	8856	1767	1387	1087	589	263	46	4	29	232	674	1153	1625	(9)
(10)		CDD50	2361	0	0	2	58	248	514	686	567	255	31	0	0	(10)
(11)		CDD65	503	0	0	0	2	20	109	225	130	17	0	0	0	(11)
(12)		CDH74	5022	0	0	0	31	320	1183	2165	1133	189	1	0	0	(12)
(13)		CDH80	1501	0	0	0	2	65	346	768	291	29	0	0	0	(13)
(14)	Wind	WSAvg	7.0	5.9	6.4	7.9	8.9	8.6	7.2	6.2	5.9	6.4	6.7	6.9	6.3	(14)
(15)	Precipitation	PrecAvg	10.1	0.1	0.1	0.2	0.3	0.8	1.5	2.5	2.2	1.4	0.4	0.2	0.1	(15)
(16)		PrecMax	16.7	0.3	0.6	1.3	1.0	2.6	4.0	5.2	4.5	3.7	1.5	0.8	0.4	(16)
(17)		PrecMin	5.7	0.0	0.0	0.0	0.0	0.0	0.1	1.1	0.2	0.3	0.0	0.0	0.0	(17)
(18)		PrecStd	2.2	0.1	0.1	0.3	0.3	0.7	0.8	0.9	1.0	0.9	0.4	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	46.3	63.8	78.1	86.0	90.8	94.5	89.2	83.9	71.4	54.7	39.3	(19)
MCWB			27.4	32.4	41.6	49.4	53.1	58.1	63.2	60.8	55.7	50.2	38.9	28.6	(20)	
2%		DB	30.8	40.8	56.7	72.6	81.4	87.1	90.1	86.2	78.8	66.5	50.0	33.7	(21)	
		MCWB	23.2	29.7	38.2	46.8	52.1	56.9	61.8	60.7	54.7	47.6	35.9	25.5	(22)	
5%		DB	26.7	36.5	51.6	68.0	77.6	84.1	87.2	83.2	75.4	62.4	45.6	29.9	(23)	
		MCWB	20.4	27.2	35.6	44.8	50.4	56.1	60.7	60.0	53.5	45.3	33.9	23.2	(24)	
10%		DB	22.7	32.4	47.0	63.2	73.9	81.0	84.3	80.4	71.7	58.3	41.4	26.5	(25)	
		MCWB	17.7	24.9	33.1	42.5	49.0	55.7	60.0	58.9	52.4	43.4	31.9	20.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.8	33.8	43.5	52.1	56.9	63.1	69.1	68.6	62.1	52.9	40.6	29.6	(27)
MDCB			36.6	44.1	58.5	70.4	73.3	75.5	81.9	78.2	70.3	64.8	52.1	37.8	(28)	
2%		WB	23.5	30.4	39.1	48.6	54.4	61.0	66.6	66.2	58.4	49.5	37.0	26.2	(29)	
		MDCB	30.3	39.4	54.6	68.0	72.7	75.5	80.5	77.5	70.5	61.9	48.2	32.8	(30)	
5%		WB	20.5	27.7	36.3	46.0	52.6	59.5	64.7	64.2	56.4	46.9	34.5	23.6	(31)	
		MDCB	26.5	35.9	50.4	64.7	71.5	74.9	77.2	75.7	68.9	58.9	44.7	29.9	(32)	
10%		WB	17.7	25.0	33.7	43.4	50.7	58.2	63.3	62.4	54.7	44.7	32.1	20.9	(33)	
		MDCB	22.6	32.4	46.0	61.9	69.8	74.0	76.2	74.2	67.5	55.7	40.8	26.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.6	23.9	23.4	23.5	23.3	21.4	20.2	20.1	21.1	21.3	20.4	20.3	(35)
MCDBR			25.1	27.4	28.3	29.8	28.4	26.4	24.7	23.9	25.6	25.7	24.7	23.4	(36)	
MCWBR			19.3	19.1	16.2	14.5	12.2	8.7	6.8	7.2	9.3	12.1	14.7	17.2	(37)	
5% WB		MCDBR	25.0	26.0	26.3	25.3	22.8	20.1	18.6	18.3	19.6	21.8	22.8	22.7	(38)	
		MCWBR	19.5	18.4	15.5	13.0	10.8	7.0	6.6	7.6	8.7	11.5	14.2	16.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.280	0.324	0.371	0.422	0.458	0.496	0.465	0.457	0.422	0.361	0.308	0.286	(40)	
(41)		taud	2.247	2.139	2.023	1.949	1.909	1.887	2.034	2.039	2.053	2.163	2.226	2.230	(41)	
(42)		Ebn at Noon	273	275	274	268	261	251	257	255	254	258	258	259	(42)	
(43)		Edh at Noon	29	38	49	56	60	62	53	51	47	37	30	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	763	1104	1548	1930	2155	2042	1989	1842	1548	1241	852	668	(44)	
(45)		RadStd	72	75	116	104	109	144	94	86	82	58	75	64	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-1.17	N/A	N/A	N/A	N/A	(46)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.90	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page