

BAILING-MIAO, China

WMO: 533520

Lat: 41.7036N

Lon: 110.4352E

Elev: 1377

StdP: 85.84

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.5	-23.8	-32.3	0.2	-21.2	-30.2	0.3	-19.2	9.8	-8.2	8.5	-8.9	1.7	140	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	31.6	15.6	30.1	15.1	28.6	14.6	18.9	25.8	17.9	24.6	17.0	24.0	3.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	14.2	21.7	15.6	13.1	21.0	14.6	12.2	20.3	60.1	26.1	56.3	24.5	53.3	24.0	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.3	7.3	-30.1	34.0	3.0	1.7	-32.2	35.2	-33.9	36.1	-35.6	37.0	-37.8	38.2		
(5)			-30.3	20.3	2.9	1.6	-32.4	21.5	-34.1	22.4	-35.7	23.3	-37.8	24.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-13.3	-9.2	-1.1	7.5	14.0	19.5	22.3	20.2	14.4	6.3	-3.0	-10.8	(6)
(7)		DBStd	13.10	5.09	5.54	5.61	5.31	4.45	3.33	2.69	2.99	4.11	4.80	5.37	5.16	(7)
(8)		HDD10.0	2909	723	537	347	108	15	0	0	0	11	133	391	644	(8)
(9)		HDD18.3	4920	982	771	604	327	146	26	2	16	129	374	641	903	(9)
(10)		CDD10.0	1312	0	0	1	32	138	286	381	315	142	17	0	0	(10)
(11)		CDD18.3	279	0	0	0	1	11	61	125	72	9	0	0	0	(11)
(12)		CDH23.3	2790	0	0	0	17	178	657	1203	629	105	1	0	0	(12)
(13)		CDH26.7	834	0	0	0	1	36	192	427	162	16	0	0	0	(13)
(14)	Wind	WSAvg	3.1	2.6	2.9	3.5	4.0	3.8	3.2	2.8	2.7	2.9	3.0	3.1	2.8	(14)
(15)	Precipitation	PrecAvg	256	2	3	6	7	21	39	64	57	36	11	5	2	(15)
(16)		PrecMax	425	8	14	34	25	66	101	133	115	93	37	21	9	(16)
(17)		PrecMin	146	0	0	0	0	0	3	29	6	7	0	0	0	(17)
(18)		PrecStd	55	2	3	7	7	18	21	23	26	24	9	5	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.0	7.9	17.6	25.6	30.0	32.6	34.7	31.8	28.8	21.9	12.6	4.1	(19)
(20)			MCWB	-2.5	0.2	5.4	9.7	11.7	14.5	17.3	16.0	13.2	10.1	3.8	-1.9	(20)
(21)		2%	DB	-0.7	4.9	13.7	22.5	27.4	30.6	32.3	30.1	26.0	19.2	10.0	0.9	(21)
(22)			MCWB	-4.9	-1.3	3.5	8.2	11.2	13.8	16.6	15.9	12.6	8.7	2.2	-3.6	(22)
(23)		5%	DB	-2.9	2.5	10.9	20.0	25.3	28.9	30.7	28.5	24.1	16.9	7.5	-1.1	(23)
(24)			MCWB	-6.4	-2.7	2.0	7.1	10.2	13.4	15.9	15.6	11.9	7.4	1.1	-4.9	(24)
(25)		10%	DB	-5.1	0.2	8.4	17.3	23.3	27.2	29.1	26.9	22.1	14.6	5.2	-3.0	(25)
(26)			MCWB	-8.0	-3.9	0.6	5.8	9.4	13.1	15.6	15.0	11.3	6.3	0.0	-6.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.3	1.0	6.4	11.1	13.8	17.3	20.6	20.3	16.7	11.6	4.8	-1.3	(27)
(28)			MCD B	2.6	6.7	14.7	21.3	22.9	24.2	27.7	25.7	21.3	18.2	11.2	3.2	(28)
(29)		2%	WB	-4.7	-0.9	3.9	9.2	12.5	16.1	19.2	19.0	14.7	9.7	2.8	-3.2	(29)
(30)			MCD B	-1.0	4.1	12.6	20.0	22.6	24.2	27.0	25.3	21.4	16.6	9.0	0.5	(30)
(31)		5%	WB	-6.4	-2.4	2.4	7.8	11.4	15.3	18.2	17.9	13.6	8.3	1.4	-4.7	(31)
(32)			MCD B	-3.1	2.1	10.2	18.1	22.0	23.9	25.1	24.3	20.5	14.9	7.0	-1.2	(32)
(33)		10%	WB	-7.9	-3.9	0.9	6.4	10.4	14.6	17.4	16.9	12.6	7.0	0.1	-6.2	(33)
(34)			MCD B	-5.2	0.2	7.8	16.6	21.0	23.3	24.6	23.5	19.7	13.2	4.9	-3.1	(34)
(35)	Mean Daily Temperature Range	MDBR	12.6	13.3	13.0	13.1	12.9	11.9	11.2	11.1	11.7	11.8	11.3	11.3	(35)	
(36)		5% DB	MCD BR	13.9	15.2	15.7	16.6	15.8	14.7	13.7	13.3	14.2	14.3	13.7	13.0	(36)
(37)			MCWBR	10.7	10.6	9.0	8.0	6.8	4.8	3.8	4.0	5.2	6.7	8.2	9.5	(37)
(38)			5% WB	MCD BR	13.9	14.4	14.6	14.0	12.7	11.2	10.3	10.2	10.9	12.1	12.6	12.6
(39)		MCWBR		10.8	10.2	8.6	7.2	6.0	3.9	3.7	4.2	4.9	6.4	7.9	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.280	0.324	0.371	0.422	0.458	0.496	0.465	0.457	0.422	0.361	0.308	0.286	(40)	
(41)		taud	2.247	2.139	2.023	1.949	1.909	1.887	2.034	2.039	2.053	2.163	2.226	2.230	(41)	
(42)		Ebn at Noon	862	867	863	845	822	790	811	804	802	812	814	816	(42)	
(43)		Edh at Noon	91	120	153	178	190	195	167	161	147	116	93	85	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.41	3.48	4.88	6.08	6.79	6.44	6.27	5.81	4.88	3.91	2.69	2.11	(44)	
(45)		RadStd	0.23	0.24	0.36	0.33	0.34	0.45	0.29	0.27	0.26	0.18	0.24	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-0.65	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.50	N/A	N/A	N/A	N/A

Nomenclature: See separate page