

LINHE, China

WMO: 535130

Lat: 40.7218N

Lon: 107.3706E

Elev: 3419

StdP: 12.97

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.0	1.0	-19.6	2.1	10.1	-15.8	2.6	10.7	16.7	24.0	14.9	22.6	2.7	220	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	92.3	64.8	89.9	64.0	87.5	63.0	70.4	84.0	68.7	82.0	67.1	80.4	5.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	110.8	77.6	64.3	102.7	75.6	62.5	96.1	74.3	36.8	83.9	35.2	82.1	33.7	80.3	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.1	13.6	11.5	DB	-7.2	97.2	5.0	2.5	-10.8	99.0	-13.7	100.5	-16.6	101.9	-20.2	103.8
(5)				WB	-8.0	73.1	4.8	2.2	-11.5	74.7	-14.3	76.0	-17.0	77.3	-20.4	78.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	15.8	24.3	38.0	52.8	63.8	73.0	76.7	72.9	63.1	49.4	33.4	20.0
	DBStd	22.18	7.41	8.75	8.95	8.53	7.06	5.38	4.48	5.12	6.44	7.58	7.88	7.60
	HDD50	3767	1060	721	382	68	3	0	0	0	2	103	498	930
	HDD65	6929	1525	1141	838	373	107	6	0	5	107	484	948	1395
	CDD50	3302	0	0	9	152	432	689	828	711	396	85	0	0
	CDD65	990	0	0	0	7	71	245	363	252	51	1	0	0
	CDH74	9608	0	0	0	131	830	2452	3581	2152	445	17	0	0
	CDH80	3531	0	0	0	26	235	941	1510	727	91	1	0	0
Wind	WSAvg	4.5	4.0	4.4	5.4	5.7	5.4	4.7	4.4	4.1	3.9	3.9	4.3	4.3
Precipitation	PrecAvg	5.7	0.0	0.0	0.1	0.2	0.6	0.9	1.2	1.4	0.9	0.2	0.1	0.0
	PrecMax	9.3	0.2	0.4	0.9	1.5	2.5	3.8	3.1	4.7	2.9	0.9	0.7	0.4
	PrecMin	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.1	0.0	0.0	0.0
	PrecStd	1.7	0.0	0.1	0.2	0.3	0.6	0.9	0.7	1.1	0.8	0.3	0.2	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.8	50.9	68.3	83.9	89.8	94.4	96.3	92.8	87.8	76.1	58.6	41.8
		MCWB	29.3	35.9	46.6	54.1	57.7	62.2	69.5	66.5	61.7	53.3	42.4	31.1
	2%	DB	34.8	45.7	62.1	77.7	86.0	91.3	92.9	89.6	82.3	70.7	53.6	37.2
		MCWB	26.3	33.2	42.5	50.7	56.5	61.7	66.6	65.6	59.6	51.1	40.2	28.3
	5%	DB	31.4	42.1	57.5	73.0	82.3	88.6	90.6	86.9	78.9	66.8	49.6	34.0
		MCWB	23.9	31.1	40.1	48.8	54.9	60.8	65.9	64.8	58.0	49.3	38.0	26.3
	10%	DB	28.2	38.3	53.0	68.6	78.7	85.7	88.0	84.2	75.8	62.9	45.7	31.3
		MCWB	21.8	28.8	37.7	46.9	53.4	60.3	65.3	63.9	57.3	47.5	36.0	24.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.6	37.8	47.5	56.7	61.0	68.6	74.1	72.7	66.5	57.0	44.9	31.9
		MCDB	39.1	46.8	64.6	73.4	78.8	81.8	90.9	85.1	76.0	68.3	54.3	40.6
	2%	WB	26.5	33.8	43.5	53.1	58.9	66.0	71.0	70.4	63.3	53.7	41.1	29.0
		MCDB	34.3	44.4	59.9	72.0	78.8	81.5	86.3	82.2	75.2	66.0	51.5	36.2
	5%	WB	24.1	31.6	41.0	50.5	57.1	64.4	69.3	68.6	61.4	51.3	38.8	26.8
		MCDB	31.0	40.9	55.4	69.2	76.9	80.0	83.6	80.7	73.5	63.2	48.5	33.5
	10%	WB	21.9	29.3	38.7	48.3	55.3	62.9	67.8	66.8	59.5	48.9	36.6	24.8
		MCDB	28.1	38.1	51.8	66.7	73.9	78.6	81.7	79.2	71.6	60.5	45.2	31.1
Mean Daily Temperature Range	5% DB	MDBR	18.3	21.1	21.4	22.5	22.6	20.8	19.4	19.2	20.7	20.7	16.6	16.2
		MCDBR	20.9	24.1	27.2	29.3	27.8	25.3	23.5	22.7	24.7	25.8	20.6	18.0
		MCWBR	14.8	15.0	14.2	12.6	10.6	8.3	7.8	7.9	9.1	11.4	11.3	12.2
	5% WB	MCDBR	20.3	22.8	24.3	24.2	23.5	20.3	19.5	18.0	19.9	22.1	19.6	16.9
		MCWBR	14.5	14.4	13.2	11.3	10.0	7.5	8.0	8.1	8.6	11.3	11.5	11.7
Clear-Sky Solar Irradiance	taub	0.314	0.360	0.408	0.459	0.490	0.514	0.489	0.482	0.451	0.398	0.349	0.318	
	taud	2.179	2.069	1.950	1.869	1.859	1.868	2.004	1.998	2.003	2.067	2.121	2.144	
	Ebn at Noon	260	263	263	258	253	246	252	249	247	246	242	246	
	Edh at Noon	32	42	53	62	64	63	55	54	50	42	34	30	
All-Sky Solar Radiation	RadAvg	814	1155	1582	1948	2194	2149	2019	1856	1564	1290	914	735	
	RadStd	84	66	98	105	99	140	115	90	86	49	68	65	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	-2.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page