

YUANPING, China

WMO: 536730

Lat: 38.7383N

Lon: 112.7143E

Elev: 2749

StdP: 13.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.1	8.6	-18.8	2.2	18.4	-15.4	2.6	19.0	19.8	21.5	17.7	22.6	2.8	0	0.422

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	90.5	64.9	88.0	65.4	85.8	65.1	73.3	82.8	71.7	81.0	70.3	79.5	5.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.5	124.4	78.5	68.9	117.6	76.9	67.3	111.3	75.8	39.0	82.7	37.5	80.9	36.2	79.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.8	15.1	12.6	-1.0	95.2	4.7	3.2	-4.4	97.5	-7.1	99.4	-9.8	101.1	-13.2	103.5		
			-2.4	75.5	4.2	1.7	-5.4	76.8	-7.9	77.8	-10.3	78.8	-13.4	80.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	21.9	29.6	42.0	55.2	65.9	72.6	75.7	72.8	63.9	51.8	36.9	24.5	(6)
(7)		DBStd	19.83	5.91	6.93	7.89	7.97	6.07	4.89	4.30	4.54	5.36	6.15	7.20	6.29	(7)
(8)		HDD50	2988	871	571	267	39	1	0	0	0	53	395	791		(8)
(9)		HDD65	6006	1336	991	712	303	63	6	1	4	81	409	844	1256	(9)
(10)		CDD50	3417	0	0	20	197	493	677	797	706	417	109	1	0	(10)
(11)		CDD65	959	0	0	0	10	90	233	333	245	48	0	0	0	(11)
(12)		CDH74	8218	0	0	3	185	997	2116	2826	1727	354	10	0	0	(12)
(13)		CDH80	2635	0	0	0	43	285	763	1018	465	61	0	0	0	(13)
(14)	Wind	WSAvg	4.4	4.1	4.5	5.3	5.6	5.7	4.5	3.8	3.7	3.6	3.9	3.7	4.0	(14)
(15)	Precipitation	PrecAvg	16.7	0.1	0.2	0.3	0.7	1.1	2.0	4.1	4.5	2.3	0.9	0.3	0.1	(15)
(16)		PrecMax	30.0	0.4	0.9	1.7	3.1	2.9	6.3	9.3	15.4	7.0	2.7	1.8	0.3	(16)
(17)		PrecMin	6.4	0.0	0.0	0.0	0.0	0.0	0.1	0.7	0.9	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	5.4	0.1	0.2	0.3	0.7	0.8	1.4	2.0	3.0	1.7	0.7	0.4	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.4	54.1	71.9	85.5	90.5	94.4	94.4	90.0	85.8	75.5	61.6	45.0	(19)
(20)		0.4%	MCWB	31.9	38.5	48.1	55.1	58.4	63.5	67.3	68.6	63.8	55.7	44.5	32.9	(20)
(21)		2%	DB	39.4	49.4	65.4	79.0	86.4	90.3	90.6	87.2	81.2	71.3	57.2	41.3	(21)
(22)		2%	MCWB	28.5	35.3	44.7	52.8	57.4	61.9	68.2	68.9	61.9	53.5	42.2	30.6	(22)
(23)		5%	DB	36.0	45.7	60.5	74.6	83.1	87.3	88.0	84.8	77.9	67.5	53.0	38.3	(23)
(24)		5%	MCWB	26.6	33.4	42.2	50.9	56.3	61.9	68.8	68.0	60.9	51.8	39.9	28.9	(24)
(25)		10%	DB	33.1	42.1	55.9	70.4	79.7	84.6	85.6	82.5	74.8	63.7	49.0	35.3	(25)
(26)		10%	MCWB	25.1	31.3	39.8	49.1	55.3	61.8	68.5	67.7	60.1	50.2	38.5	27.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.3	39.8	49.5	59.5	64.2	69.7	75.5	75.5	69.3	59.6	46.9	34.1	(27)
(28)		0.4%	MCDWB	43.5	51.8	67.8	72.7	78.1	82.9	85.7	82.7	78.9	70.2	54.6	42.6	(28)
(29)		2%	WB	29.2	36.5	45.9	56.2	61.7	67.9	73.8	72.9	66.5	56.6	44.3	31.3	(29)
(30)		2%	MCDWB	38.3	46.7	61.6	72.4	76.4	80.1	83.6	82.0	74.3	65.7	52.9	40.0	(30)
(31)		5%	WB	27.2	34.1	43.4	53.5	59.9	66.4	72.5	71.4	63.9	54.6	41.7	29.4	(31)
(32)		5%	MCDWB	35.6	43.9	58.6	69.8	75.2	78.1	82.1	80.2	72.1	62.9	51.3	37.3	(32)
(33)		10%	WB	25.2	32.0	41.1	51.2	58.1	65.0	71.1	70.0	62.1	52.4	39.4	27.5	(33)
(34)		10%	MCDWB	32.8	41.5	54.1	66.5	73.9	77.3	80.6	78.4	71.0	61.0	48.0	34.9	(34)
(35)	Mean Daily Temperature Range		MDBR	18.8	19.5	20.8	21.9	22.3	20.1	16.9	16.5	18.4	19.2	18.0	17.3	(35)
(36)		5% DB	MCDBR	22.6	24.7	27.6	29.4	28.4	25.9	21.8	20.2	23.7	25.0	24.4	21.3	(36)
(37)			MCWBR	15.4	15.0	14.2	12.5	10.5	8.6	7.3	7.4	9.4	11.4	13.5	13.8	(37)
(38)			MCDBR	21.9	22.7	25.8	24.9	22.4	19.1	16.7	16.0	17.7	19.4	20.9	19.8	(38)
(39)		5% WB	MCWBR	15.0	14.0	13.8	11.4	9.5	7.5	7.0	6.8	8.4	10.1	12.4	13.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.349	0.425	0.449	0.495	0.531	0.633	0.619	0.608	0.541	0.475	0.374	0.342	(40)	
(41)		taud	2.148	1.966	1.939	1.887	1.845	1.685	1.764	1.766	1.858	1.946	2.143	2.207	(41)	
(42)		Ebn at Noon	252	244	253	250	244	219	221	218	224	224	240	246	(42)	
(43)		Edh at Noon	35	48	55	61	65	76	70	69	59	49	35	31	(43)	
(44)	All-Sky Solar Radiation	RadAvg	891	1111	1535	1808	1995	1802	1666	1552	1341	1151	912	789	(44)	
(45)		RadStd	68	85	123	119	143	143	98	123	105	96	113	66	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-2.93	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page