

LISHI, China

WMO: 537640

Lat: 37.5067N

Lon: 111.1132E

Elev: 951

StdP: 90.41

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.1	-14.1	-25.8	0.4	-10.2	-23.7	0.5	-8.9	6.8	-3.1	6.0	-3.6	2.1	20	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	33.4	19.3	32.0	18.7	30.7	18.6	23.2	28.6	22.3	27.6	21.4	26.6	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.7	18.4	26.1	20.7	17.3	25.2	19.7	16.2	24.5	75.0	28.6	70.9	27.7	67.3	26.5	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	6.9	5.9	5.1	DB	-19.1	35.8	2.7	1.6	-21.0	37.0	-22.6	37.9	-24.1	38.8	-26.1	40.0
(5)				WB	-19.8	24.7	2.5	1.7	-21.6	26.0	-23.1	27.0	-24.5	28.0	-26.4	29.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-5.6	-1.1	5.9	12.9	18.4	22.7	24.6	22.8	17.7	11.0	3.4	-3.8	(6)
(7)		DBStd	10.99	3.93	4.44	4.39	4.44	3.33	2.61	2.38	2.64	3.31	3.53	3.96	3.81	(7)
(8)		HDD10.0	1616	484	311	139	22	1	0	0	1	31	199	429		(8)
(9)		HDD18.3	3300	742	544	386	171	41	2	0	2	50	226	449	687	(9)
(10)		CDD10.0	1904	0	0	12	108	259	382	453	396	231	63	1	0	(10)
(11)		CDD18.3	547	0	0	0	7	42	134	194	139	30	1	0	0	(11)
(12)		CDH23.3	5147	0	0	4	123	544	1382	1769	1069	244	9	0	0	(12)
(13)		CDH26.7	1871	0	0	1	29	150	553	732	346	59	1	0	0	(13)
(14)	Wind	WSAvg	2.2	2.1	2.2	2.4	2.6	2.5	2.3	2.0	1.9	1.9	2.0	2.0	2.0	(14)
(15)	Precipitation	PrecAvg	500	3	5	11	24	38	58	118	114	80	34	15	3	(15)
(16)		PrecMax	746	9	24	33	59	159	136	277	267	207	123	51	15	(16)
(17)		PrecMin	250	0	0	0	3	2	8	28	28	16	5	0	0	(17)
(18)		PrecStd	130	3	6	8	16	34	35	67	62	50	27	14	4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.4	14.6	23.2	30.2	32.3	35.2	35.7	33.2	31.7	24.6	17.3	8.7	(19)
(20)			MCWB	1.7	5.1	9.8	13.5	16.0	17.8	20.7	21.1	18.3	14.3	8.6	1.9	(20)
(21)		2%	DB	5.5	10.7	19.3	26.6	30.0	32.9	33.8	31.6	28.2	21.8	14.6	6.1	(21)
(22)			MCWB	-0.2	3.3	8.2	12.4	14.9	17.2	20.3	20.4	17.3	12.5	7.2	0.8	(22)
(23)		5%	DB	3.2	8.5	16.6	24.1	28.4	31.4	32.3	30.2	26.1	19.7	12.4	4.2	(23)
(24)			MCWB	-1.6	2.0	6.8	11.1	14.1	16.9	20.1	20.1	16.8	11.8	6.1	-0.6	(24)
(25)		10%	DB	1.1	6.5	14.1	21.7	26.6	30.0	30.8	28.7	24.1	17.7	10.3	2.3	(25)
(26)			MCWB	-2.9	0.9	5.5	10.1	13.4	16.7	20.1	19.8	16.0	10.8	5.3	-1.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	5.9	11.1	16.2	18.2	21.6	24.7	24.3	21.4	15.5	9.9	3.0	(27)
(28)			MCDWB	7.3	12.1	21.0	24.4	27.8	29.4	31.0	29.0	26.6	20.7	14.2	7.1	(28)
(29)		2%	WB	0.0	4.1	9.0	14.0	16.6	20.2	23.7	23.0	19.5	14.2	8.5	1.1	(29)
(30)			MCDWB	4.7	9.4	17.3	23.2	25.2	27.7	29.6	27.7	24.9	19.1	12.4	4.8	(30)
(31)		5%	WB	-1.3	2.6	7.5	12.4	15.8	19.3	22.7	22.1	18.2	13.1	7.2	0.0	(31)
(32)			MCDWB	2.7	7.5	15.3	21.1	24.8	26.4	28.3	27.1	23.3	17.6	11.4	3.2	(32)
(33)		10%	WB	-2.7	1.3	6.0	11.2	14.8	18.4	21.8	21.3	17.1	12.0	5.6	-1.1	(33)
(34)			MCDWB	0.8	5.9	13.1	19.2	23.4	25.8	27.3	26.1	22.2	16.4	9.9	2.2	(34)
(35)	Mean Daily Temperature Range	MDBR	11.0	11.4	12.1	12.8	12.9	12.2	10.3	9.8	10.2	10.9	10.6	10.1	(35)	
(36)		5% DB	MCDBR	14.4	14.6	16.6	16.8	16.7	15.5	13.5	12.4	13.8	14.5	14.4	12.7	(36)
(37)			MCWBR	9.9	8.8	8.6	7.2	6.6	5.2	4.3	4.2	5.2	6.7	8.1	8.4	(37)
(38)			MCDBR	13.4	12.9	15.3	13.7	13.0	11.5	10.1	9.5	10.8	11.3	12.3	11.2	(38)
(39)		5% WB	MCWBR	9.4	8.0	8.4	6.5	5.7	4.7	4.2	4.0	5.0	5.8	7.5	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.395	0.486	0.510	0.540	0.567	0.643	0.629	0.636	0.573	0.530	0.421	0.378	(40)	
(41)		taud	1.985	1.795	1.784	1.758	1.765	1.659	1.743	1.709	1.790	1.816	1.977	2.048	(41)	
(42)		Ebn at Noon	742	711	745	753	741	685	691	671	684	661	706	731	(42)	
(43)		Edh at Noon	133	183	203	221	223	248	226	229	200	177	133	117	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.78	3.44	4.74	5.65	6.19	5.91	5.40	4.90	4.09	3.55	2.91	2.52	(44)	
(45)		RadStd	0.27	0.37	0.40	0.46	0.45	0.45	0.44	0.35	0.37	0.40	0.39	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page