

TAIYUAN, China

WMO: 537720

Lat: 37.6206N

Lon: 112.5764E

Elev: 785

StdP: 92.24

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.3	-12.2	-27.0	0.3	-5.8	-24.8	0.4	-4.8	9.7	-1.6	8.4	-1.8	1.3	110	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	33.9	19.7	32.2	19.6	31.0	19.4	24.2	29.3	23.2	28.2	22.3	27.3	2.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.8	19.3	27.0	21.8	18.2	26.0	20.9	17.1	25.3	77.6	29.4	73.6	28.1	70.1	27.1	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.6	6.3	-18.2	36.4	2.0	1.6	-19.6	37.5	-20.8	38.5	-21.9	39.4	-23.4	40.6		
			-18.9	25.7	1.9	1.2	-20.3	26.6	-21.4	27.3	-22.4	28.0	-23.8	28.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	-4.2	-0.2	6.2	13.2	19.0	22.9	24.9	23.2	18.2	11.6	3.9	-2.5	(6)
(7)		DBStd	10.65	3.33	3.86	4.24	4.30	3.22	2.71	2.40	2.75	3.10	3.39	3.86	3.40	(7)
(8)		HDD10.0	1473	440	286	132	18	0	0	0	0	23	186	389		(8)
(9)		HDD18.3	3120	698	519	376	161	31	3	0	39	209	434	647		(9)
(10)		CDD10.0	1987	0	0	14	113	280	388	462	410	246	73	2	0	(10)
(11)		CDD18.3	591	0	0	0	7	52	140	203	154	34	1	0	0	(11)
(12)		CDH23.3	5677	0	0	7	146	690	1417	1851	1242	304	20	0	0	(12)
(13)		CDH26.7	2125	0	0	0	36	222	592	772	431	71	1	0	0	(13)
(14)	Wind	WSAvg	2.3	2.0	2.4	2.8	3.0	2.9	2.4	2.1	2.0	1.8	1.8	2.0	2.0	(14)
(15)	Precipitation	PrecAvg	446	3	6	12	23	32	55	110	100	62	25	14	3	(15)
(16)		PrecMax	625	14	17	53	60	77	113	241	212	120	70	52	23	(16)
(17)		PrecMin	258	0	0	0	1	5	8	35	10	8	4	0	0	(17)
(18)		PrecStd	86	4	5	15	16	17	26	51	53	32	19	16	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	15.0	23.9	30.5	33.2	35.9	35.9	33.9	31.5	25.8	18.2	9.6	(19)
(20)			MCWB	1.6	5.2	10.2	14.6	15.7	18.6	21.0	21.6	18.9	14.4	8.5	2.3	(20)
(21)		2%	DB	6.6	11.8	20.1	27.0	31.0	33.5	34.0	32.0	28.8	23.0	15.9	7.3	(21)
(22)			MCWB	0.0	3.8	8.3	12.3	14.8	17.7	21.2	21.5	17.7	12.9	7.2	0.9	(22)
(23)		5%	DB	4.4	9.5	17.2	24.7	29.1	31.9	32.2	30.8	26.8	20.9	13.6	5.6	(23)
(24)			MCWB	-1.2	2.3	7.0	11.8	14.4	17.6	21.3	21.3	17.1	12.1	6.2	-0.1	(24)
(25)		10%	DB	2.8	7.2	14.9	22.1	27.2	30.1	31.0	29.1	24.9	18.8	11.1	3.8	(25)
(26)			MCWB	-2.1	0.9	5.9	10.7	13.8	17.4	21.3	20.8	16.6	11.2	5.1	-1.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.9	6.2	11.5	16.8	18.7	22.5	25.7	25.1	22.2	16.4	10.1	3.1	(27)
(28)			MCDWB	8.2	12.5	20.5	24.7	26.6	28.9	30.6	29.7	27.4	22.4	15.7	7.6	(28)
(29)		2%	WB	0.3	4.3	9.3	14.8	17.6	21.1	24.5	23.9	20.4	14.9	8.6	1.5	(29)
(30)			MCDWB	5.8	10.3	17.9	23.3	25.4	27.8	29.8	29.0	24.7	19.7	13.3	6.0	(30)
(31)		5%	WB	-0.9	2.9	7.8	13.2	16.5	20.1	23.6	23.0	18.8	13.8	7.2	0.4	(31)
(32)			MCDWB	3.9	8.4	16.0	21.3	24.5	26.9	28.8	27.9	23.3	18.2	11.7	4.6	(32)
(33)		10%	WB	-2.1	1.4	6.4	11.9	15.5	19.2	22.7	22.2	17.6	12.6	5.8	-0.8	(33)
(34)			MCDWB	2.2	6.7	13.8	19.5	23.8	26.1	27.8	26.8	22.6	16.9	10.5	3.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.8	13.1	13.8	14.4	14.3	13.3	11.1	10.9	12.1	13.1	12.5	11.8	(35)
(36)			MCDBR	15.3	16.4	18.3	18.4	18.0	16.5	13.9	13.0	15.3	16.5	16.2	14.2	(36)
(37)			MCWBR	10.1	10.0	9.8	7.9	6.8	5.7	5.1	5.2	6.2	7.8	9.1	9.0	(37)
(38)		5% WB	MCDWB	14.4	14.7	16.4	15.4	14.1	12.8	11.2	10.8	11.9	12.9	13.8	12.8	(38)
(39)	MCWBR		9.7	9.1	9.2	7.5	6.4	5.5	5.3	5.3	6.0	6.9	8.2	8.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.405	0.491	0.512	0.551	0.589	0.689	0.679	0.661	0.599	0.545	0.431	0.388	(40)
(41)		taud		1.997	1.812	1.799	1.757	1.729	1.586	1.652	1.667	1.743	1.799	1.981	2.064	(41)
(42)		Ebn at Noon		732	706	743	744	724	653	656	653	662	647	695	720	(42)
(43)		Edh at Noon		131	180	200	221	231	267	248	239	210	180	132	115	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.75	3.37	4.66	5.58	6.11	5.61	5.12	4.80	4.06	3.52	2.86	2.50	(44)
(45)		RadStd		0.25	0.36	0.42	0.40	0.43	0.44	0.36	0.38	0.34	0.37	0.38	0.22	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	-0.65	-1.01	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page