

YUSHE, China

WMO: 537870

Lat: 37.0687N

Lon: 112.9826E

Elev: 1042

StdP: 89.42

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.4	-14.4	-28.6	0.3	-8.0	-26.1	0.4	-6.5	7.1	-3.4	6.1	-1.8	1.3	70	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	31.4	18.1	30.1	18.2	28.9	18.1	22.6	27.1	21.8	26.0	21.0	25.2	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	18.2	25.0	20.5	17.3	24.2	19.7	16.4	23.5	72.9	27.3	69.4	26.1	66.2	25.1	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	6.0	5.0	-19.8	34.2	2.1	1.4	-21.3	35.3	-22.6	36.1	-23.7	36.9	-25.2	38.0		
			-20.5	23.8	2.0	0.8	-21.9	24.4	-23.1	24.8	-24.2	25.2	-25.7	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	-5.4	-1.7	4.7	11.4	16.7	20.7	23.0	21.4	16.5	10.2	2.8	-3.9
	DBStd	10.36	3.43	3.90	4.11	4.17	2.99	2.45	2.20	2.64	3.08	3.18	3.88	3.54
	HDD10.0	1696	478	328	170	33	1	0	0	0	1	37	217	431
	HDD18.3	3489	737	561	423	211	67	7	1	6	70	252	466	689
	CDD10.0	1606	0	0	6	74	208	322	403	354	196	43	1	0
	CDD18.3	356	0	0	0	2	16	79	144	101	14	0	0	0
	CDH23.3	3191	0	0	2	67	316	841	1119	700	143	3	0	0
	CDH26.7	916	0	0	0	14	65	266	368	177	26	0	0	0
Wind	WSAvg	2.0	1.6	1.8	2.3	2.5	2.5	2.2	1.9	1.8	1.7	1.8	1.7	1.7
Precipitation	PrecAvg	587	4	7	14	26	39	70	152	135	78	36	15	5
	PrecMax	876	15	25	47	99	129	222	269	245	208	93	45	23
	PrecMin	318	0	0	0	2	2	19	25	23	13	1	0	0
	PrecStd	135	5	7	10	22	31	50	65	66	49	28	13	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.8	13.5	22.1	28.9	30.7	33.1	34.0	31.6	29.8	23.5	17.6	9.4
		MCWB	0.9	4.3	9.0	13.2	14.2	17.0	19.1	20.1	17.2	12.6	8.1	1.9
	2%	DB	5.9	10.2	18.2	25.1	28.5	31.1	31.7	30.0	26.8	21.4	14.9	6.8
		MCWB	-0.8	2.5	6.9	11.4	13.7	16.3	19.4	20.0	16.5	11.4	6.2	0.2
	5%	DB	3.7	8.1	15.6	22.6	26.8	29.6	30.1	28.7	24.8	19.4	12.5	4.7
		MCWB	-1.9	1.2	5.8	10.3	13.1	16.2	19.8	19.7	15.8	10.6	5.2	-0.9
	10%	DB	1.7	5.9	13.1	20.3	25.0	28.1	28.7	27.3	22.9	17.2	10.1	2.9
		MCWB	-2.8	0.0	4.7	9.4	12.6	16.1	19.9	19.4	15.2	9.6	4.2	-1.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.6	5.3	10.4	15.9	17.1	20.9	23.9	23.5	21.1	14.8	9.4	3.0
		MCDB	5.8	10.9	18.0	21.8	23.7	26.4	28.6	28.5	24.7	19.8	14.6	7.7
	2%	WB	0.0	3.3	8.0	13.6	16.1	19.7	23.0	22.5	18.9	13.4	7.7	0.9
		MCDB	4.9	8.5	16.1	21.1	23.0	25.4	27.4	27.0	23.4	18.1	11.9	5.7
	5%	WB	-1.5	1.9	6.5	12.0	15.2	18.7	22.1	21.6	17.7	12.3	6.3	-0.5
		MCDB	3.5	6.9	14.3	20.0	22.5	24.9	26.4	25.8	21.8	16.4	10.7	3.8
	10%	WB	-2.8	0.5	5.1	10.6	14.3	17.9	21.4	20.8	16.5	11.2	4.9	-1.5
		MCDB	1.4	5.4	12.3	18.1	21.5	24.1	25.6	24.8	20.4	15.2	9.6	2.2
Mean Daily Temperature Range	5% DB	MDBR	13.0	12.5	13.2	13.8	14.2	13.1	10.4	10.1	11.1	12.0	12.2	12.0
		MCDBR	16.0	16.0	18.0	18.3	18.1	16.6	13.5	12.5	14.5	16.0	16.1	14.8
		MCWBR	10.7	9.7	9.4	7.8	6.8	5.3	4.2	4.4	5.6	7.4	9.0	9.5
	5% WB	MCDBR	14.9	14.3	16.0	14.8	13.2	11.9	9.4	9.3	10.2	11.1	13.1	13.2
		MCWBR	10.0	8.8	8.7	6.7	5.8	4.6	4.0	4.1	4.7	5.7	7.8	8.6
Clear-Sky Solar Irradiance	taub	0.402	0.486	0.510	0.545	0.577	0.684	0.672	0.651	0.589	0.538	0.427	0.382	
	taud	1.973	1.796	1.788	1.755	1.736	1.573	1.645	1.664	1.743	1.789	1.964	2.046	
	Ebn at Noon	738	714	748	751	735	657	661	662	673	657	703	731	
	Edh at Noon	136	184	203	222	230	271	250	240	211	183	136	118	
All-Sky Solar Radiation	RadAvg	2.70	3.29	4.52	5.38	5.89	5.38	4.86	4.58	3.90	3.40	2.78	2.46	
	RadStd	0.27	0.40	0.44	0.42	0.45	0.43	0.33	0.40	0.34	0.40	0.41	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page