

JIEXIU, China

WMO: 538630

Lat: 37.0628N

Lon: 111.9450E

Elev: 745

StdP: 92.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-10.6	-26.0	0.4	-4.6	-23.6	0.5	-4.0	9.3	-1.3	8.2	-0.1	1.3	250	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	33.8	19.8	32.4	19.9	31.1	19.9	24.3	29.1	23.5	28.3	22.6	27.4	3.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	19.6	26.7	22.1	18.4	26.0	21.2	17.4	25.5	78.4	29.4	74.7	28.2	71.2	27.7	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	6.1	DB	-16.3	36.6	2.6	1.4	-18.2	37.6	-19.8	38.4	-21.2	39.2	-23.2	40.2	(4)
(5)			WB	-17.0	25.6	2.4	1.0	-18.8	26.4	-20.2	27.0	-21.6	27.6	-23.4	28.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	-3.1	0.7	7.4	13.9	19.1	23.1	25.1	23.2	18.2	12.1	4.9	-1.3	(6)	
	DBStd	10.25	3.58	3.83	4.33	4.28	3.21	2.75	2.45	2.71	3.08	3.26	3.88	3.52	(7)	
	HDD10.0	1308	407	261	103	13	0	0	0	0	0	17	158	349	(8)	
	HDD18.3	2919	666	494	339	143	29	2	0	2	38	193	404	608	(9)	
	CDD10.0	2037	0	0	23	129	282	393	467	408	247	83	4	0	(10)	
	CDD18.3	604	0	0	1	9	53	145	208	152	35	1	0	0	(11)	
	CDH23.3	5814	0	0	9	152	658	1543	1932	1208	294	18	0	0	(12)	
	CDH26.7	2173	0	0	1	34	198	656	808	406	70	1	0	0	(13)	
(14) Wind	WSAvg	2.4	2.4	2.5	2.9	2.9	2.8	2.4	2.1	1.9	1.8	2.0	2.3	2.4	(14)	
(15) Precipitation	PrecAvg	498	3	6	14	26	38	54	131	97	76	34	14	4	(15)	
	PrecMax	733	14	26	47	89	146	133	318	194	237	102	45	16	(16)	
	PrecMin	276	0	0	0	1	1	10	32	24	11	1	0	0	(17)	
	PrecStd	121	4	6	10	20	33	35	73	44	56	25	12	5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	15.1	24.6	30.2	32.8	35.5	36.2	33.4	31.7	25.4	18.6	10.8	(19)	
		MCWB	2.6	5.6	10.8	15.1	15.9	18.5	21.7	22.1	19.2	14.1	8.3	3.1	(20)	
	2%	DB	7.1	12.2	20.7	27.1	30.5	33.7	34.1	31.7	28.5	23.0	16.1	8.2	(21)	
		MCWB	0.4	3.9	8.7	13.4	15.5	18.0	21.2	22.2	18.2	13.3	7.5	1.6	(22)	
	5%	DB	5.0	10.2	18.1	24.8	28.9	32.1	32.5	30.5	26.5	21.0	13.9	6.2	(23)	
		MCWB	-0.7	3.1	7.5	12.1	15.1	17.8	21.5	21.8	17.4	12.1	6.6	0.4	(24)	
	10%	DB	3.1	7.9	15.7	22.4	27.1	30.6	31.0	29.1	24.7	18.9	11.6	4.5	(25)	
		MCWB	-1.8	1.7	6.4	11.3	14.5	17.7	21.5	21.2	16.9	11.4	5.8	-0.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.8	6.5	11.6	17.5	19.1	22.5	26.0	25.5	22.3	16.6	10.7	4.2	(27)	
		MCDB	9.2	12.5	21.9	25.1	27.3	29.1	30.8	30.2	26.8	22.0	14.7	8.8	(28)	
	2%	WB	0.9	4.7	9.8	15.2	17.7	21.3	24.6	24.3	20.2	15.1	9.2	2.3	(29)	
		MCDB	6.1	10.6	18.2	24.1	25.7	27.8	29.4	29.0	24.9	19.7	13.1	6.7	(30)	
	5%	WB	-0.4	3.5	8.4	13.7	16.8	20.2	23.7	23.5	19.0	13.9	7.9	1.1	(31)	
		MCDB	4.4	9.1	16.9	21.7	25.0	27.2	28.8	28.0	23.7	17.9	11.8	5.2	(32)	
	10%	WB	-1.5	2.2	7.1	12.4	15.9	19.5	23.0	22.6	18.0	12.9	6.6	0.0	(33)	
		MCDB	2.7	7.5	14.5	19.7	24.0	26.5	28.1	26.8	22.5	17.0	11.0	3.7	(34)	
(35) Mean Daily Temperature Range	MDBR		10.4	11.2	12.0	12.7	13.0	12.8	10.0	10.0	10.7	11.2	10.5	9.5	(35)	
	5% DB	MCDBR	13.0	14.4	16.1	16.5	16.5	16.1	13.2	12.2	14.3	15.3	14.4	12.2	(36)	
		MCWBR	8.2	8.2	7.7	6.7	6.1	4.7	4.1	4.5	5.6	6.6	7.5	7.3	(37)	
	5% WB	MCDBR	12.1	13.2	14.8	14.0	13.2	11.9	9.9	9.8	11.1	11.0	12.2	11.3	(38)	
		MCWBR	7.8	7.7	7.5	6.5	5.7	4.4	4.1	4.3	5.2	5.7	7.1	7.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.406	0.488	0.509	0.539	0.571	0.659	0.651	0.648	0.583	0.538	0.431	0.384	(40)	
	taud		2.000	1.824	1.818	1.789	1.783	1.650	1.718	1.703	1.795	1.822	1.989	2.074	(41)	
	Ebn at Noon		737	713	749	756	740	675	676	664	679	658	701	732	(42)	
	Edh at Noon		132	179	197	214	219	250	233	231	200	177	133	115	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.79	3.41	4.65	5.53	6.05	5.68	5.14	4.75	3.99	3.51	2.89	2.54	(44)	
	RadStd		0.27	0.38	0.43	0.44	0.44	0.43	0.40	0.37	0.35	0.42	0.40	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page