

ANYANG, China

WMO: 538980

Lat: 36.0536N

Lon: 114.1392E

Elev: 642

StdP: 14.36

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.7	20.0	-7.1	3.8	33.9	-2.5	4.9	34.0	16.6	38.2	14.3	37.8	2.2	250	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	95.9	73.4	93.4	74.6	91.1	74.7	82.1	89.2	80.7	87.4	79.2	85.7	9.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.2	160.8	86.7	78.8	153.3	85.3	77.4	145.9	84.0	46.7	89.5	45.1	87.6	43.6	85.7	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	14.7	12.8		12.1	101.8	5.2	2.7	8.4	103.7	5.3	105.3	2.4	106.8	-1.4	108.8
				10.6	84.4	4.8	1.4	7.1	85.4	4.3	86.3	1.6	87.1	-1.9	88.1
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.7	31.3	38.0	49.3	60.3	70.7	79.4	81.6	79.1	71.4	60.7	46.2	34.9	(6)
(7)		DBStd	18.55	5.73	6.65	7.68	7.07	5.80	5.12	4.39	4.53	5.55	6.35	7.84	6.04	(7)
(8)		HDD50	1666	581	337	104	8	0	0	0	0	0	4	162	470	(8)
(9)		HDD65	4150	1046	755	489	172	17	0	0	0	12	160	564	935	(9)
(10)		CDD50	4832	0	2	84	317	640	882	979	901	641	337	49	0	(10)
(11)		CDD65	1841	0	0	3	31	192	433	514	437	203	28	0	0	(11)
(12)		CDH74	18389	0	0	31	294	1704	4841	5735	4144	1416	220	4	0	(12)
(13)		CDH80	7498	0	0	4	67	569	2336	2534	1547	404	37	0	0	(13)
(14)	Wind	WSAvg	5.6	4.8	5.8	7.0	7.1	6.6	6.1	5.2	4.8	4.7	4.8	4.9	4.8	(14)
(15)	Precipitation	PrecAvg	21.8	0.2	0.4	0.6	1.0	1.7	2.4	6.8	4.5	2.2	1.1	0.7	0.2	(15)
(16)		PrecMax	34.2	0.9	1.7	2.4	2.6	3.7	6.0	19.1	8.7	7.5	4.4	2.8	0.8	(16)
(17)		PrecMin	12.8	0.0	0.0	0.0	0.1	0.0	0.5	2.3	1.1	0.0	0.1	0.0	0.0	(17)
(18)		PrecStd	5.3	0.2	0.4	0.7	0.7	1.0	1.3	4.0	2.3	1.9	1.1	0.8	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.5	62.9	77.7	86.6	95.0	100.7	99.1	94.6	91.2	84.5	72.7	57.5	(19)
(20)			MCWB	39.5	46.0	55.6	65.0	64.8	70.1	74.1	81.0	72.3	62.6	54.9	42.8	(20)
(21)		2%	DB	48.6	57.9	71.9	80.9	89.2	97.1	95.2	91.9	87.4	79.6	67.0	52.2	(21)
(22)			MCWB	36.2	44.0	53.7	64.2	66.9	70.1	77.9	79.6	71.0	60.4	52.6	39.4	(22)
(23)		5%	DB	44.4	53.8	67.0	76.8	85.9	94.0	93.0	89.7	84.7	76.0	62.6	48.0	(23)
(24)			MCWB	34.2	41.7	51.7	60.7	65.9	70.0	77.9	78.4	69.5	59.6	50.1	37.1	(24)
(25)		10%	DB	41.0	50.0	62.4	73.4	82.9	91.1	90.8	87.6	81.9	72.4	58.4	44.5	(25)
(26)			MCWB	32.1	39.5	49.3	58.8	65.5	70.0	77.7	77.1	68.2	58.7	47.9	35.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.8	49.8	60.6	71.2	74.1	78.8	84.5	84.1	78.5	67.3	57.4	44.6	(27)
(28)			MCDWB	52.7	58.3	70.6	82.1	84.1	89.1	91.4	91.8	86.0	77.8	68.4	51.2	(28)
(29)		2%	WB	37.2	45.8	56.4	66.8	71.8	76.5	82.4	82.2	75.6	64.8	54.1	41.1	(29)
(30)			MCDWB	46.4	54.4	68.3	76.1	82.5	87.9	90.3	88.8	82.4	72.8	63.1	48.4	(30)
(31)		5%	WB	34.9	42.9	53.0	63.9	69.9	75.0	81.0	80.8	73.1	62.7	51.9	38.9	(31)
(32)			MCDWB	42.7	51.8	64.8	73.0	80.4	86.7	88.4	86.7	80.5	70.7	60.0	45.9	(32)
(33)		10%	WB	33.0	40.5	50.3	61.2	68.1	73.4	79.8	79.3	71.0	61.0	49.5	36.9	(33)
(34)			MCDWB	39.5	48.6	60.6	70.4	78.4	84.6	86.8	85.0	77.8	68.8	56.6	43.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.1	16.3	17.7	18.1	18.4	18.9	14.0	13.4	16.1	17.4	16.2	15.0	(35)
(36)			MCDBR	21.8	23.4	24.5	24.1	24.6	24.6	17.8	16.2	20.7	24.2	23.1	21.7	(36)
(37)			MCWBR	12.9	13.2	12.5	12.0	10.0	6.9	5.8	6.4	7.6	9.4	11.3	12.4	(37)
(38)		5% WB	MCDWB	19.4	21.5	22.3	21.0	19.8	18.8	14.1	13.7	15.4	17.7	19.9	18.7	(38)
(39)			MCWBR	12.0	13.0	12.7	12.3	10.3	7.3	6.4	6.6	7.3	8.3	10.7	11.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.518	0.596	0.602	0.627	0.650	0.789	0.772	0.750	0.698	0.664	0.558	0.498	(40)	
(41)		taud	1.771	1.639	1.661	1.645	1.646	1.451	1.524	1.542	1.599	1.606	1.737	1.828	(41)	
(42)		Ebn at Noon	197	197	214	219	217	188	190	189	189	177	183	193	(42)	
(43)		Edh at Noon	55	70	74	79	80	97	90	87	78	71	56	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	746	922	1334	1588	1760	1652	1458	1394	1197	993	793	708	(44)	
(45)		RadStd	89	147	131	128	143	128	111	160	131	120	132	88	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page