

ANYANG, China

WMO: 538980

Lat: 36.0536N

Lon: 114.1392E

Elev: 196

StdP: 99.00

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.5	-6.7	-21.7	0.5	1.1	-19.2	0.7	1.1	7.4	3.4	6.4	3.2	1.0	250	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	35.5	23.0	34.1	23.7	32.8	23.7	27.8	31.8	27.0	30.8	26.2	29.8	4.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.8	23.0	30.4	26.0	21.9	29.6	25.2	20.8	28.9	90.8	32.0	87.0	30.9	83.4	29.9	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.6	5.7	-11.0	38.8	2.9	1.5	-13.1	39.9	-14.8	40.7	-16.4	41.6	-18.5	42.7		
(5)			-11.9	29.1	2.7	0.8	-13.8	29.7	-15.4	30.1	-16.9	30.6	-18.8	31.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	-0.4	3.4	9.6	15.7	21.5	26.3	27.6	26.2	21.9	16.0	7.9	1.6		
	DBStd	10.30	3.18	3.70	4.27	3.93	3.22	2.85	2.44	2.52	3.08	3.53	4.35	3.35		
	HDD10.0	926	323	187	58	4	0	0	0	0	0	2	90	261		
	HDD18.3	2306	581	419	272	96	9	0	0	0	7	89	313	519		
	CDD10.0	2684	0	1	47	176	356	490	544	501	356	187	27	0		
	CDD18.3	1023	0	0	2	17	107	241	286	243	113	16	0	0		
	CDH23.3	10216	0	0	17	163	947	2689	3186	2302	787	122	2	0		
	CDH26.7	4166	0	0	2	37	316	1298	1408	859	224	21	0	0		
(14) Wind	WSAvg	2.5	2.1	2.6	3.1	3.2	3.0	2.7	2.3	2.2	2.1	2.1	2.2	2.2		
(15) Precipitation	PrecAvg	554	4	11	15	26	42	60	172	115	57	27	19	5		
	PrecMax	869	23	43	60	67	94	153	486	221	190	111	71	20		
	PrecMin	326	0	0	0	2	1	12	59	28	0	3	0	0		
	PrecStd	135	6	10	18	18	26	34	102	58	47	29	21	6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	17.2	25.4	30.4	35.0	38.2	37.3	34.8	32.9	29.2	22.6	14.2		
		MCWB	4.2	7.8	13.1	18.4	18.2	21.2	23.4	27.2	22.4	17.0	12.7	6.0		
	2%	DB	9.2	14.4	22.2	27.2	31.8	36.1	35.1	33.3	30.8	26.5	19.4	11.2		
		MCWB	2.3	6.7	12.0	17.9	19.4	21.2	25.5	26.4	21.7	15.8	11.4	4.1		
	5%	DB	6.9	12.1	19.4	24.9	29.9	34.5	33.9	32.1	29.3	24.4	17.0	8.9		
		MCWB	1.2	5.4	10.9	16.0	18.8	21.1	25.5	25.8	20.8	15.3	10.0	2.9		
	10%	DB	5.0	10.0	16.9	23.0	28.3	32.9	32.7	30.9	27.7	22.5	14.7	6.9		
		MCWB	0.1	4.2	9.6	14.9	18.6	21.1	25.4	25.1	20.1	14.8	8.9	2.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.9	9.9	15.9	21.8	23.4	26.0	29.2	29.0	25.9	19.6	14.1	7.0		
		MCDB	11.5	14.6	21.4	27.8	29.0	31.7	33.0	33.2	30.0	25.4	20.2	10.7		
	2%	WB	2.9	7.7	13.6	19.3	22.1	24.7	28.0	27.9	24.2	18.2	12.3	5.0		
		MCDB	8.0	12.4	20.1	24.5	28.0	31.1	32.4	31.5	28.0	22.7	17.3	9.1		
	5%	WB	1.6	6.1	11.7	17.7	21.1	23.9	27.2	27.1	22.9	17.1	11.1	3.9		
		MCDB	5.9	11.0	18.2	22.8	26.9	30.4	31.3	30.4	26.9	21.5	15.5	7.7		
	10%	WB	0.6	4.7	10.2	16.2	20.1	23.0	26.6	26.3	21.7	16.1	9.7	2.7		
		MCDB	4.2	9.2	15.9	21.3	25.8	29.2	30.4	29.5	25.4	20.4	13.7	6.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	9.0	9.8	10.1	10.2	10.5	7.8	7.5	8.9	9.6	9.0	8.3		
		MCDBR	12.1	13.0	13.6	13.4	13.7	13.7	9.9	9.0	11.5	13.5	12.8	12.1		
	5% WB	MCWBR	7.2	7.3	6.9	6.7	5.6	3.8	3.2	3.6	4.2	5.2	6.3	6.9		
		MCWBR	10.8	11.9	12.4	11.7	11.0	10.4	7.9	7.6	8.5	9.8	11.1	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.518	0.596	0.602	0.627	0.650	0.789	0.772	0.750	0.698	0.664	0.558	0.498		
	taud		1.771	1.639	1.661	1.645	1.646	1.451	1.524	1.542	1.599	1.606	1.737	1.828		
	Ebn at Noon		621	621	675	690	683	592	598	597	596	559	577	607		
	Edh at Noon		172	220	233	249	252	306	283	273	246	224	176	153		
(44) All-Sky Solar Radiation	RadAvg		2.35	2.91	4.20	5.01	5.55	5.21	4.59	4.39	3.77	3.13	2.50	2.23		
	RadStd		0.28	0.46	0.41	0.41	0.45	0.40	0.35	0.51	0.41	0.38	0.42	0.28		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page