

PINGLIANG, China

WMO: 539150

Lat: 35.5311N

Lon: 106.6600E

Elev: 4820

StdP: 12.31

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	12.7	-7.6	4.4	21.7	-4.1	5.3	23.5	15.6	31.3	13.4	31.6	3.6	290	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	87.5	64.1	85.1	64.1	82.6	63.7	71.0	79.7	69.7	78.1	68.4	76.4	6.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.7	126.4	74.9	67.3	120.3	73.9	65.9	114.3	72.9	38.3	80.0	37.1	78.0	35.9	76.5	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	11.9	10.2	4.2	91.7	3.8	2.3	1.4	93.4	-0.8	94.8	-2.9	96.1	-5.7	97.8
			2.6	72.9	3.6	1.8	0.0	74.2	-2.1	75.2	-4.2	76.2	-6.8	77.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	26.1	32.3	42.9	53.7	61.3	68.2	71.8	69.5	60.7	50.3	39.3	29.0
	DBStd	16.75	6.38	7.02	7.69	7.06	5.64	4.65	4.15	4.72	5.30	5.81	6.37	5.77
	HDD50	2568	742	497	242	41	2	0	0	0	2	68	323	651
	HDD65	5819	1207	917	684	342	140	22	3	14	149	455	770	1116
	CDD50	2755	0	0	23	153	351	546	675	606	321	78	2	0
	CDD65	534	0	0	0	4	25	118	213	155	19	0	0	0
	CDH74	4408	0	0	6	96	385	1153	1624	984	157	3	0	0
	CDH80	1155	0	0	0	17	66	328	492	222	30	0	0	0
Wind	WSAvg	4.6	4.5	4.7	5.3	5.5	5.1	4.5	4.5	4.3	4.1	4.1	4.3	4.4
Precipitation	PrecAvg	19.1	0.2	0.2	0.6	1.1	1.7	2.6	4.0	3.9	3.0	1.5	0.4	0.1
	PrecMax	29.0	0.6	0.6	1.2	3.0	4.5	7.3	11.7	7.6	8.1	3.1	2.0	0.3
	PrecMin	11.2	0.0	0.0	0.0	0.1	0.2	0.7	0.6	0.5	0.7	0.2	0.0	0.0
	PrecStd	4.1	0.1	0.2	0.3	0.7	1.1	1.6	2.6	1.6	1.8	0.8	0.4	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	59.4	73.1	82.5	85.4	90.1	91.3	88.6	83.9	72.9	64.1	51.9
		MCWB	35.8	42.1	49.8	56.4	57.3	60.5	65.3	67.3	62.3	55.1	47.3	36.9
	2%	DB	45.5	53.1	66.6	76.3	81.7	86.8	87.9	85.2	78.3	68.5	59.7	46.9
		MCWB	32.9	38.4	46.4	53.4	56.7	61.0	66.2	67.0	61.8	53.8	44.6	34.0
	5%	DB	41.4	48.6	61.6	72.1	78.2	83.9	85.4	82.3	74.2	65.0	55.2	43.2
		MCWB	30.5	35.9	44.0	51.1	56.1	60.8	66.2	66.6	61.3	52.3	42.3	32.1
	10%	DB	37.3	44.3	57.0	68.3	75.2	80.9	82.6	79.7	70.6	61.4	50.7	39.6
		MCWB	27.9	33.4	42.1	49.5	55.1	60.6	66.5	66.2	60.1	50.4	40.5	30.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.6	43.2	52.0	59.4	63.8	68.2	74.0	72.4	68.6	59.2	49.8	37.5
		MCDB	49.6	56.7	65.3	72.9	75.3	79.0	82.3	81.5	74.4	66.6	59.3	49.2
	2%	WB	33.2	39.2	47.7	56.4	61.2	66.5	71.6	70.8	65.9	56.9	46.6	34.7
		MCDB	44.7	51.0	62.5	70.4	73.2	76.5	80.1	79.7	72.0	64.2	55.0	45.2
	5%	WB	30.6	36.5	45.4	53.8	59.4	65.2	70.1	69.6	63.5	54.7	44.1	32.6
		MCDB	40.7	46.5	58.9	66.9	71.2	74.8	78.8	77.8	70.4	61.1	51.8	41.6
	10%	WB	28.2	34.4	43.1	51.7	57.9	63.7	68.8	68.5	61.6	52.6	42.0	30.7
		MCDB	36.1	42.6	55.0	63.0	69.3	73.2	77.4	75.9	67.6	58.5	48.7	38.3
Mean Daily Temperature Range	5% DB	MDBR	18.1	18.1	19.5	20.8	21.0	20.0	17.2	15.9	15.1	16.7	18.1	17.7
		MCDBR	25.5	26.5	28.5	28.7	28.4	27.6	24.1	21.4	23.1	23.7	25.9	23.9
		MCWBR	16.1	15.4	14.3	12.6	11.6	9.3	8.1	7.8	9.7	11.9	14.6	14.6
	5% WB	MCDBR	24.7	24.0	26.2	24.3	22.4	19.2	17.0	16.1	16.5	19.1	21.1	22.4
		MCWBR	15.9	14.6	13.9	11.9	10.6	8.2	7.4	6.7	8.3	11.0	13.0	14.1
Clear-Sky Solar Irradiance	taub	0.395	0.463	0.509	0.525	0.513	0.516	0.517	0.550	0.505	0.474	0.405	0.365	
	taud	1.962	1.818	1.757	1.766	1.869	1.922	1.988	1.867	1.933	1.924	2.008	2.071	
	Ebn at Noon	241	237	239	245	250	248	247	236	239	232	236	244	
	Edh at Noon	44	58	67	70	64	61	56	62	56	51	42	37	
All-Sky Solar Radiation	RadAvg	827	1010	1347	1627	1758	1757	1619	1448	1113	995	874	792	
	RadStd	82	131	122	142	136	142	208	168	118	143	124	88	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page