

PINGLIANG, China

WMO: 539150

Lat: 35.5311N

Lon: 106.6600E

Elev: 1469

StdP: 84.88

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-10.7	-22.0	0.6	-5.7	-20.1	0.8	-4.7	7.0	-0.4	6.0	-0.2	1.6	290	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	30.8	17.8	29.5	17.8	28.1	17.6	21.7	26.5	20.9	25.6	20.2	24.7	2.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	18.1	23.8	19.6	17.2	23.3	18.8	16.3	22.7	71.3	26.7	68.3	25.5	65.5	24.7	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.3	4.5	DB	-15.5	33.2	2.1	1.3	-17.0	34.1	-18.2	34.9	-19.4	35.6	-20.9	36.6	(4)
(5)			WB	-16.3	22.7	2.0	1.0	-17.8	23.4	-19.0	24.0	-20.1	24.6	-21.6	25.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-3.3	0.1	6.1	12.1	16.3	20.1	22.1	20.9	15.9	10.2	4.1	-1.7	(6)	
	DBStd	9.30	3.55	3.90	4.27	3.92	3.14	2.58	2.30	2.62	2.94	3.23	3.54	3.21	(7)	
	HDD10.0	1427	412	276	134	23	1	0	0	0	1	38	179	362	(8)	
	HDD18.3	3233	671	509	380	190	78	12	2	8	83	253	428	620	(9)	
	CDD10.0	1531	0	0	13	85	195	303	375	337	178	43	1	0	(10)	
	CDD18.3	297	0	0	0	2	14	66	118	86	11	0	0	0	(11)	
	CDH23.3	2449	0	0	3	53	214	641	902	547	87	2	0	0	(12)	
	CDH26.7	642	0	0	0	9	37	182	273	123	17	0	0	0	(13)	
(14) Wind	WSAvg	2.1	2.0	2.1	2.4	2.5	2.3	2.0	2.0	1.9	1.8	1.8	1.9	2.0	(14)	
(15) Precipitation	PrecAvg	484	4	6	14	28	44	65	102	98	76	37	9	2	(15)	
	PrecMax	736	15	15	30	76	115	185	297	192	206	80	51	8	(16)	
	PrecMin	285	0	0	1	3	5	17	15	13	17	5	0	0	(17)	
	PrecStd	105	3	4	7	19	29	41	65	41	46	20	11	2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	15.2	22.8	28.1	29.7	32.3	32.9	31.4	28.8	22.7	17.8	11.0	(19)	
		MCWB	2.1	5.6	9.9	13.5	14.1	15.8	18.5	19.6	16.8	12.8	8.5	2.7	(20)	
	2%	DB	7.5	11.7	19.2	24.6	27.6	30.4	31.0	29.6	25.7	20.3	15.4	8.3	(21)	
		MCWB	0.5	3.6	8.0	11.9	13.7	16.1	19.0	19.5	16.5	12.1	7.0	1.1	(22)	
	5%	DB	5.2	9.2	16.4	22.3	25.7	28.8	29.6	28.0	23.5	18.3	12.9	6.2	(23)	
		MCWB	-0.8	2.2	6.6	10.6	13.4	16.0	19.0	19.2	16.3	11.3	5.7	0.0	(24)	
	10%	DB	2.9	6.8	13.9	20.2	24.0	27.2	28.1	26.5	21.4	16.3	10.4	4.2	(25)	
		MCWB	-2.3	0.8	5.6	9.7	12.8	15.9	19.2	19.0	15.6	10.2	4.7	-1.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.6	6.2	11.1	15.2	17.6	20.1	23.4	22.4	20.3	15.1	9.9	3.1	(27)	
		MCDB	9.8	13.7	18.5	22.7	24.0	26.1	27.9	27.5	23.6	19.2	15.2	9.5	(28)	
	2%	WB	0.7	4.0	8.7	13.6	16.2	19.1	22.0	21.6	18.8	13.8	8.1	1.5	(29)	
		MCDB	7.1	10.5	16.9	21.3	22.9	24.7	26.7	26.5	22.2	17.9	12.8	7.4	(30)	
	5%	WB	-0.8	2.5	7.4	12.1	15.2	18.4	21.2	20.9	17.5	12.6	6.7	0.3	(31)	
		MCDB	4.8	8.1	15.0	19.4	21.8	23.8	26.0	25.5	21.3	16.1	11.0	5.3	(32)	
	10%	WB	-2.1	1.3	6.1	10.9	14.4	17.6	20.5	20.3	16.5	11.5	5.6	-0.7	(33)	
		MCDB	2.3	5.9	12.8	17.2	20.7	22.9	25.2	24.4	19.8	14.7	9.3	3.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	10.1	10.8	11.6	11.7	11.1	9.6	8.8	8.4	9.3	10.1	9.8	(35)	
		MCDBR	14.1	14.7	15.8	16.0	15.8	15.3	13.4	11.9	12.8	13.2	14.4	13.3	(36)	
	5% WB	MCWBR	9.0	8.6	8.0	7.0	6.4	5.2	4.5	4.4	5.4	6.6	8.1	8.1	(37)	
		MCWBR	13.7	13.4	14.6	13.5	12.4	10.7	9.4	8.9	9.2	10.6	11.7	12.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.395	0.463	0.509	0.525	0.513	0.516	0.517	0.550	0.505	0.474	0.405	0.365	(40)	
	taud		1.962	1.818	1.757	1.766	1.869	1.922	1.988	1.867	1.933	1.924	2.008	2.071	(41)	
	Ebn at Noon		760	747	755	771	788	783	779	743	752	730	744	770	(42)	
	Edh at Noon		140	183	212	221	202	191	178	197	176	162	133	118	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.61	3.18	4.25	5.13	5.54	5.54	5.11	4.56	3.51	3.14	2.75	2.50	(44)	
	RadStd		0.26	0.41	0.39	0.45	0.43	0.45	0.66	0.53	0.37	0.45	0.39	0.28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page