

XIFENGZHEN, China

WMO: 539230

Lat: 35.7267N

Lon: 107.6283E

Elev: 4669

StdP: 12.38

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	13.7	-12.0	3.4	21.2	-7.8	4.3	22.5	15.1	28.8	13.4	30.0	4.9	320	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	86.1	62.8	83.6	63.1	81.2	63.0	70.2	78.0	69.1	76.6	67.9	75.0	7.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.2	123.5	73.7	66.9	118.1	73.0	65.6	112.7	72.3	37.5	78.2	36.4	76.4	35.3	74.9	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.4	12.2	10.8	DB	5.6	90.3	4.7	2.6	2.2	92.2	-0.5	93.7	-3.2	95.1	-6.6	97.0	(4)
(5)			WB	3.5	71.9	4.3	1.2	0.4	72.8	-2.1	73.5	-4.5	74.2	-7.6	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	25.9	31.7	42.5	53.7	61.8	69.1	72.2	69.6	60.8	50.4	39.4	28.8	(6)
(7)		DBStd	17.21	6.85	7.31	8.56	8.01	6.32	5.40	4.60	5.06	5.95	6.39	6.76	6.23	(7)
(8)		HDD50	2625	747	511	259	51	3	0	0	0	2	73	322	657	(8)
(9)		HDD65	5859	1212	931	697	346	136	22	4	17	152	452	768	1122	(9)
(10)		CDD50	2843	0	0	28	162	369	574	687	607	327	86	3	0	(10)
(11)		CDD65	602	0	0	0	7	37	146	226	159	27	0	0	0	(11)
(12)		CDH74	3599	0	0	1	51	235	977	1424	783	127	1	0	0	(12)
(13)		CDH80	766	0	0	0	6	26	225	351	135	23	0	0	0	(13)
(14)	Wind	WSAvg	5.5	5.0	5.3	5.9	6.2	6.0	5.7	5.7	5.4	5.2	5.0	5.1	5.1	(14)
(15)	Precipitation	PrecAvg	22.4	0.2	0.3	0.7	1.6	2.2	2.2	4.4	4.2	3.9	1.7	0.7	0.2	(15)
(16)		PrecMax	31.7	0.5	0.8	1.9	4.0	4.4	4.6	11.4	9.0	9.8	5.9	1.9	0.7	(16)
(17)		PrecMin	14.2	0.0	0.0	0.0	0.3	0.4	0.2	1.7	0.7	1.0	0.4	0.0	0.0	(17)
(18)		PrecStd	4.8	0.1	0.2	0.4	0.8	1.1	1.2	2.0	2.4	2.2	1.2	0.6	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	55.4	69.8	79.7	83.0	88.8	89.7	87.1	82.8	70.8	61.4	48.5	(19)
(20)			MCWB	33.7	40.4	48.1	55.0	56.5	59.4	66.0	65.7	60.5	54.0	45.8	34.7	(20)
(21)		2%	DB	43.1	50.3	64.2	74.2	79.4	85.2	86.5	83.5	77.3	66.7	57.2	44.3	(21)
(22)			MCWB	31.6	36.8	45.4	52.3	55.5	59.7	64.6	66.1	61.2	52.5	43.5	32.6	(22)
(23)		5%	DB	39.3	46.5	59.5	70.2	76.4	82.5	84.0	80.9	73.5	63.4	53.5	41.2	(23)
(24)			MCWB	29.2	34.7	43.0	50.1	54.9	59.7	65.1	65.8	60.1	51.0	41.8	30.9	(24)
(25)		10%	DB	36.0	43.0	55.6	66.7	73.5	79.8	81.4	78.4	70.1	60.3	49.6	38.3	(25)
(26)			MCWB	27.2	32.7	41.4	48.9	54.1	59.4	65.3	65.4	59.1	49.8	40.0	29.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.8	41.3	51.6	58.3	62.6	67.1	72.4	71.7	69.1	58.2	49.2	36.4	(27)
(28)			MCD B	46.1	53.5	62.2	71.6	73.4	76.0	80.2	79.2	73.8	64.6	56.4	45.1	(28)
(29)		2%	WB	32.0	38.0	46.9	55.6	60.5	65.2	70.7	70.1	65.3	55.9	46.8	33.6	(29)
(30)			MCD B	42.1	47.9	60.9	67.9	70.3	75.0	78.7	77.9	71.5	61.8	52.8	42.5	(30)
(31)		5%	WB	29.7	35.6	44.4	53.3	58.7	63.9	69.5	69.1	62.7	54.0	44.1	31.6	(31)
(32)			MCD B	38.7	43.9	56.8	64.7	68.5	73.8	77.2	76.5	68.5	59.5	50.2	39.5	(32)
(33)		10%	WB	27.6	33.7	42.2	51.1	57.0	62.7	68.2	68.0	61.0	52.1	41.6	30.0	(33)
(34)			MCD B	35.1	40.8	53.2	61.9	67.8	72.6	75.9	74.7	66.5	57.5	47.8	37.1	(34)
(35)	Mean Daily Temperature Range	MDBR		12.6	13.5	15.2	16.4	16.4	15.7	14.1	13.0	12.0	12.5	13.0	12.4	(35)
(36)		5% DB	MCD BR	17.6	19.2	21.1	21.1	21.0	20.3	18.4	16.5	17.3	17.0	18.3	16.7	(36)
(37)			MCWBR	10.8	10.9	10.5	9.1	8.2	6.4	5.4	5.4	6.2	7.7	10.1	10.1	(37)
(38)		5% WB	MCD BR	17.4	17.1	19.0	18.3	15.9	14.7	13.5	12.9	12.3	13.2	14.8	15.1	(38)
(39)			MCWBR	10.8	10.2	10.0	9.1	7.7	6.0	5.3	5.3	5.7	7.2	9.1	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.400	0.475	0.510	0.526	0.515	0.529	0.534	0.567	0.520	0.492	0.419	0.375	(40)
(41)		taud		1.942	1.789	1.755	1.766	1.861	1.884	1.937	1.824	1.888	1.871	1.963	2.027	(41)
(42)		Ebn at Noon		239	233	239	244	249	245	243	231	234	225	230	239	(42)
(43)		Edh at Noon		45	60	67	70	64	63	59	65	58	54	44	39	(43)
(44)	All-Sky Solar Radiation	RadAvg		839	1027	1368	1651	1793	1826	1695	1481	1145	1005	877	789	(44)
(45)		RadStd		83	140	125	143	128	140	202	177	125	155	125	84	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-68

Nomenclature: See separate page