

YANGCHENG, China

WMO: 539750

Lat: 35.4888N

Lon: 112.4104E

Elev: 2162

StdP: 13.58

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	17.1	-14.9	2.7	27.2	-9.9	3.5	28.8	20.7	34.3	17.8	33.2	2.5	320	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	92.0	68.3	89.4	68.8	87.1	68.8	76.7	84.8	75.3	83.1	73.8	81.1	7.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.4	139.4	81.9	72.9	132.6	80.3	71.6	126.4	79.0	42.1	84.9	40.6	83.2	39.1	81.4	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.3	12.1	DB	8.7	97.5	3.6	2.3	6.1	99.1	4.0	100.4	2.0	101.7	-0.6	103.4	(4)
(5)			WB	6.4	78.6	3.4	2.1	3.9	80.2	2.0	81.4	0.1	82.5	-2.3	84.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.3	29.1	35.4	46.4	58.0	67.3	74.4	77.8	75.5	66.8	56.2	43.4	32.6	(6)
(7)		DBStd	17.74	5.51	6.63	7.34	7.06	5.28	4.52	4.01	4.79	5.37	5.59	6.48	5.26	(7)
(8)		HDD50	1997	647	411	157	16	0	0	0	0	0	14	212	540	(8)
(9)		HDD65	4751	1112	830	575	226	37	2	0	2	40	275	647	1005	(9)
(10)		CDD50	3943	0	0	47	255	536	731	860	789	504	206	15	0	(10)
(11)		CDD65	1225	0	0	0	16	108	283	395	326	94	3	0	0	(11)
(12)		CDH74	10134	0	0	14	224	1004	2583	3348	2391	533	37	0	0	(12)
(13)		CDH80	3449	0	0	1	53	288	993	1232	761	119	2	0	0	(13)
(14)	Wind	WSAvg	4.1	3.6	4.3	5.1	5.1	5.1	4.4	4.0	3.6	3.3	3.4	3.6	4.0	(14)
(15)	Precipitation	PrecAvg	24.3	0.2	0.4	0.9	1.4	2.0	2.5	5.8	4.8	3.5	1.6	0.9	0.3	(15)
(16)		PrecMax	33.5	1.1	1.7	2.6	3.2	5.2	6.9	18.5	12.6	8.8	6.0	3.4	1.1	(16)
(17)		PrecMin	13.2	0.0	0.0	0.0	0.2	0.2	0.2	0.9	0.4	0.8	0.0	0.0	0.0	(17)
(18)		PrecStd	5.2	0.3	0.4	0.7	0.8	1.5	1.8	3.5	2.5	2.1	1.3	0.9	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	59.6	75.5	86.1	91.4	95.4	95.7	93.0	88.4	78.1	67.2	52.1	(19)
(20)			MCWB	36.1	43.0	51.5	58.4	61.2	64.7	71.3	70.5	66.7	58.0	49.2	38.0	(20)
(21)		2%	DB	46.0	54.8	68.9	79.8	86.5	91.6	91.7	89.6	82.9	73.8	62.7	48.5	(21)
(22)			MCWB	33.7	40.5	49.1	56.6	60.3	65.2	71.7	72.1	66.4	56.2	47.2	36.2	(22)
(23)		5%	DB	42.4	50.7	64.2	75.5	82.9	88.7	89.0	86.9	79.7	70.0	58.4	45.4	(23)
(24)			MCWB	31.8	38.5	46.9	54.8	60.1	64.8	72.2	71.8	64.6	54.7	45.5	34.6	(24)
(25)		10%	DB	39.3	47.1	59.8	71.4	79.7	85.9	86.5	84.3	76.5	66.7	54.5	42.4	(25)
(26)			MCWB	30.6	36.5	44.9	53.2	59.3	65.0	72.4	71.3	63.5	53.8	43.8	33.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.0	46.1	56.4	65.4	68.4	74.2	79.2	77.7	73.8	62.9	52.7	42.0	(27)
(28)			MCD B	45.4	54.4	68.3	72.8	78.6	83.9	88.7	86.2	81.1	70.0	60.8	45.8	(28)
(29)		2%	WB	35.1	42.3	51.1	61.6	66.0	71.7	77.4	76.3	70.4	60.1	49.8	38.4	(29)
(30)			MCD B	43.3	51.4	64.5	73.2	77.5	81.8	85.7	84.4	77.9	67.2	56.9	45.6	(30)
(31)		5%	WB	32.9	39.8	48.5	58.4	64.1	70.1	76.0	75.0	67.8	58.3	47.9	35.9	(31)
(32)			MCD B	41.3	48.6	61.5	69.3	75.4	80.4	83.9	82.4	75.1	65.3	55.3	43.3	(32)
(33)		10%	WB	31.1	37.5	46.0	56.1	62.5	68.5	74.5	73.6	65.7	56.4	45.6	33.8	(33)
(34)			MCD B	38.3	46.2	57.3	66.7	73.8	79.3	82.2	80.7	72.5	63.2	52.6	41.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.2	17.8	19.6	20.6	20.7	19.4	15.3	14.8	15.9	17.2	17.2	16.3	(35)
(36)			MCD BR	22.8	24.5	28.3	28.8	28.2	26.0	20.3	19.0	22.0	24.3	24.2	22.1	(36)
(37)			MCWBR	14.0	13.8	13.8	11.4	10.4	8.2	6.5	6.5	8.2	10.5	12.5	13.3	(37)
(38)		5% WB	MCD BR	20.7	21.9	25.0	22.5	20.9	18.1	15.3	14.8	16.6	17.2	19.1	19.1	(38)
(39)			MCWBR	13.1	12.7	12.7	10.5	9.7	7.4	6.3	6.3	7.8	8.8	10.7	12.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.503	0.591	0.605	0.620	0.632	0.748	0.753	0.748	0.675	0.647	0.540	0.476	(40)	
(41)		taud	1.760	1.621	1.634	1.635	1.658	1.492	1.533	1.523	1.614	1.606	1.738	1.832	(41)	
(42)		Ebn at Noon	203	199	214	221	221	196	194	191	195	182	190	201	(42)	
(43)		Edh at Noon	55	71	76	80	79	93	89	89	77	71	56	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	798	966	1322	1591	1753	1685	1493	1379	1150	1006	830	751	(44)	
(45)		RadStd	92	163	138	139	141	137	141	168	121	146	135	91	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page