

LINDONG, China

WMO: 540270

Lat: 43.9687N

Lon: 119.3782E

Elev: 1591

StdP: 13.87

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.4	-4.7	-25.1	1.4	-1.2	-21.6	1.8	1.7	28.5	11.5	23.1	11.7	3.3	290	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	92.0	67.2	88.8	66.1	86.0	65.3	73.4	83.6	71.7	81.3	70.0	79.8	7.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.5	119.0	78.3	68.6	111.5	77.0	66.8	104.6	75.4	38.4	83.6	36.7	81.3	35.2	79.7	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	22.3	18.0	15.1	DB	-12.2	97.7	5.2	2.9	-15.9	99.9	-18.9	101.6	-21.8	103.2	-25.6	105.4
(5)				WB	-13.0	76.8	4.9	2.4	-16.5	78.5	-19.4	79.9	-22.1	81.2	-25.7	82.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	10.2	17.3	30.3	47.1	60.6	69.7	74.4	71.0	60.2	45.2	26.4	13.1	(6)
(7)		DBStd	23.91	7.31	8.57	9.46	8.73	7.57	6.08	4.53	4.94	6.73	7.98	10.00	7.26	(7)
(8)		HDD50	4968	1233	914	614	154	7	0	0	7	188	709	1142		(8)
(9)		HDD65	8412	1698	1334	1076	539	180	24	1	9	172	614	1158	1607	(9)
(10)		CDD50	2753	0	0	3	67	334	591	757	650	311	39	1	0	(10)
(11)		CDD65	722	0	0	0	2	42	165	293	194	26	0	0	0	(11)
(12)		CDH74	7339	0	0	3	83	684	1765	2659	1724	400	21	0	0	(12)
(13)		CDH80	2596	0	0	0	18	247	675	1013	549	93	1	0	0	(13)
(14)	Wind	WSAvg	5.6	5.7	5.9	6.9	7.5	7.0	5.1	4.5	4.1	4.5	5.4	5.4	5.4	(14)
(15)	Precipitation	PrecAvg	14.6	0.0	0.1	0.2	0.3	0.9	2.7	4.8	3.5	1.3	0.5	0.2	0.0	(15)
(16)		PrecMax	24.3	0.3	0.7	0.9	1.4	2.6	8.9	10.2	10.6	5.6	2.2	0.9	0.4	(16)
(17)		PrecMin	9.2	0.0	0.0	0.0	0.0	0.0	0.7	1.8	0.3	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.6	0.1	0.2	0.2	0.3	0.8	1.9	2.2	2.4	1.2	0.6	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	48.1	67.2	82.4	93.1	95.8	96.3	93.5	87.3	77.2	59.6	40.3	(19)
(20)		MCWB	26.7	34.7	44.9	53.9	60.3	64.2	70.6	70.2	62.7	54.6	42.7	30.4		(20)
(21)		2%	DB	29.8	42.2	58.4	75.3	86.7	90.9	92.2	88.7	82.7	70.2	52.5	32.7	(21)
(22)		MCWB	22.9	31.1	40.5	50.2	57.6	64.2	70.3	67.9	60.7	51.1	38.8	25.3		(22)
(23)		5%	DB	26.3	37.2	52.5	70.2	81.3	87.2	88.8	85.7	78.7	64.6	46.6	29.0	(23)
(24)		MCWB	20.3	27.8	37.8	47.9	55.9	63.4	69.1	67.0	59.1	47.8	35.6	22.8		(24)
(25)		10%	DB	22.7	32.6	47.1	65.2	76.7	83.7	85.6	82.8	75.0	59.9	41.6	25.2	(25)
(26)		MCWB	17.5	24.9	34.2	45.7	53.7	62.5	68.4	66.1	57.7	45.3	32.3	20.0		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	35.1	45.8	55.4	63.2	71.2	76.7	75.4	67.5	56.3	43.6	30.5	(27)
(28)		MCDWB	34.5	47.3	64.0	77.7	83.9	83.9	86.9	87.2	79.6	70.5	57.9	40.1		(28)
(29)		2%	WB	23.0	31.2	41.3	51.7	59.8	68.7	74.3	72.7	64.5	52.7	39.1	25.7	(29)
(30)		MCDWB	29.4	41.9	57.8	72.7	78.9	81.7	85.2	82.1	75.4	67.2	51.5	32.4		(30)
(31)		5%	WB	20.3	28.0	37.6	48.7	57.8	66.8	72.7	70.9	62.1	49.4	35.9	22.8	(31)
(32)		MCDWB	26.1	37.0	51.5	67.9	75.8	79.3	82.8	79.7	72.9	61.2	46.3	28.8		(32)
(33)		10%	WB	17.5	24.9	34.5	46.1	55.7	65.2	71.1	69.1	59.8	46.3	32.6	20.1	(33)
(34)		MCDWB	22.6	32.6	46.4	63.3	73.6	77.5	80.9	77.9	71.0	58.3	41.1	25.2		(34)
(35)	Mean Daily Temperature Range		MDBR	19.4	21.4	21.8	23.6	23.7	20.9	18.6	20.6	24.5	22.3	19.8	18.8	(35)
(36)		5% DB	MCDBR	24.6	28.1	31.7	33.9	32.8	28.7	25.0	25.9	31.1	31.7	27.6	24.2	(36)
(37)			MCWBR	19.2	20.1	19.2	17.1	13.2	9.6	8.6	9.7	12.9	16.0	17.2	18.4	(37)
(38)			MCDBR	24.5	27.7	30.2	31.1	26.8	21.3	19.5	19.7	25.2	27.9	27.1	23.9	(38)
(39)		5% WB	MCWBR	19.2	19.9	18.6	16.4	11.7	8.5	8.6	9.2	11.6	14.8	17.1	18.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.281	0.317	0.367	0.440	0.519	0.558	0.511	0.470	0.417	0.373	0.314	0.286	(40)	
(41)		taud	2.301	2.212	2.106	1.954	1.806	1.816	2.003	2.082	2.144	2.167	2.248	2.266	(41)	
(42)		Ebn at Noon	267	274	272	260	243	233	244	250	253	248	248	251	(42)	
(43)		Edh at Noon	26	34	44	56	66	66	54	48	42	36	27	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	729	1065	1464	1770	1954	1859	1830	1761	1497	1106	744	606	(44)	
(45)		RadStd	54	62	81	114	125	147	125	80	77	76	59	48	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.95	N/A	N/A	+1.48	N/A	N/A	N/A	N/A	+234	+135
(47)	Regional (4 neighbors)	N/A	N/A	-2.45	N/A	N/A	-0.81	N/A	N/A	+122	N/A

Nomenclature: See separate page