

SUIFENHE, China

WMO: 540960

Lat: 44.3894N

Lon: 131.1645E

Elev: 570

StdP: 94.66

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.7	-22.8	-29.7	0.3	-23.3	-28.1	0.3	-21.6	12.1	-18.2	11.2	-19.2	4.9	270	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	28.6	20.3	26.9	19.7	25.4	19.3	22.7	26.1	21.7	24.9	20.8	23.8	3.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.7	17.5	24.8	20.7	16.5	23.6	19.8	15.5	22.6	70.5	26.2	66.7	24.9	63.2	23.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.9	9.4	8.2	-26.9	31.6	2.4	1.6	-28.6	32.7	-30.0	33.6	-31.4	34.5	-33.1	35.6		
			-27.1	24.2	2.3	1.0	-28.8	24.8	-30.2	25.4	-31.5	25.9	-33.2	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.6	-15.3	-11.5	-4.2	5.0	11.5	16.5	19.3	13.5	5.7	-5.0	-13.4		
		DBStd	13.20	4.17	4.93	5.36	4.74	4.01	3.44	2.82	2.81	3.50	4.60	6.19	4.89	(7)
		HDD10.0	3355	785	603	440	164	29	1	0	9	147	452	726		
		HDD18.3	5532	1043	836	698	401	215	74	16	23	149	392	701	984	(8)
		CDD10.0	1007	0	0	0	13	76	197	308	287	113	13	1	0	(9)
		CDD18.3	144	0	0	0	0	3	20	66	52	3	0	0	0	(10)
		CDH23.3	883	0	0	0	4	58	174	384	238	23	1	0	0	(11)
		CDH26.7	162	0	0	0	1	12	34	82	33	1	0	0	0	(12)
(13)	Wind	WSAvg	3.3	4.3	4.1	4.0	3.6	3.2	2.4	2.2	2.3	2.6	3.4	3.9	4.3	(13)
(14)	Precipitation	PrecAvg	564	4	9	11	28	52	96	111	125	66	35	17	9	(14)
(15)		PrecMax	906	19	27	44	56	126	253	236	267	143	95	47	44	(15)
(16)		PrecMin	304	0	2	1	2	10	31	24	37	10	2	1	1	(16)
(17)		PrecStd	141	4	7	10	17	30	52	53	61	38	24	12	9	(17)
(18)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	-1.4	4.5	13.2	23.1	28.5	30.0	31.2	29.6	25.9	21.2	12.9	3.5		
(19)		0.4% MCWB	-3.8	-0.2	5.5	11.6	15.0	18.7	22.1	22.5	18.0	12.4	6.5	0.3		
(20)		2% DB	-4.4	2.0	9.1	19.5	24.8	27.4	29.0	27.4	23.5	17.9	9.5	-0.6		
(21)		2% MCWB	-6.4	-1.8	2.6	9.2	13.8	18.1	21.5	21.2	16.4	10.6	4.6	-2.8		
(22)		5% DB	-6.6	-0.7	6.2	16.4	22.1	25.3	27.2	25.9	21.6	15.4	6.8	-3.3		
(23)		5% MCWB	-8.4	-3.5	1.1	7.7	12.6	17.8	21.0	20.3	15.5	9.1	3.0	-5.2		
(24)		10% DB	-9.0	-3.1	3.9	13.7	19.5	23.3	25.4	24.5	19.9	13.2	4.2	-5.7		
(25)		10% MCWB	-10.4	-5.5	-0.2	6.1	11.6	17.2	20.4	20.1	14.6	8.3	1.0	-7.3		
(26)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	-3.5	0.5	5.9	12.2	16.6	21.4	24.2	24.1	20.0	13.7	7.3	0.3		
(27)		0.4% MCDB	-1.9	3.7	12.0	20.9	24.9	26.3	28.8	27.2	23.2	18.7	11.7	3.2		
(28)		2% WB	-6.3	-1.5	3.4	9.7	14.7	20.0	23.1	22.7	18.2	11.8	5.1	-2.6		
(29)		2% MCDB	-4.6	1.6	8.2	18.1	22.5	24.3	26.8	25.8	21.4	15.8	8.6	-0.6		
(30)		5% WB	-8.4	-3.5	1.5	8.1	13.5	19.0	22.1	21.7	16.9	10.5	3.0	-5.1		
(31)		5% MCDB	-6.7	-0.6	5.7	15.6	20.2	23.2	25.4	24.5	19.8	14.2	6.5	-3.4		
(32)		10% WB	-10.4	-5.5	-0.1	6.6	12.3	17.9	21.2	20.8	15.7	8.8	1.1	-7.3		
(33)		10% MCDB	-9.0	-3.1	3.3	12.9	18.1	22.1	24.3	23.3	18.7	12.8	3.9	-5.7		
(34)	Mean Daily Temperature Range	MDBR	8.1	9.2	9.1	10.4	10.5	9.8	8.1	8.2	10.9	10.4	8.3	7.6		
(35)		5% DB MCDBR	10.8	12.1	12.0	15.4	15.7	13.5	11.6	10.4	12.9	14.0	11.5	10.4		
(36)		5% WB MCWBR	9.2	9.3	7.3	8.0	7.0	6.2	5.1	5.0	6.4	7.7	7.8	8.7		
(37)		5% WB MCWBR	10.8	11.9	11.6	14.3	13.5	11.0	9.3	8.6	10.0	11.8	11.0	10.0		
(38)	Clear-Sky Solar Irradiance	taub	0.304	0.347	0.425	0.522	0.543	0.526	0.494	0.454	0.410	0.425	0.360	0.316		
(39)		taud	2.141	2.032	1.901	1.757	1.777	1.904	2.060	2.167	2.203	2.014	2.095	2.110		
(40)		Ebn at Noon	789	813	790	744	745	760	782	800	805	712	704	722		
(41)		Edh at Noon	95	129	169	213	215	190	161	140	124	131	100	90		
(42)	All-Sky Solar Radiation	RadAvg	2.28	3.39	4.40	4.59	5.07	5.37	4.87	4.65	4.23	3.06	2.09	1.85		
(43)		RadStd	0.17	0.16	0.34	0.39	0.49	0.58	0.49	0.41	0.34	0.22	0.16	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page