

XILIN GOL, China

WMO: 541020

Lat: 43.9501N

Lon: 116.1200E

Elev: 3294

StdP: 13.03

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.2	-17.6	-27.9	1.3	-18.8	-24.4	1.6	-15.7	21.4	15.6	18.9	9.5	4.6	140	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	91.0	62.8	87.7	61.8	84.5	60.8	68.1	81.2	66.4	79.2	64.8	77.4	9.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.2	101.8	72.9	62.3	95.0	71.8	60.5	88.9	70.7	34.5	80.9	33.1	79.1	31.8	77.3	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
22.1	19.1	16.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-25.7	96.1	4.8	3.6	-29.2	98.7	-32.0	100.8	-34.8	102.9	-38.3	105.5
			-26.0	70.7	4.8	2.9	-29.4	72.7	-32.3	74.4	-34.9	76.0	-38.4	78.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.6	-0.6	8.2	24.9	42.7	55.9	66.5	72.2	68.4	57.3	40.5	20.9	4.6
	DBStd	26.73	9.26	10.82	10.91	9.92	8.85	6.89	5.74	6.11	8.16	9.30	11.51	9.54
	HDD50	6439	1568	1170	778	259	40	0	0	0	26	317	872	1409
	HDD65	10153	2033	1590	1242	669	305	63	7	34	253	761	1322	1874
	CDD50	2282	0	0	1	41	222	495	687	570	244	22	0	0
	CDD65	521	0	0	0	1	23	108	229	139	21	0	0	0
	CDH74	5501	0	0	0	39	411	1202	2224	1349	272	4	0	0
	CDH80	1930	0	0	0	6	122	424	877	446	55	0	0	0
Wind	WSAvg	7.6	6.7	6.8	8.2	9.5	9.6	7.9	7.2	6.8	7.0	7.3	7.3	6.9
Precipitation	PrecAvg	10.9	0.1	0.1	0.2	0.3	0.9	1.7	3.3	2.7	1.1	0.4	0.2	0.1
	PrecMax	18.9	0.4	0.4	0.6	1.2	3.7	3.9	11.1	6.2	2.6	2.7	0.7	0.3
	PrecMin	6.1	0.0	0.0	0.0	0.0	0.0	0.5	0.4	0.2	0.0	0.0	0.0	0.0
	PrecStd	2.6	0.1	0.1	0.2	0.3	0.8	0.8	1.9	1.5	0.7	0.5	0.2	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.9	43.8	62.5	79.1	90.0	92.6	96.7	94.0	85.4	72.6	54.9	36.3
		MCWB	24.3	33.1	41.9	50.1	56.4	60.9	66.5	65.0	58.5	51.2	39.8	28.7
	2%	DB	23.8	36.7	54.3	71.7	83.1	88.6	92.2	88.6	80.8	66.6	48.3	28.5
		MCWB	19.5	28.7	38.5	47.2	54.1	60.0	65.1	62.9	56.7	48.6	36.1	23.3
	5%	DB	19.7	31.6	48.3	66.4	78.4	85.1	88.4	84.8	76.8	61.6	43.1	23.6
		MCWB	16.2	25.2	34.8	45.2	52.4	58.9	64.1	61.8	55.5	45.7	33.6	19.8
	10%	DB	14.9	26.3	43.3	61.4	73.8	81.2	84.8	81.6	72.8	56.6	37.9	19.3
		MCWB	12.3	21.4	32.3	42.6	50.8	58.2	63.2	61.2	53.9	43.2	30.6	16.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.3	33.6	43.1	52.6	58.6	64.9	71.3	69.5	63.4	53.8	40.9	28.7
		MCDB	30.0	41.9	57.6	75.7	78.2	79.7	82.6	84.8	77.6	68.3	53.6	36.0
	2%	WB	19.7	29.3	39.1	48.3	56.3	63.4	68.9	67.4	59.7	49.8	36.9	23.3
		MCDB	23.7	36.4	53.3	67.3	76.4	79.0	82.1	79.6	73.1	63.5	46.9	28.1
	5%	WB	16.2	25.2	35.6	46.1	54.3	62.0	67.4	65.7	57.6	47.0	33.8	19.8
		MCDB	19.5	31.5	48.0	63.6	73.7	77.6	80.6	77.0	71.9	59.2	42.7	23.5
	10%	WB	12.2	21.5	32.3	43.5	52.2	60.4	66.0	64.1	55.8	44.1	30.7	16.2
		MCDB	14.8	26.3	42.8	60.3	70.4	74.9	79.2	75.8	69.5	55.7	37.9	19.2
Mean Daily Temperature Range	5% DB	MDBR	19.9	22.6	23.2	24.1	24.4	21.8	20.4	21.6	23.7	22.5	20.3	18.7
		MCDBR	24.3	26.8	30.1	31.5	30.8	27.6	25.7	26.0	28.2	29.1	25.0	22.4
		MCWBR	20.5	20.2	18.4	15.5	12.4	8.7	7.5	8.5	11.3	15.1	16.2	18.2
	5% WB	MCDBR	24.0	26.2	29.0	28.4	26.1	21.3	20.0	19.8	22.6	26.0	24.3	22.5
		MCWBR	20.4	20.1	18.0	15.0	11.3	7.7	7.4	7.9	10.2	14.9	16.1	18.5
Clear-Sky Solar Irradiance	taub	0.268	0.303	0.350	0.405	0.468	0.491	0.450	0.435	0.384	0.348	0.295	0.276	
	taud	2.288	2.201	2.120	2.027	1.904	1.948	2.137	2.139	2.210	2.223	2.275	2.251	
	Ebn at Noon	272	279	278	271	256	251	260	259	264	258	257	255	
	Edh at Noon	26	35	43	51	60	58	47	46	39	34	26	25	
All-Sky Solar Radiation	RadAvg	700	1059	1512	1853	2066	2008	1976	1847	1542	1118	754	554	
	RadStd	58	72	102	118	131	136	77	65	83	78	54	61	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-3.40	N/A	N/A	-1.13	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	-2.95	N/A	N/A	-1.03	N/A	N/A	N/A	N/A

Nomenclature: See separate page