

YANJI, China

WMO: 542920

Lat: 42.8737N

Lon: 129.5045E

Elev: 846

StdP: 14.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-3.6	-20.3	1.9	-0.7	-17.1	2.2	1.3	26.8	8.5	24.5	9.0	4.1	270	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	88.5	71.2	85.4	69.8	82.5	68.7	75.6	83.9	73.7	80.3	72.0	78.4	6.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.0	126.3	80.4	71.5	120.0	78.3	69.8	113.3	76.2	39.9	84.2	38.0	80.3	36.4	78.4	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
23.4	20.3	17.4	DB	-10.2	93.6	4.4	2.4	-13.4	95.4	-16.0	96.8	-18.5	98.1	-21.7	99.9	
			WB	-11.0	77.7	4.2	2.1	-14.0	79.2	-16.5	80.4	-18.9	81.6	-22.0	83.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	10.0	17.4	30.4	45.7	57.2	65.8	71.9	71.4	60.7	46.2	27.9	13.7
	DBStd	22.91	6.35	7.96	8.56	7.76	6.92	6.27	5.53	4.80	5.81	7.30	9.32	7.19
	HDD50	4905	1241	914	607	174	16	0	0	0	3	162	662	1126
	HDD65	8463	1706	1334	1071	579	255	65	9	7	151	583	1112	1591
	CDD50	2471	0	0	1	46	240	474	678	665	323	44	0	0
	CDD65	554	0	0	0	1	14	89	222	206	22	0	0	0
	CDH74	4133	0	0	0	39	307	786	1581	1259	158	3	0	0
	CDH80	1207	0	0	0	7	86	244	529	325	16	0	0	0
Wind	WSAvg	5.9	6.8	6.6	7.2	7.1	6.4	5.7	5.0	4.5	4.0	5.1	5.6	6.3
Precipitation	PrecAvg	20.3	0.2	0.2	0.4	1.1	2.2	3.4	4.4	4.9	2.2	1.0	0.6	0.2
	PrecMax	29.0	0.9	1.1	1.7	3.0	5.1	13.3	8.4	11.4	8.0	4.4	3.1	2.0
	PrecMin	12.2	0.0	0.0	0.0	0.1	0.3	0.8	0.6	0.5	0.2	0.0	0.0	0.0
	PrecStd	4.2	0.2	0.2	0.3	0.7	1.3	1.9	1.9	2.7	1.7	0.8	0.6	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	45.2	63.2	79.0	87.7	90.9	93.2	90.7	82.3	72.2	57.7	36.8
		MCWB	26.1	34.3	46.6	55.1	61.3	68.2	75.2	75.2	68.2	56.9	45.4	30.9
	2%	DB	27.2	39.7	54.7	72.9	82.0	86.1	88.9	87.0	78.3	67.4	51.7	32.5
		MCWB	22.0	30.8	40.4	51.6	59.0	66.7	73.7	73.1	64.7	54.1	41.8	27.4
	5%	DB	23.8	35.3	49.8	67.1	76.8	82.5	85.8	83.6	75.1	63.4	46.2	28.7
		MCWB	19.4	28.4	38.0	48.6	57.5	65.6	71.8	71.5	62.8	51.5	38.2	24.2
	10%	DB	20.7	31.6	44.9	62.1	72.1	78.4	82.5	80.7	72.3	59.6	41.6	25.5
		MCWB	16.9	26.2	35.1	46.0	55.2	64.3	71.1	70.1	61.2	49.6	35.2	21.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	35.4	46.4	57.9	64.7	71.7	78.7	77.4	70.8	59.4	46.8	31.6
		MCDB	31.2	43.0	61.4	74.1	81.2	83.6	90.0	87.6	78.5	67.7	55.5	35.1
	2%	WB	22.3	32.1	41.8	52.6	61.1	69.6	76.5	75.3	68.0	56.5	42.6	27.7
		MCDB	26.7	38.3	52.7	69.0	76.3	80.6	85.4	83.5	74.3	64.2	49.6	31.9
	5%	WB	19.5	29.0	38.5	50.0	58.9	67.7	74.4	73.7	65.6	54.1	39.3	24.3
		MCDB	23.5	34.9	48.5	65.4	72.9	77.9	81.8	80.2	71.6	60.7	45.0	28.4
	10%	WB	17.0	26.1	35.7	47.1	57.0	65.8	72.5	72.2	63.5	51.3	35.7	21.5
		MCDB	20.6	31.5	44.1	59.7	69.4	75.2	79.2	77.9	69.4	57.5	41.2	25.2
Mean Daily Temperature Range	5% DB	MDBR	17.8	20.3	20.3	23.1	21.6	18.0	15.4	15.7	21.6	22.7	18.0	16.7
		MCDBR	22.3	25.2	28.2	33.6	31.7	26.5	21.9	19.9	24.6	28.1	25.5	20.6
		MCWBR	18.0	17.9	16.4	16.2	12.5	9.7	8.2	7.9	11.4	15.2	16.4	16.3
	5% WB	MCDBR	21.7	23.9	26.1	31.2	26.8	21.7	18.1	16.0	19.2	24.0	24.1	19.9
		MCWBR	17.7	17.5	15.9	15.9	11.8	9.2	8.1	7.3	10.0	14.2	16.3	16.2
Clear-Sky Solar Irradiance	taub	0.329	0.383	0.457	0.540	0.579	0.573	0.536	0.484	0.432	0.443	0.386	0.339	
	taud	2.124	1.997	1.864	1.743	1.723	1.822	1.983	2.124	2.177	2.005	2.056	2.099	
	Ebn at Noon	246	248	243	233	229	231	238	247	251	224	219	226	
	Edh at Noon	32	44	57	69	72	66	56	47	41	43	35	30	
All-Sky Solar Radiation	RadAvg	755	1074	1344	1507	1627	1658	1482	1456	1359	1030	707	617	
	RadStd	52	40	88	115	157	200	176	124	116	75	66	40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page