

JI'AN JILIN, China

WMO: 543770

Lat: 41.1531N

Lon: 126.2179E

Elev: 740

StdP: 14.31

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.8	-3.4	-16.0	2.4	-2.0	-12.6	2.9	1.3	12.7	18.1	11.3	16.2	2.8	0	0.429

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	89.7	73.0	86.9	72.2	84.6	71.3	77.1	84.8	75.7	82.3	74.4	80.3	6.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	135.2	80.5	73.8	129.5	79.3	72.5	123.8	78.1	41.3	85.2	39.9	82.2	38.5	80.2	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.3	11.9	9.9	-11.3	94.0	3.7	3.1	-14.0	96.3	-16.2	98.1	-18.2	99.9	-21.0	102.2		
			-11.8	78.5	3.7	2.0	-14.5	80.0	-16.6	81.2	-18.7	82.3	-21.4	83.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	12.2	20.5	34.3	49.0	60.6	69.6	75.7	74.1	63.9	49.8	32.5	16.7
	DBStd	23.00	7.56	8.71	7.85	7.80	5.74	4.73	3.93	4.56	5.63	7.29	9.31	8.26
	HDD50	4254	1172	826	488	111	3	0	0	0	1	94	527	1032
	HDD65	7518	1637	1246	952	481	157	14	0	3	85	472	974	1497
	CDD50	3056	0	0	2	81	332	589	796	748	419	87	2	0
	CDD65	846	0	0	0	1	21	153	332	286	53	0	0	0
	CDH74	6384	0	0	0	48	392	1245	2435	1950	308	6	0	0
	CDH80	1941	0	0	0	3	72	388	844	596	38	0	0	0
Wind	WSAvg	3.5	2.5	3.2	4.4	5.1	4.9	4.0	3.5	3.1	3.1	3.1	2.9	2.6
Precipitation	PrecAvg	37.0	0.4	0.5	0.7	2.0	2.9	4.6	9.6	9.2	3.4	1.7	1.3	0.7
	PrecMax	50.1	1.2	1.1	1.9	4.8	7.0	11.5	18.5	20.5	7.4	3.9	3.1	1.3
	PrecMin	28.6	0.0	0.0	0.1	0.3	0.8	1.5	2.3	3.0	0.8	0.0	0.2	0.1
	PrecStd	6.0	0.3	0.3	0.5	1.1	1.4	2.2	3.9	4.6	1.7	0.9	0.7	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	46.7	63.0	79.7	86.0	92.2	94.8	91.6	84.1	74.2	59.5	38.2
		MCWB	30.9	37.3	47.3	56.7	64.2	68.2	75.8	75.5	69.7	59.2	49.5	33.1
	2%	DB	30.9	40.9	56.2	74.0	81.9	87.8	90.6	88.3	80.5	69.6	53.6	34.4
		MCWB	26.9	33.8	43.5	54.0	61.0	67.7	74.6	75.1	67.4	56.3	45.5	30.9
	5%	DB	27.4	37.3	51.5	69.7	78.7	84.5	87.3	85.9	77.6	65.7	49.5	32.1
		MCWB	23.9	31.5	40.5	51.5	59.4	67.1	73.7	73.6	65.0	54.3	43.5	29.1
	10%	DB	24.1	34.1	47.5	65.3	75.1	81.3	84.7	83.4	74.7	61.9	45.6	29.4
		MCWB	20.9	29.7	38.3	49.4	57.7	66.4	73.1	72.5	63.8	52.2	40.8	26.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.8	38.4	49.1	60.5	67.6	72.7	79.6	78.7	72.7	61.5	51.2	34.6
		MCDB	34.9	44.8	60.1	73.7	80.9	83.0	89.6	86.7	80.1	70.7	57.0	36.9
	2%	WB	27.4	34.9	44.4	55.7	64.2	70.5	77.6	77.1	70.2	58.4	47.3	31.7
		MCDB	30.4	39.6	54.2	70.4	75.5	80.7	85.7	84.8	76.2	66.9	52.3	34.0
	5%	WB	24.1	32.3	41.6	53.1	61.8	69.3	76.2	75.8	68.0	56.1	44.6	29.3
		MCDB	27.0	36.2	50.1	66.0	73.8	79.4	83.1	82.4	74.2	63.0	48.4	31.9
	10%	WB	21.1	29.8	38.8	50.8	59.8	68.0	74.8	74.6	65.8	53.8	41.3	26.5
		MCDB	23.9	34.2	46.5	62.3	71.3	77.4	81.1	80.3	72.1	59.8	45.2	29.0
Mean Daily Temperature Range	5% DB	MDBR	19.3	19.9	19.4	23.0	23.1	19.6	15.6	16.3	20.8	21.9	16.2	16.7
		MCDBR	19.3	20.8	25.7	31.1	30.7	26.5	21.0	19.8	23.1	26.4	20.9	15.8
		MCWBR	15.4	14.5	14.6	14.2	12.0	9.1	7.2	7.8	10.2	13.2	13.4	12.7
	5% WB	MCDBR	18.3	18.6	24.0	26.7	25.3	19.9	16.2	15.5	18.0	22.2	17.7	14.4
		MCWBR	14.9	13.5	14.5	13.1	10.9	8.0	6.6	6.8	8.8	11.9	12.6	12.2
Clear-Sky Solar Irradiance	taub	0.377	0.451	0.527	0.601	0.637	0.685	0.632	0.553	0.487	0.514	0.450	0.390	
	taud	1.956	1.807	1.714	1.643	1.616	1.595	1.756	1.934	2.023	1.849	1.911	1.962	
	Ebn at Noon	228	227	225	220	216	206	216	230	236	205	200	210	
	Edh at Noon	40	55	67	77	81	83	70	57	49	52	42	37	
All-Sky Solar Radiation	RadAvg	779	1056	1380	1518	1716	1614	1413	1432	1373	1041	682	626	
	RadStd	44	66	79	113	144	174	159	158	126	76	84	45	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	-1.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (16 neighbors)	N/A	N/A	-1.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page