

JI'AN JILIN, China

WMO: 543770

Lat: 41.1531N

Lon: 126.2179E

Elev: 226

StdP: 98.65

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.6	-19.7	-26.7	0.3	-18.9	-24.8	0.4	-17.0	5.7	-7.7	5.1	-8.8	1.2	0	0.429

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	32.1	22.8	30.5	22.3	29.2	21.8	25.1	29.3	24.3	27.9	23.5	26.8	2.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.9	19.3	27.0	23.2	18.5	26.3	22.5	17.7	25.6	78.1	29.6	74.9	27.9	71.7	26.8	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.3	4.4	-24.0	34.5	2.1	1.7	-25.5	35.7	-26.8	36.7	-27.9	37.7	-29.4	39.0		
			-24.3	25.9	2.1	1.1	-25.8	26.7	-27.0	27.3	-28.2	28.0	-29.7	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-11.0	-6.4	1.3	9.4	15.9	20.9	24.3	23.4	17.7	9.9	0.3	-8.5
	DBStd	12.78	4.20	4.84	4.36	4.33	3.19	2.63	2.18	2.53	3.13	4.05	5.17	4.59
	HDD10.0	2363	651	459	271	62	2	0	0	0	1	52	293	573
	HDD18.3	4177	909	692	529	267	87	8	0	2	47	262	541	832
	CDD10.0	1698	0	0	1	45	184	327	442	416	233	48	1	0
	CDD18.3	470	0	0	0	1	12	85	184	159	29	0	0	0
	CDH23.3	3547	0	0	0	27	218	692	1353	1083	171	3	0	0
	CDH26.7	1078	0	0	0	2	40	216	469	331	21	0	0	0
Wind	WSAvg	1.6	1.1	1.4	2.0	2.3	2.2	1.8	1.5	1.4	1.4	1.4	1.3	1.1
Precipitation	PrecAvg	941	11	12	19	51	74	116	245	233	86	44	34	17
	PrecMax	1273	31	29	47	123	178	293	469	521	188	100	80	33
	PrecMin	727	0	1	2	8	20	39	59	75	21	0	6	2
	PrecStd	152	8	8	12	27	36	57	99	116	43	23	19	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.8	8.2	17.2	26.5	30.0	33.4	34.9	33.1	28.9	23.4	15.3	3.5
		MCWB	-0.6	2.9	8.5	13.7	17.9	20.1	24.3	24.2	20.9	15.1	9.7	0.6
	2%	DB	-0.6	4.9	13.4	23.3	27.7	31.0	32.5	31.3	26.9	20.9	12.0	1.3
		MCWB	-2.8	1.0	6.4	12.2	16.1	19.8	23.7	24.0	19.6	13.5	7.5	-0.6
	5%	DB	-2.6	2.9	10.8	21.0	26.0	29.2	30.7	29.9	25.3	18.7	9.7	0.1
		MCWB	-4.5	-0.3	4.7	10.9	15.2	19.5	23.2	23.1	18.4	12.4	6.4	-1.6
	10%	DB	-4.4	1.2	8.6	18.5	23.9	27.4	29.3	28.6	23.7	16.6	7.6	-1.5
		MCWB	-6.1	-1.3	3.5	9.7	14.3	19.1	22.8	22.5	17.6	11.2	4.9	-3.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.1	3.6	9.5	15.8	19.8	22.6	26.4	25.9	22.6	16.4	10.7	1.5
		MCDB	1.6	7.1	15.6	23.2	27.2	28.3	32.0	30.4	26.7	21.5	13.9	2.7
	2%	WB	-2.5	1.6	6.9	13.1	17.9	21.4	25.3	25.1	21.2	14.7	8.5	-0.2
		MCDB	-0.9	4.2	12.4	21.3	24.2	27.0	29.8	29.4	24.6	19.4	11.3	1.1
	5%	WB	-4.4	0.2	5.3	11.7	16.6	20.7	24.5	24.4	20.0	13.4	7.0	-1.5
		MCDB	-2.8	2.3	10.0	18.9	23.2	26.3	28.4	28.0	23.4	17.2	9.1	-0.1
	10%	WB	-6.1	-1.2	3.8	10.5	15.4	20.0	23.8	23.7	18.8	12.1	5.1	-3.0
		MCDB	-4.5	1.2	8.1	16.8	21.8	25.2	27.3	26.8	22.3	15.4	7.3	-1.7
Mean Daily Temperature Range	5% DB	MDBR	10.7	11.1	10.8	12.8	12.8	10.9	8.7	9.1	11.6	12.2	9.0	9.3
		MCDBR	10.7	11.5	14.3	17.3	17.0	14.7	11.6	11.0	12.8	14.7	11.6	8.8
	5% WB	MCWBR	8.5	8.1	8.1	7.9	6.7	5.1	4.0	4.3	5.7	7.3	7.4	7.0
		MCWBR	10.2	10.3	13.3	14.9	14.0	11.1	9.0	8.6	10.0	12.3	9.8	8.0
Clear-Sky Solar Irradiance	taub	taub	0.377	0.451	0.527	0.601	0.637	0.685	0.632	0.553	0.487	0.514	0.450	0.390
		taud	1.956	1.807	1.714	1.643	1.616	1.595	1.756	1.934	2.023	1.849	1.911	1.962
	Ebn at Noon	Ebn at Noon	720	716	710	692	681	650	682	725	744	647	630	662
		Edh at Noon	126	172	212	244	256	262	221	180	154	163	133	117
All-Sky Solar Radiation	RadAvg	RadAvg	2.46	3.33	4.35	4.79	5.41	5.09	4.46	4.51	4.33	3.28	2.15	1.97
	RadStd	RadStd	0.14	0.21	0.25	0.36	0.46	0.55	0.50	0.50	0.40	0.24	0.27	0.14

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-1.08	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	N/A	N/A	-0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page