

BEIJING, China

WMO: 545110

Lat: 39.8060N

Lon: 116.4693E

Elev: 33

StdP: 100.94

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.6	-9.8	-28.0	0.3	-4.6	-25.8	0.4	-3.7	12.5	-3.5	11.1	-3.8	2.8	0	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	35.2	22.0	33.9	22.2	32.2	22.3	27.1	30.7	26.2	29.7	25.5	29.0	3.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.6	29.3	25.2	20.4	28.3	24.2	19.2	27.6	86.8	30.6	82.1	29.7	78.4	28.8	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.4	6.9	-14.4	38.6	2.4	1.9	-16.2	40.0	-17.6	41.0	-18.9	42.1	-20.7	43.4		
(5)			-15.7	28.9	2.1	1.0	-17.2	29.6	-18.4	30.2	-19.6	30.7	-21.1	31.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	-3.2	0.1	6.9	14.6	20.8	25.1	27.1	25.9	20.9	13.6	4.9	-1.4		
	DBStd	11.18	3.21	3.50	4.01	3.54	3.11	2.73	2.30	2.15	2.93	3.42	3.94	3.04		
	HDD10.0	1324	409	277	113	5	0	0	0	0	9	157	354			
	HDD18.3	2842	667	510	354	120	12	1	0	11	152	402	613			
	CDD10.0	2419	0	0	17	143	334	452	530	493	328	119	4	0		
	CDD18.3	896	0	0	0	8	87	202	272	236	88	3	0	0		
	CDH23.3	9073	0	0	4	130	969	2066	2943	2251	675	36	0	0		
	CDH26.7	3671	0	0	1	26	340	934	1312	869	185	4	0	0		
(14) Wind	WSAvg	2.7	2.9	2.9	3.2	3.2	3.0	2.5	2.2	2.1	2.2	2.3	2.5	2.9		
(15) Precipitation	PrecAvg	544	2	6	10	24	38	79	176	112	55	27	13	3		
	PrecMax	827	12	24	42	79	88	225	446	254	114	66	77	9		
	PrecMin	290	0	0	0	2	6	19	47	46	4	0	0	0		
	PrecStd	137	4	7	12	20	19	44	93	55	32	20	17	3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	14.0	23.1	29.3	34.8	37.1	37.9	35.2	32.2	26.9	19.1	10.6		
		MCWB	1.6	4.6	10.5	15.0	18.5	20.1	22.7	23.3	20.8	15.3	9.2	2.7		
	2%	DB	6.2	11.1	20.1	26.8	32.1	35.0	35.7	33.2	30.4	24.0	16.1	8.0		
		MCWB	-0.1	3.1	9.6	14.3	17.6	20.4	23.2	23.5	20.0	14.8	8.1	1.3		
	5%	DB	4.4	9.0	17.4	24.5	30.1	33.2	34.0	32.1	28.9	21.9	14.0	6.1		
		MCWB	-1.2	2.0	7.8	13.5	17.2	20.6	23.8	23.5	19.6	13.4	7.1	0.5		
	10%	DB	2.8	7.0	14.9	22.4	28.2	31.8	32.2	31.0	27.1	20.0	12.0	4.2		
		MCWB	-2.2	1.1	6.4	12.3	16.5	20.4	24.0	23.6	19.0	12.7	6.1	-0.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.8	5.6	12.7	18.8	22.3	25.3	28.5	28.7	25.2	19.2	11.2	3.7		
		MCDB	8.1	10.1	20.8	25.6	29.4	30.9	32.1	30.9	29.1	23.1	15.8	7.5		
	2%	WB	0.2	4.2	10.4	16.6	20.8	24.1	27.4	27.1	23.3	17.5	9.6	2.0		
		MCDB	5.2	9.5	18.2	22.9	27.9	29.6	31.1	30.4	26.6	20.7	13.5	6.9		
	5%	WB	-0.9	2.7	8.5	15.3	19.6	23.2	26.5	26.1	21.9	16.0	8.3	0.9		
		MCDB	3.6	8.4	15.6	21.5	26.4	28.4	30.3	29.3	25.7	19.2	12.2	5.1		
	10%	WB	-1.9	1.4	7.0	13.8	18.5	22.4	25.8	25.4	20.8	14.7	7.0	-0.1		
		MCDB	2.1	6.6	13.6	19.8	24.9	27.7	29.5	28.6	24.7	18.0	11.0	3.5		
(35) Mean Daily Temperature Range	MDBR		10.2	11.2	12.0	12.5	12.7	11.1	9.1	9.3	10.9	11.2	10.4	9.7		
	5% DB	MCDBR	12.6	14.3	16.4	16.2	16.4	14.6	12.1	11.2	13.1	13.7	13.4	12.6		
		MCWBR	8.1	8.6	8.4	7.3	6.2	5.0	4.5	4.7	5.2	6.4	7.3	7.7		
	5% WB	MCDBR	11.8	13.0	14.8	13.2	12.6	10.4	8.8	8.4	9.8	10.1	11.7	11.3		
		MCWBR	7.7	8.2	8.0	7.2	6.3	4.9	4.7	4.8	5.2	5.9	7.1	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.430	0.514	0.535	0.604	0.652	0.797	0.795	0.756	0.676	0.618	0.485	0.441		
	taud		1.954	1.789	1.779	1.688	1.622	1.438	1.478	1.528	1.615	1.671	1.898	1.981		
	Ebn at Noon		678	667	712	696	674	581	577	582	592	565	611	629		
	Edh at Noon		132	180	201	234	256	308	293	272	235	200	139	120		
(44) All-Sky Solar Radiation	RadAvg		2.44	3.19	4.52	5.40	6.00	5.32	4.83	4.75	4.20	3.27	2.49	2.18		
	RadStd		0.19	0.33	0.40	0.30	0.43	0.51	0.33	0.26	0.30	0.33	0.34	0.21		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page