

LETING, China

WMO: 545390

Lat: 39.4291N

Lon: 118.8867E

Elev: 39

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.3	13.5	-15.4	2.4	22.1	-11.5	3.0	22.5	18.2	28.6	16.1	28.3	3.7	290	0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	90.9	76.0	88.5	75.1	86.5	73.9	80.6	86.9	79.1	84.7	77.7	82.9	6.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.9	150.3	84.6	77.4	142.9	83.1	76.1	136.6	81.7	44.4	87.3	42.9	85.1	41.4	83.0	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.4	13.9	11.9	DB	5.8	95.8	4.2	3.6	2.7	98.3	0.3	100.4	-2.1	102.4	-5.2	105.0
			WB	3.9	82.7	4.2	1.6	0.9	83.9	-1.5	84.8	-3.9	85.7	-6.9	86.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.0	25.1	30.8	42.0	55.0	66.1	73.6	79.0	77.9	70.0	56.8	41.3	29.4	(6)
	DBStd	19.76	5.90	6.36	7.17	6.35	5.76	4.65	3.85	3.93	5.34	6.67	7.37	5.88	(7)
	HDD50	2527	772	536	265	24	0	0	0	0	18	274	638		(8)
	HDD65	5363	1237	956	713	302	58	2	0	0	18	262	712	1103	(9)
	CDD50	4002	0	0	17	175	498	708	897	866	599	230	12	0	(10)
	CDD65	1363	0	0	0	4	90	260	432	401	167	9	0	0	(11)
	CDH74	10946	0	0	0	47	690	1889	3917	3418	952	33	0	0	(12)
	CDH80	3306	0	0	0	5	153	582	1333	1053	178	2	0	0	(13)
(14) Wind	WSAvg	5.3	5.0	5.5	6.5	7.0	6.3	5.5	4.9	4.4	4.4	4.5	4.8	4.6	(14)
(15) Precipitation	PrecAvg	25.1	0.1	0.2	0.4	1.1	1.7	3.1	8.8	6.5	1.8	0.9	0.4	0.2	(15)
	PrecMax	45.8	0.7	1.3	1.3	4.7	6.7	10.6	19.0	14.0	5.2	2.4	1.9	1.0	(16)
	PrecMin	13.0	0.0	0.0	0.0	0.1	0.4	0.4	3.2	1.9	0.1	0.0	0.0	0.0	(17)
	PrecStd	7.2	0.2	0.3	0.4	1.1	1.3	2.3	4.4	3.0	1.2	0.7	0.4	0.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.8	52.4	69.1	79.0	88.5	93.2	94.4	92.3	87.4	77.9	64.1	48.2	(19)
		MCWB	33.2	40.3	51.9	59.5	64.8	70.9	76.3	78.7	71.7	63.5	52.2	40.2	(20)
	2%	DB	39.7	47.7	62.9	74.2	84.0	88.9	91.6	89.6	84.3	73.9	60.0	44.2	(21)
		MCWB	31.3	37.2	48.5	56.8	63.8	70.8	77.8	77.1	69.5	61.1	50.3	36.3	(22)
	5%	DB	36.9	44.4	57.8	70.8	81.0	86.0	89.0	87.5	81.9	70.6	56.4	41.0	(23)
		MCWB	29.7	35.2	45.1	55.3	62.6	69.5	77.2	75.8	68.7	59.2	48.0	34.4	(24)
	10%	DB	34.3	41.0	53.8	67.2	77.9	83.2	86.7	85.5	79.6	67.7	53.0	38.3	(25)
		MCWB	28.4	33.6	42.4	52.7	60.8	68.8	76.1	75.2	67.6	57.4	45.8	32.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.1	42.0	54.6	63.8	69.9	76.2	82.9	82.6	77.2	67.8	55.7	42.5	(27)
		MCDB	40.3	48.8	66.2	74.5	83.0	85.4	89.6	88.5	82.7	73.9	59.9	46.0	(28)
	2%	WB	32.6	38.9	49.9	59.9	67.6	73.8	80.9	80.7	73.8	65.0	52.4	38.0	(29)
		MCDB	37.6	45.1	59.3	70.8	79.3	82.9	87.7	86.2	79.5	70.5	57.6	41.7	(30)
	5%	WB	30.8	36.6	46.6	57.3	65.6	72.3	79.6	79.2	72.2	62.4	49.6	35.6	(31)
		MCDB	35.8	42.7	56.5	68.0	76.3	81.2	85.7	84.3	77.8	67.3	54.4	39.3	(32)
	10%	WB	29.0	34.3	43.6	54.7	63.7	71.0	78.3	77.8	70.6	60.1	46.9	33.3	(33)
		MCDB	33.8	40.2	52.1	63.6	73.7	79.6	83.8	82.7	76.2	65.2	52.0	37.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	16.0	17.0	18.1	18.0	15.4	12.3	13.0	16.1	17.1	15.6	14.4	(35)
		MCDBR	18.5	20.3	23.0	23.7	22.8	20.4	15.7	15.0	18.0	19.7	20.2	17.4	(36)
	5% WB	MCWBR	12.0	12.1	11.9	11.2	9.2	7.2	6.2	6.1	7.2	9.5	12.1	11.6	(37)
		MCWBR	16.5	18.7	22.0	21.6	19.5	16.4	13.0	12.2	14.5	15.9	18.3	15.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.440	0.519	0.549	0.623	0.666	0.775	0.777	0.710	0.635	0.626	0.511	0.459	(40)
		taud	1.916	1.774	1.741	1.647	1.601	1.470	1.509	1.610	1.688	1.651	1.827	1.919	(41)
	Ebn at Noon		212	211	223	216	211	189	187	195	198	178	186	193	(42)
		Edh at Noon	44	58	67	78	83	95	90	80	69	65	48	41	(43)
(44) All-Sky Solar Radiation	RadAvg		748	986	1419	1671	1882	1688	1523	1486	1350	1020	755	650	(44)
	RadStd		79	99	115	85	117	154	119	97	96	87	90	60	(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.24	+1.78	N/A	N/A	N/A	N/A	-205	-302	+247	+158	(46)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+122	N/A	(47)

Nomenclature: See separate page