

BAODING, China

WMO: 546020

Lat: 38.7373N

Lon: 115.4776E

Elev: 18

StdP: 101.11

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.8	-8.9	-24.8	0.4	-2.3	-22.5	0.5	-1.9	6.8	1.3	5.7	-0.4	1.3	220	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	35.4	22.9	33.9	23.1	32.6	23.2	27.5	31.4	26.5	30.4	25.6	29.5	2.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.4	22.0	30.0	25.4	20.6	29.1	24.5	19.5	28.4	87.8	31.3	83.3	30.5	79.5	29.5	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.4	4.6	-13.3	38.0	2.5	1.6	-15.1	39.1	-16.6	40.1	-18.0	41.0	-19.8	42.2		
(5)			-14.4	28.6	2.2	1.0	-16.0	29.3	-17.3	29.9	-18.5	30.5	-20.2	31.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	-2.5	1.3	8.2	15.3	21.1	25.8	27.6	26.1	21.4	14.4	5.9	-0.5	(6)	(7)
	DBStd	10.98	3.17	3.56	4.08	3.72	3.17	2.90	2.54	2.29	3.01	3.50	4.09	3.02	(7)	(8)
	HDD10.0	1183	387	244	84	4	0	0	0	0	6	132	325		(8)	(9)
	HDD18.3	2642	646	477	314	103	11	1	0	0	9	127	372	583	(9)	(10)
	CDD10.0	2547	0	0	29	164	344	473	546	498	341	143	10	0	(10)	(11)
	CDD18.3	966	0	0	1	13	97	223	287	240	99	6	0	0	(11)	(12)
	CDH23.3	9743	0	0	9	132	891	2395	3281	2306	688	41	0	0	(12)	(13)
	CDH26.7	3962	0	0	2	23	291	1112	1502	852	176	4	0	0	(13)	(14)
(14) Wind	WSAvg	2.0	1.7	1.9	2.4	2.6	2.5	2.2	2.0	1.8	1.7	1.7	1.7	1.7	(14)	(15)
(15) Precipitation	PrecAvg	500	3	6	10	24	35	70	155	108	50	23	14	3	(15)	(16)
	PrecMax	785	19	30	42	61	86	143	382	282	108	92	54	11	(16)	(17)
	PrecMin	290	0	0	0	3	3	18	58	40	7	2	0	0	(17)	(18)
	PrecStd	127	4	7	13	15	19	36	74	57	27	19	16	4	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	14.3	24.3	29.2	33.8	37.5	38.1	34.5	31.9	27.1	19.4	10.6	(19)	(20)
		MCWB	1.8	5.1	11.5	16.6	19.1	20.7	22.7	26.0	22.4	16.7	9.9	3.0	(20)	(21)
	2%	DB	6.2	11.8	20.8	26.7	31.6	35.5	35.7	33.0	30.2	24.4	16.5	7.9	(21)	(22)
		MCWB	0.1	4.1	10.6	15.5	18.6	20.9	24.2	25.0	21.2	14.9	9.3	2.0	(22)	(23)
	5%	DB	4.4	9.6	18.1	24.6	29.9	34.0	34.2	31.9	28.8	22.4	14.0	5.9	(23)	(24)
		MCWB	-0.8	3.1	8.8	14.7	18.3	21.1	24.5	24.7	20.5	14.3	8.0	0.9	(24)	(25)
	10%	DB	2.7	7.6	15.5	22.6	28.2	32.3	32.8	30.8	27.2	20.4	12.2	4.3	(25)	(26)
		MCWB	-1.6	2.1	7.4	13.7	17.7	20.8	24.6	24.3	19.8	13.8	7.3	0.1	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	6.7	13.8	19.8	22.8	25.2	28.7	28.5	25.3	19.5	11.8	4.2	(27)	(28)
		MCDB	7.5	11.6	21.8	25.3	29.2	31.6	32.9	32.0	28.9	23.3	15.3	8.2	(28)	(29)
	2%	WB	0.7	5.0	11.6	17.6	21.4	24.1	27.8	27.4	23.7	17.6	10.4	2.7	(29)	(30)
		MCDB	5.1	10.3	18.6	23.6	28.0	30.8	32.0	30.9	27.7	21.0	14.7	6.6	(30)	(31)
	5%	WB	-0.3	3.7	9.8	16.3	20.3	23.3	26.9	26.4	22.4	16.4	9.1	1.6	(31)	(32)
		MCDB	3.5	8.7	16.7	22.4	27.0	29.5	31.1	30.0	26.6	20.0	12.9	5.1	(32)	(33)
	10%	WB	-1.2	2.4	8.1	14.9	19.2	22.5	26.1	25.6	21.2	15.2	7.9	0.6	(33)	(34)
		MCDB	2.2	7.2	14.5	20.9	25.5	28.6	30.2	29.0	25.4	18.6	11.3	3.6	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	9.3	10.3	10.8	11.0	10.4	8.1	7.8	9.4	9.5	8.5	8.0	(35)	(36)
		MCDBR	11.1	12.2	14.2	14.3	14.1	13.4	10.7	9.3	11.2	12.1	11.3	10.8	(36)	(37)
	5% WB	MCWBR	6.9	7.1	6.9	6.4	5.4	4.0	3.3	3.6	4.4	5.5	6.1	6.5	(37)	(38)
		MCWBR	9.6	10.9	13.5	11.8	11.6	9.8	8.3	7.6	8.9	9.3	10.0	9.3	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.471	0.550	0.557	0.613	0.657	0.802	0.798	0.771	0.695	0.644	0.521	0.471	(39)	(40)
		taud	1.855	1.715	1.723	1.657	1.607	1.421	1.466	1.493	1.574	1.618	1.806	1.898	(40)	(41)
	Ebn at Noon		641	642	698	692	673	580	577	576	584	552	584	605	(41)	(42)
		Edh at Noon	150	197	215	243	260	314	298	283	247	214	156	134	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		2.41	3.06	4.46	5.35	5.88	5.28	4.72	4.58	4.07	3.21	2.48	2.17	(43)	(44)
	RadStd		0.21	0.38	0.41	0.32	0.45	0.49	0.30	0.31	0.34	0.36	0.38	0.25	(44)	(45)

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (13 neighbors)		(m)								
		-0.37	-1.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page