

ZHOU SHUIZI, China

WMO: 546620

Lat: 38.908N

Lon: 121.660E

Elev: 318

StdP: 14.53

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.0	13.2	-7.7	3.7	17.9	-4.0	4.5	20.1	24.5	20.8	22.4	22.1	9.0	0	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	89.4	74.5	86.4	73.7	84.3	73.1	79.4	84.5	78.2	82.7	76.9	81.1	8.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.5	149.5	82.7	76.9	142.0	81.2	75.4	134.7	79.8	43.6	84.8	42.1	83.4	40.7	80.7	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.0	19.4	17.3	DB	6.1	94.1	4.3	3.0	3.1	96.2	0.6	98.0	-1.8	99.6	-4.9	101.8	(4)
			WB	4.4	82.1	4.0	1.9	1.5	83.4	-0.9	84.5	-3.1	85.6	-6.0	87.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.2	24.9	29.8	40.2	52.5	63.6	71.5	77.2	77.8	70.1	57.3	42.2	30.0	(6)
		DBStd	19.51	7.08	7.11	7.08	6.12	5.78	4.73	4.02	3.70	4.76	6.73	8.30	7.25	(7)
		HDD50	2593	779	566	313	41	0	0	0	0	19	256	619		(8)
		HDD65	5508	1244	986	770	376	96	6	0	13	250	683	1084		(9)
		CDD50	3769	0	0	8	117	423	645	843	862	604	244	23	0	(10)
		CDD65	1207	0	0	0	2	54	200	378	397	166	10	0	0	(11)
		CDH74	7839	0	0	0	12	313	1094	2655	3012	728	25	0	0	(12)
		CDH80	1983	0	0	0	2	54	289	747	788	102	1	0	0	(13)
(14)	Wind	WSAvg	8.0	8.1	8.4	9.0	9.3	8.7	7.6	7.2	6.7	6.8	7.5	8.3	8.1	(14)
(15)	Precipitation	PrecAvg	24.9	0.4	0.3	0.5	1.3	1.7	3.3	6.8	5.8	2.3	1.1	0.8	0.4	(15)
(16)		PrecMax	37.1	1.5	1.1	2.7	3.5	5.2	9.6	15.3	14.5	5.9	3.1	1.9	2.4	(16)
(17)		PrecMin	13.4	0.0	0.0	0.0	0.2	0.3	0.6	0.6	0.4	0.2	0.1	0.1	0.0	(17)
(18)		PrecStd	6.7	0.4	0.3	0.6	1.0	1.2	2.6	3.6	3.7	1.5	0.7	0.6	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	45.0	50.3	64.6	75.1	85.6	91.5	93.4	91.7	86.0	77.1	65.9	52.0		(19)
(20)		MCWB	37.5	40.2	48.6	54.4	62.1	68.1	77.0	78.0	70.5	64.7	54.8	46.7		(20)
(21)		DB	42.1	46.5	58.6	69.8	80.7	86.3	89.6	88.2	82.6	73.2	61.3	48.5		(21)
(22)		MCWB	36.7	37.8	45.6	53.4	60.1	67.3	75.9	76.2	69.5	62.5	53.9	43.6		(22)
(23)		DB	39.3	43.2	53.9	66.2	77.2	82.8	86.4	86.2	80.5	70.0	58.8	46.0		(23)
(24)		MCWB	34.6	36.7	42.6	51.4	58.9	66.4	75.2	75.3	68.3	60.8	52.4	41.1		(24)
(25)		DB	36.9	40.9	50.3	62.8	74.0	80.3	84.2	84.3	78.4	67.8	55.9	42.7		(25)
(26)		MCWB	32.3	35.6	40.8	49.7	58.0	66.2	74.9	74.9	67.7	59.6	50.3	37.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	40.3	43.0	50.9	59.8	67.2	73.8	81.1	81.8	76.4	68.2	59.4	49.2		(27)
(28)		MCDB	42.7	46.6	61.2	69.1	78.4	81.6	88.2	86.8	80.6	71.7	61.7	50.6		(28)
(29)		WB	37.4	40.3	47.3	56.3	64.2	71.9	79.3	79.9	74.1	66.0	56.0	44.7		(29)
(30)		MCDB	41.0	43.6	54.3	64.7	73.8	78.7	85.2	84.6	78.3	70.2	59.2	47.5		(30)
(31)		WB	34.9	38.2	44.8	54.2	62.5	70.3	78.2	78.7	72.3	63.9	53.6	41.2		(31)
(32)		MCDB	38.7	41.8	51.0	61.8	71.5	76.6	83.3	82.7	76.8	68.1	57.9	44.6		(32)
(33)		WB	32.4	36.0	42.5	52.0	60.7	69.2	76.9	77.5	70.7	61.6	50.9	38.1		(33)
(34)		MCDB	36.0	40.0	48.6	59.2	68.8	75.2	81.3	81.4	75.4	66.1	55.5	41.8		(34)
(35)	Mean Daily Temperature Range	MDBR	14.0	14.6	15.2	15.8	16.4	14.6	12.1	12.0	14.6	15.9	15.5	14.5		(35)
(36)		5% DB	18.0	18.0	19.9	20.8	20.5	19.3	15.7	14.2	16.7	18.0	19.4	18.7		(36)
(37)		MCWBR	14.4	12.8	11.9	11.3	10.3	8.9	7.6	7.1	8.7	10.9	14.2	14.9		(37)
(38)		5% WB	17.1	16.2	17.8	18.2	17.4	14.6	13.0	11.7	14.0	16.2	17.8	17.5		(38)
(39)		MCWBR	14.6	12.9	12.0	11.5	10.5	7.8	7.1	6.8	9.1	11.8	15.2	15.5		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.432	0.494	0.540	0.607	0.637	0.722	0.708	0.626	0.558	0.574	0.516	0.447		(40)
(41)		taud	1.944	1.820	1.763	1.679	1.670	1.575	1.644	1.802	1.877	1.747	1.834	1.927		(41)
(42)		Ebn at Noon	217	220	226	221	218	200	201	214	220	193	187	200		(42)
(43)		Edh at Noon	43	56	65	75	77	85	79	66	58	59	48	41		(43)
(44)	All-Sky Solar Radiation	RadAvg	742	995	1426	1671	1864	1708	1531	1507	1406	1053	739	620		(44)
(45)		RadStd	61	81	105	89	147	152	143	145	105	78	80	41		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.57	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page