

DEZHOU, China

WMO: 547140

Lat: 37.433N

Lon: 116.317E

Elev: 72

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.1	19.7	-8.0	3.6	27.9	-3.2	4.6	31.1	16.0	31.5	14.4	32.9	3.3	220	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	93.6	75.7	91.3	75.8	89.4	75.2	82.1	88.7	80.4	86.8	78.9	85.1	7.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.2	156.9	86.6	78.6	148.9	85.2	77.1	141.3	83.6	46.2	88.5	44.3	87.0	42.7	85.4	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.5	14.3	12.4	DB	12.5	98.4	2.6	1.9	10.7	99.8	9.2	100.9	7.8	101.9	5.9	103.3
(5)				WB	10.0	84.1	2.5	2.0	8.2	85.6	6.7	86.8	5.3	87.9	3.5	89.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.5	30.2	35.6	44.9	60.3	69.2	77.9	80.8	79.1	71.8	59.8	45.0	33.6
	DBStd	18.95	5.07	5.76	7.30	6.70	6.31	4.81	3.91	3.65	4.53	6.46	8.54	5.61
	HDD50	1922	614	404	190	7	0	0	0	0	0	4	193	510
	HDD65	4492	1079	822	622	169	34	1	0	0	4	185	601	975
	CDD50	4643	0	2	33	316	594	838	956	901	654	307	42	0
	CDD65	1738	0	0	0	28	163	389	491	436	208	23	0	0
	CDH74	16398	0	0	2	187	1363	3975	5241	4136	1340	154	0	0
	CDH80	6038	0	0	0	18	402	1683	2137	1479	299	20	0	0
Wind	WSAvg	5.4	4.3	4.8	6.2	7.4	6.8	5.9	5.4	4.6	4.9	5.2	5.1	4.6
Precipitation	PrecAvg	22.5	0.2	0.2	0.4	1.1	1.3	2.5	7.6	5.6	1.9	1.1	0.5	0.2
	PrecMax	41.7	0.7	1.5	1.3	5.4	4.1	6.9	18.4	13.0	5.3	4.6	1.8	0.6
	PrecMin	10.1	0.0	0.0	0.0	0.0	0.3	0.6	1.2	0.3	0.1	0.0	0.0	0.0
	PrecStd	7.5	0.2	0.4	0.4	1.1	0.9	1.7	3.9	3.2	1.3	1.1	0.5	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	62.0	69.6	82.5	92.1	98.3	96.6	92.7	87.9	82.7	69.3	55.1
		MCWB	36.8	47.6	52.3	63.2	71.9	69.1	75.0	80.5	74.5	65.4	52.4	44.4
	2%	DB	44.5	53.2	65.4	79.3	87.9	93.7	93.8	90.5	85.5	78.3	65.1	49.2
		MCWB	34.9	41.4	50.1	61.7	67.3	70.5	78.5	78.2	71.7	61.3	50.9	39.9
	5%	DB	41.8	48.5	61.2	75.6	84.5	91.1	91.6	89.1	83.5	75.0	61.1	45.6
		MCWB	33.2	38.0	47.7	59.2	66.8	71.2	78.5	76.9	69.9	60.0	50.4	37.5
	10%	DB	38.8	45.0	57.3	72.3	81.6	88.6	89.4	87.3	81.4	71.6	56.5	42.4
		MCWB	31.6	35.8	45.2	57.2	65.2	70.4	78.1	76.2	68.0	58.1	47.8	36.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.9	48.8	55.5	67.3	73.5	78.9	84.6	82.8	78.7	67.2	56.1	44.8
		MCDB	46.1	60.8	67.0	78.1	87.3	85.7	91.6	89.3	85.4	78.9	62.7	53.7
	2%	WB	36.6	42.0	51.7	64.1	71.1	76.4	83.2	81.4	75.8	64.2	53.7	41.4
		MCDB	42.7	51.7	61.8	75.3	83.2	85.0	89.8	88.1	81.7	75.4	61.5	47.2
	5%	WB	34.2	39.4	48.9	61.8	69.3	74.6	81.3	79.9	73.1	61.8	51.3	39.1
		MCDB	39.6	46.2	59.0	72.4	80.1	84.8	87.7	86.3	80.6	71.2	58.0	43.5
	10%	WB	32.6	37.3	46.7	59.3	67.3	73.0	79.9	78.3	71.2	59.5	48.9	36.8
		MCDB	37.3	43.1	55.8	69.2	77.8	83.2	86.1	84.5	78.2	68.4	55.4	41.4
Mean Daily Temperature Range	5% DB	MDBR	14.0	15.7	16.1	18.1	18.5	17.7	13.7	13.7	16.5	18.0	15.5	13.2
		MCDBR	18.5	21.6	21.6	21.4	22.7	21.2	17.0	15.4	18.0	21.5	21.2	18.6
		MCWBR	11.3	12.8	11.6	10.3	9.4	7.2	6.5	5.9	7.5	8.9	10.6	11.4
	5% WB	MCDBR	15.6	19.2	19.3	19.7	19.0	17.2	14.0	13.1	15.0	18.1	16.9	15.7
		MCWBR	10.6	12.0	11.8	11.4	9.9	8.5	7.5	6.3	7.6	8.7	10.6	10.3
Clear-Sky Solar Irradiance	taub	0.521	0.593	0.603	0.638	0.671	0.813	0.791	0.766	0.697	0.682	0.582	0.524	
	taud	1.742	1.634	1.630	1.596	1.580	1.391	1.473	1.500	1.570	1.554	1.680	1.771	
	Ebn at Noon	191	194	212	215	211	183	185	185	187	169	171	178	
	Edh at Noon	55	69	75	82	85	103	94	90	79	74	58	50	
All-Sky Solar Radiation	RadAvg	698	895	1346	1617	1825	1676	1492	1419	1259	991	741	647	
	RadStd	85	140	118	106	136	134	101	140	129	99	118	82	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page