

LINGXIAN, China

WMO: 547150

Lat: 37.3214N

Lon: 116.5628E

Elev: 19

StdP: 101.10

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.6	-8.6	-21.9	0.5	-2.9	-19.7	0.7	-3.4	8.4	3.8	7.3	2.2	1.3	110	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.2	35.0	23.7	33.7	24.0	32.4	24.0	28.0	31.5	27.2	30.6	26.3	29.6	3.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	22.9	30.3	26.2	21.7	29.4	25.4	20.6	28.7	90.2	31.5	86.3	30.8	82.6	29.6	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.0	6.1	-14.3	37.7	3.0	1.6	-16.5	38.9	-18.2	39.9	-19.9	40.8	-22.1	42.0		
			-14.8	29.3	2.6	0.8	-16.7	29.9	-18.2	30.4	-19.7	30.8	-21.6	31.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	-1.9	1.7	8.3	14.5	20.2	25.7	27.4	25.8	21.4	15.3	6.8	0.2	(6)
(7)		DBStd	10.66	3.19	3.91	4.22	3.83	3.11	2.76	2.22	2.39	2.90	3.71	4.20	3.19	(7)
(8)		HDD10.0	1114	368	234	84	7	0	0	0	0	5	113	303		(8)
(9)		HDD18.3	2567	626	467	312	124	17	0	0	8	105	347	562		(9)
(10)		CDD10.0	2518	0	1	31	142	317	470	539	491	341	171	17	0	(10)
(11)		CDD18.3	930	0	0	1	9	76	220	281	232	99	12	0	0	(11)
(12)		CDH23.3	9164	0	0	4	78	662	2373	3092	2162	709	83	0	0	(12)
(13)		CDH26.7	3634	0	0	0	10	177	1113	1350	791	183	10	0	0	(13)
(14)	Wind	WSAvg	2.6	2.3	2.8	3.5	3.5	3.0	2.9	2.4	2.1	2.4	2.4	2.3		(14)
(15)	Precipitation	PrecAvg	563	3	9	10	24	44	74	183	123	43	29	16	4	(15)
(16)		PrecMax	944	26	31	43	70	104	172	477	307	147	216	79	18	(16)
(17)		PrecMin	300	0	0	0	1	5	9	34	30	2	1	0	0	(17)
(18)		PrecStd	160	5	9	11	18	23	39	116	68	29	41	19	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	15.5	23.4	28.1	32.7	37.0	36.9	34.4	31.6	27.9	20.3	11.1	(19)
(20)			MCWB	3.2	8.0	14.1	19.4	20.9	21.5	24.2	27.0	22.7	18.4	12.8	5.4	(20)
(21)		2%	DB	7.1	12.7	20.6	25.4	30.3	35.3	35.1	32.9	30.1	25.7	17.6	8.6	(21)
(22)			MCWB	1.7	6.2	12.7	17.8	20.1	21.8	25.2	26.4	22.0	16.8	11.3	3.8	(22)
(23)		5%	DB	5.2	10.6	18.0	23.5	28.7	33.9	33.7	31.7	28.8	23.6	15.4	6.8	(23)
(24)			MCWB	0.7	5.1	11.0	16.3	19.8	21.2	25.5	25.8	21.0	15.6	9.9	2.7	(24)
(25)		10%	DB	3.5	8.5	15.6	21.6	27.0	32.4	32.4	30.6	27.4	21.7	13.3	5.3	(25)
(26)			MCWB	-0.3	3.7	9.0	15.1	19.0	21.2	25.5	25.3	20.4	14.9	8.8	1.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	9.5	16.1	21.5	23.6	26.1	29.4	29.0	25.7	20.5	14.1	6.7	(27)
(28)			MCDWB	8.6	14.1	21.8	26.4	29.1	31.9	33.0	32.4	29.4	25.3	18.1	9.6	(28)
(29)		2%	WB	2.3	7.3	13.5	19.1	22.3	24.7	28.2	28.0	24.0	18.9	12.4	4.9	(29)
(30)			MCDWB	5.8	11.3	19.0	23.8	27.7	30.6	31.8	31.3	27.7	22.6	16.1	7.2	(30)
(31)		5%	WB	1.3	5.6	11.8	17.6	21.3	23.7	27.5	27.2	22.8	17.6	10.9	3.6	(31)
(32)			MCDWB	4.4	9.4	17.2	22.1	26.8	29.6	31.2	30.2	26.4	21.0	14.3	5.9	(32)
(33)		10%	WB	0.2	4.1	9.9	16.0	20.1	22.8	26.7	26.3	21.8	16.3	9.5	2.4	(33)
(34)			MCDWB	2.8	8.0	14.9	20.9	25.2	28.9	30.3	29.2	25.5	20.1	12.5	4.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.0	9.6	10.4	10.7	11.0	11.0	8.2	7.9	10.0	10.4	9.3	8.6	(35)
(36)			MCDBR	11.9	12.4	12.8	12.8	13.4	13.6	10.5	9.2	12.0	12.9	12.2	11.0	(36)
(37)			MCWBR	7.8	7.6	7.2	7.2	6.0	4.1	3.4	3.8	4.8	5.5	6.8	7.0	(37)
(38)		5% WB	MCDWR	10.3	11.2	12.0	11.6	11.1	10.5	8.0	7.8	9.2	10.0	10.3	9.2	(38)
(39)	MCWBR		7.0	7.3	7.4	7.5	6.4	4.2	3.7	3.8	4.3	5.2	6.4	6.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.524	0.595	0.606	0.639	0.670	0.811	0.789	0.762	0.693	0.683	0.586	0.527	(40)	
(41)		taud	1.739	1.634	1.625	1.596	1.582	1.394	1.477	1.508	1.578	1.553	1.674	1.762	(41)	
(42)		Ebn at Noon	599	612	664	677	666	577	585	586	593	534	537	560	(42)	
(43)		Edh at Noon	173	218	240	260	268	323	296	281	249	233	184	160	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.21	2.84	4.25	5.09	5.75	5.28	4.70	4.47	3.98	3.14	2.35	2.05	(44)	
(45)		RadStd	0.27	0.44	0.37	0.33	0.43	0.42	0.33	0.45	0.41	0.31	0.37	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page