

HUIMIN, China

WMO: 547250

Lat: 37.4916N

Lon: 117.5251E

Elev: 39

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.9	17.0	-8.5	3.5	24.7	-4.4	4.3	25.4	18.9	33.9	16.5	31.3	4.2	290	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	94.4	75.7	92.1	75.6	89.9	75.1	81.8	89.3	80.5	87.5	79.1	85.4	6.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.8	154.7	86.4	78.6	148.6	85.3	77.3	142.2	83.9	45.7	89.4	44.4	87.7	42.9	85.4	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.3	15.5	13.3	9.3	98.5	4.4	2.5	6.2	100.3	3.6	101.8	1.1	103.2	-2.0	105.1	
			DB												
			WB	7.3	84.0	4.0	1.3	4.4	85.0	2.1	85.7	-0.1	86.4	-3.0	87.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.0	28.8	34.9	46.4	58.5	69.1	77.5	81.3	78.7	70.8	59.2	44.6	32.5
	DBStd	19.24	5.82	7.01	8.08	7.43	6.08	5.09	4.14	4.35	5.27	6.77	7.75	5.94
	HDD50	2011	657	424	167	13	0	0	0	0	0	9	197	544
	HDD65	4626	1122	843	577	220	29	1	0	0	13	200	612	1009
	CDD50	4552	0	1	56	268	593	824	969	888	623	295	35	0
	CDD65	1692	0	0	2	25	157	375	504	423	186	20	0	0
	CDH74	16495	0	0	15	222	1405	3876	5580	3972	1294	130	1	0
	CDH80	6380	0	0	1	41	412	1690	2442	1453	330	11	0	0
Wind	WSAvg	6.0	5.6	6.5	7.8	7.9	7.0	6.1	5.3	4.8	4.8	5.5	5.7	5.5
Precipitation	PrecAvg	23.0	0.2	0.3	0.4	1.3	1.3	2.6	7.8	5.5	1.8	1.2	0.6	0.2
	PrecMax	39.9	0.9	1.2	1.3	4.6	3.8	7.7	18.9	10.4	4.7	5.3	1.7	0.9
	PrecMin	11.7	0.0	0.0	0.0	0.1	0.0	0.4	1.0	0.5	0.1	0.0	0.0	0.0
	PrecStd	7.6	0.2	0.3	0.4	1.1	1.0	1.7	4.4	2.8	1.4	1.1	0.5	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.7	59.9	75.3	84.6	91.9	97.4	97.8	94.0	89.0	81.7	69.8	52.2
		MCWB	37.9	45.7	57.2	65.7	69.0	70.7	76.5	80.8	73.6	63.4	54.3	41.9
	2%	DB	44.8	54.7	69.9	79.8	87.4	94.2	94.9	91.4	86.2	77.8	64.6	47.9
		MCWB	35.0	42.3	53.7	62.8	67.2	70.8	78.3	79.2	71.0	61.4	51.6	38.8
	5%	DB	41.4	51.0	65.2	76.0	84.4	91.8	92.5	89.2	83.8	74.4	60.5	44.6
		MCWB	32.7	40.3	50.6	60.5	66.1	70.7	78.0	77.9	69.3	60.1	49.7	37.2
	10%	DB	38.2	47.0	60.3	72.2	81.7	89.0	90.2	87.3	81.4	70.9	56.5	41.8
		MCWB	31.1	37.7	47.5	57.9	64.8	70.1	77.4	76.8	68.2	58.3	47.9	35.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.1	48.3	59.6	69.5	72.8	78.5	83.7	83.4	78.4	67.6	57.1	44.6
		MCDB	47.3	57.9	73.0	80.1	83.6	88.5	91.0	90.7	84.9	75.9	63.4	49.0
	2%	WB	36.2	44.0	54.8	65.2	70.8	75.9	82.2	81.7	74.8	65.2	54.1	41.2
		MCDB	42.6	52.8	66.3	76.6	83.5	86.3	90.4	88.6	80.8	72.3	60.6	44.8
	5%	WB	34.0	41.0	51.8	62.4	69.0	74.1	81.0	80.5	72.8	63.1	51.6	38.6
		MCDB	39.6	48.8	63.4	73.5	81.2	85.2	88.7	86.6	79.4	69.7	58.8	43.0
	10%	WB	32.1	38.3	48.4	59.7	66.9	72.5	79.8	79.1	70.8	60.8	48.9	36.3
		MCDB	37.0	45.9	59.0	69.8	77.9	83.4	86.8	84.7	77.7	68.4	55.4	41.0
Mean Daily Temperature Range	5% DB	MDBR	16.0	17.0	18.4	19.0	19.1	18.4	14.4	13.8	17.3	18.5	16.5	15.2
		MCDBR	20.4	22.0	23.1	23.2	22.8	22.1	17.8	15.8	20.0	22.1	21.2	19.2
		MCWBR	12.9	13.2	12.3	11.8	9.9	7.3	6.2	6.1	7.4	9.1	11.5	12.2
	5% WB	MCDBR	17.8	20.4	22.2	21.8	19.8	17.9	14.2	13.5	15.7	17.5	18.9	16.2
		MCWBR	12.0	13.1	12.8	12.2	10.8	7.4	6.2	6.3	7.4	8.6	11.2	11.6
Clear-Sky Solar Irradiance	taub	0.516	0.585	0.603	0.637	0.668	0.801	0.783	0.740	0.670	0.673	0.579	0.524	
	taud	1.749	1.652	1.628	1.605	1.587	1.411	1.485	1.545	1.616	1.565	1.682	1.768	
	Ebn at Noon	192	197	211	215	212	185	187	190	193	171	171	178	
	Edh at Noon	54	68	76	82	85	101	93	86	76	73	58	50	
All-Sky Solar Radiation	RadAvg	711	927	1357	1617	1839	1695	1515	1452	1297	1012	753	653	
	RadStd	80	119	101	76	132	127	119	136	126	95	108	68	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+155	N/A

Nomenclature: See separate page