

HUIMIN, China

WMO: 547250

Lat: 37.4916N

Lon: 117.5251E

Elev: 12

StdP: 101.18

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.1	-8.3	-22.5	0.5	-4.1	-20.2	0.6	-3.7	8.4	1.0	7.4	-0.4	1.9	290	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	34.7	24.3	33.4	24.2	32.2	23.9	27.7	31.9	27.0	30.8	26.2	29.6	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.1	30.2	25.9	21.2	29.6	25.2	20.3	28.8	88.5	31.9	85.4	30.9	81.9	29.7	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	6.9	6.0	-12.6	36.9	2.4	1.4	-14.4	38.0	-15.8	38.8	-17.1	39.6	-18.9	40.6		
(5)			-13.7	28.9	2.2	0.7	-15.3	29.4	-16.6	29.8	-17.8	30.2	-19.4	30.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	-1.8	1.6	8.0	14.7	20.6	25.3	27.4	25.9	21.5	15.1	7.0	0.3		
	DBStd	10.69	3.23	3.89	4.49	4.13	3.38	2.83	2.30	2.41	2.93	3.76	4.30	3.30		
	HDD10.0	1117	365	236	93	7	0	0	0	0	5	109	302			
	HDD18.3	2570	623	468	321	122	16	1	0	0	7	111	340	561		
	CDD10.0	2529	0	1	31	149	329	458	538	493	346	164	19	0		
	CDD18.3	940	0	0	1	14	87	208	280	235	103	11	0	0		
	CDH23.3	9164	0	0	8	123	781	2153	3100	2207	719	72	1	0		
	CDH26.7	3544	0	0	1	23	229	939	1357	807	183	6	0	0		
(14) Wind	WSAvg	2.7	2.5	2.9	3.5	3.5	3.1	2.7	2.4	2.1	2.2	2.4	2.6	2.4		
(15) Precipitation	PrecAvg	585	4	7	9	32	33	66	199	139	46	30	14	5		
	PrecMax	1013	22	31	33	118	96	196	480	264	120	135	44	22		
	PrecMin	298	0	0	0	2	0	10	26	12	3	1	0	0		
	PrecStd	193	5	8	9	28	25	42	112	71	35	29	13	6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	15.5	24.1	29.2	33.3	36.3	36.6	34.4	31.7	27.6	21.0	11.2		
		MCWB	3.3	7.6	14.0	18.7	20.6	21.5	24.7	27.1	23.1	17.4	12.4	5.5		
	2%	DB	7.1	12.6	21.1	26.5	30.8	34.6	34.9	33.0	30.1	25.4	18.1	8.8		
		MCWB	1.7	5.7	12.1	17.1	19.6	21.6	25.7	26.2	21.6	16.3	10.9	3.8		
	5%	DB	5.2	10.6	18.4	24.4	29.1	33.2	33.6	31.8	28.8	23.6	15.8	7.0		
		MCWB	0.4	4.6	10.3	15.8	18.9	21.5	25.5	25.5	20.7	15.6	9.8	2.9		
	10%	DB	3.4	8.3	15.7	22.3	27.6	31.7	32.3	30.7	27.4	21.6	13.6	5.4		
		MCWB	-0.5	3.1	8.6	14.4	18.2	21.2	25.2	24.9	20.1	14.6	8.8	2.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.9	9.1	15.3	20.8	22.7	25.8	28.7	28.5	25.8	19.8	14.0	7.0		
		MCDB	8.5	14.4	22.8	26.7	28.6	31.4	32.8	32.6	29.4	24.4	17.4	9.4		
	2%	WB	2.3	6.7	12.7	18.4	21.6	24.4	27.9	27.6	23.8	18.4	12.3	5.1		
		MCDB	5.9	11.6	19.1	24.8	28.6	30.2	32.4	31.4	27.1	22.4	15.9	7.1		
	5%	WB	1.1	5.0	11.0	16.9	20.5	23.4	27.2	26.9	22.7	17.3	10.9	3.7		
		MCDB	4.2	9.3	17.5	23.0	27.3	29.5	31.5	30.3	26.3	21.0	14.9	6.1		
	10%	WB	0.0	3.5	9.1	15.4	19.4	22.5	26.6	26.2	21.6	16.0	9.4	2.4		
		MCDB	2.8	7.7	15.0	21.0	25.5	28.6	30.4	29.3	25.4	20.2	13.0	5.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.4	10.2	10.5	10.6	10.2	8.0	7.7	9.6	10.3	9.2	8.5		
		MCDBR	11.3	12.2	12.9	12.9	12.7	12.3	9.9	8.8	11.1	12.3	11.8	10.7		
	5% WB	MCWBR	7.2	7.3	6.8	6.5	5.5	4.0	3.4	3.4	4.1	5.0	6.4	6.8		
		MCWBR	9.9	11.4	12.3	12.1	11.0	10.0	7.9	7.5	8.7	9.7	10.5	9.0		
(40) Clear-Sky Solar Irradiance	taub		0.516	0.585	0.603	0.637	0.668	0.801	0.783	0.740	0.670	0.673	0.579	0.524		
		taud	1.749	1.652	1.628	1.605	1.587	1.411	1.485	1.545	1.616	1.565	1.682	1.768		
	Ebn at Noon		605	620	666	678	668	583	589	600	609	540	540	561		
		Edh at Noon	171	213	239	258	267	318	293	271	239	230	182	158		
(44) All-Sky Solar Radiation	RadAvg		2.24	2.92	4.28	5.10	5.80	5.34	4.78	4.58	4.09	3.19	2.37	2.06		
	RadStd		0.25	0.37	0.32	0.24	0.42	0.40	0.38	0.43	0.40	0.30	0.34	0.21		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+86	N/A

Nomenclature: See separate page