

XINXIAN, China

WMO: 548080

Lat: 36.233N

Lon: 115.667E

Elev: 125

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.3	18.6	-5.7	4.1	29.7	-1.3	5.2	28.2	17.6	37.3	15.6	34.2	3.1	0	0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	95.2	75.8	92.8	76.3	90.6	76.0	82.9	89.5	81.5	87.9	80.1	86.3	6.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.2	162.7	87.3	79.7	155.1	86.0	78.3	147.6	84.5	47.2	89.6	45.5	88.1	44.0	86.2	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	14.1	12.2	8.9	99.9	4.8	2.9	5.4	102.0	2.6	103.7	-0.2	105.3	-3.7	107.4
			7.8	84.8	4.4	1.4	4.6	85.8	2.0	86.6	-0.5	87.4	-3.7	88.5
									</					

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	30.5	36.9	48.3	59.1	69.2	78.7	81.6	78.8	70.7	60.3	45.6	34.0	
	DBStd	18.69	5.64	6.79	7.59	6.95	5.67	4.88	4.20	4.66	5.35	6.57	7.64	5.72	
	HDD50	1783	606	368	123	10	0	0	0	0	0	6	173	497	
	HDD65	4332	1071	787	519	199	26	0	0	0	14	172	582	962	
	CDD50	4674	0	1	71	283	596	862	980	894	622	325	40	0	
	CDD65	1749	0	0	1	22	157	413	515	429	186	26	0	0	
	CDH74	17252	0	0	14	188	1341	4444	5733	4073	1274	183	2	0	
	CDH80	6911	0	0	1	30	388	2072	2526	1541	329	24	0	0	
Wind	WSAvg	5.6	5.3	6.2	7.2	6.9	6.1	5.8	4.9	4.6	4.5	4.9	5.3	5.2	
Precipitation	PrecAvg	20.8	0.1	0.4	0.6	1.0	1.9	2.4	5.4	5.0	2.0	1.1	0.7	0.2	
	PrecMax	30.9	0.9	1.5	2.2	3.8	5.4	4.5	11.3	11.6	6.4	6.3	3.1	0.7	
	PrecMin	10.8	0.0	0.0	0.0	0.2	0.0	0.2	1.3	0.5	0.1	0.0	0.0	0.0	
	PrecStd	5.4	0.2	0.4	0.7	0.8	1.3	1.1	2.5	2.7	1.7	1.4	0.8	0.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	61.1	75.5	84.1	92.2	99.0	97.6	95.0	89.6	82.9	70.8	54.2	
		MCWB	40.0	47.3	58.8	67.8	69.5	71.1	77.4	82.6	74.1	63.4	56.1	42.2	
	2%	DB	46.8	56.5	70.3	78.9	87.4	95.7	95.0	91.8	86.3	78.9	65.3	49.4	
		MCWB	37.0	45.1	55.0	64.0	68.9	71.3	79.0	80.7	71.5	62.4	52.8	40.2	
	5%	DB	43.1	52.9	65.8	75.6	84.2	93.0	92.7	89.6	83.9	75.2	61.2	46.0	
		MCWB	34.6	42.5	52.4	62.0	68.0	71.4	78.9	78.8	70.3	60.6	50.5	38.4	
	10%	DB	40.0	49.2	61.4	72.0	81.3	90.3	90.5	87.5	81.2	71.7	57.3	43.3	
		MCWB	32.9	40.3	49.5	59.7	66.6	71.1	78.6	77.9	69.2	59.4	48.6	37.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.1	50.6	61.8	70.6	75.1	80.2	84.9	84.5	79.6	68.6	57.8	45.2
			MCDB	49.6	58.9	71.9	80.6	84.9	89.0	90.6	91.0	85.1	77.2	66.6	49.5
2%		WB	38.2	46.5	57.2	66.3	72.6	77.6	83.3	82.9	75.6	65.9	54.9	42.4	
		MCDB	45.1	53.7	67.0	75.8	82.2	87.5	90.2	89.2	81.2	72.7	62.4	46.7	
5%		WB	35.8	43.9	54.0	63.9	70.7	75.7	81.9	81.4	73.3	63.6	52.4	40.1	
		MCDB	41.7	51.2	64.2	72.8	80.1	85.7	88.7	87.4	80.2	70.4	58.6	44.6	
10%		WB	33.7	41.1	50.8	61.6	68.8	74.0	80.7	80.0	71.4	61.5	50.0	37.8	
		MCDB	38.6	48.3	60.1	70.0	78.2	84.5	87.4	85.4	78.2	68.5	56.2	42.4	
Mean Daily Temperature Range	5% DB	MDBR	15.8	16.8	18.3	19.0	19.3	19.0	14.2	13.9	17.2	18.3	16.7	15.3	
		MCDBR	21.5	22.3	23.7	23.0	24.1	23.9	17.8	15.9	20.6	23.3	22.1	20.2	
		MCWBR	13.7	13.3	12.5	11.8	10.5	7.4	6.0	6.3	8.1	9.6	11.8	12.6	
	5% WB	MCDBR	18.6	19.9	21.7	20.5	19.6	17.9	14.4	13.6	16.0	17.9	18.3	16.7	
		MCWBR	12.5	12.9	12.5	12.2	11.0	7.6	6.6	6.6	7.9	8.7	10.8	11.3	
Clear-Sky Solar Irradiance	taub	0.545	0.622	0.624	0.647	0.670	0.812	0.786	0.765	0.710	0.702	0.611	0.543		
	taud	1.709	1.588	1.607	1.591	1.594	1.404	1.490	1.511	1.562	1.533	1.639	1.733		
	Ebn at Noon	187	190	208	214	212	184	187	186	186	168	167	177		
	Edh at Noon	58	73	78	83	84	102	93	89	81	76	62	53		
All-Sky Solar Radiation	RadAvg	705	888	1326	1576	1767	1669	1479	1401	1232	991	754	659		
	RadStd	90	145	116	113	132	126	113	167	142	112	120	85		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.94	N/A	N/A	+1.06	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page