

XINXIAN, China

WMO: 548080

Lat: 36.233N

Lon: 115.667E

Elev: 38

StdP: 100.87

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.3	-7.5	-21.0	0.6	-1.3	-18.5	0.7	-2.1	7.9	3.0	7.0	1.2	1.4	0	0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	35.1	24.3	33.8	24.6	32.5	24.4	28.3	32.0	27.5	31.1	26.7	30.1	3.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.3	23.2	30.7	26.5	22.2	30.0	25.7	21.1	29.2	91.9	32.0	88.0	31.2	84.4	30.1	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	7.3	6.3	5.5	DB	-12.9	37.7	2.7	1.6	-14.8	38.9	-16.4	39.8	-17.9	40.7	-19.8	41.9
(5)				WB	-13.5	29.3	2.5	0.8	-15.2	29.9	-16.7	30.4	-18.0	30.8	-19.8	31.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	-0.9	2.7	9.1	15.1	20.7	26.0	27.6	26.0	21.5	15.7	7.6	1.1	(6)
(7)		DBStd	10.38	3.13	3.77	4.22	3.86	3.15	2.71	2.33	2.59	2.97	3.65	4.24	3.18	(7)
(8)		HDD10.0	991	337	204	68	6	0	0	0	0	3	96	276	(8)	
(9)		HDD18.3	2407	595	437	288	111	14	0	0	8	96	323	534	(9)	
(10)		CDD10.0	2597	0	1	39	157	331	479	544	497	346	181	22	0	(10)
(11)		CDD18.3	972	0	0	1	12	87	229	286	238	103	14	0	0	(11)
(12)		CDH23.3	9584	0	0	8	104	745	2469	3185	2263	708	102	1	0	(12)
(13)		CDH26.7	3839	0	0	1	17	216	1151	1403	856	183	13	0	0	(13)
(14)	Wind	WSAvg	2.5	2.4	2.8	3.2	3.1	2.7	2.6	2.2	2.0	2.2	2.4	2.3	(14)	
(15)	Precipitation	PrecAvg	529	3	10	15	26	47	60	138	126	52	29	19	5	(15)
(16)		PrecMax	784	24	38	57	96	137	114	286	295	163	160	79	18	(16)
(17)		PrecMin	275	0	0	0	6	1	5	33	13	2	0	0	0	(17)
(18)		PrecStd	138	6	9	17	20	32	29	64	68	42	35	20	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	16.2	24.1	29.0	33.4	37.2	36.5	35.0	32.0	28.3	21.5	12.3	(19)
(20)			MCWB	4.4	8.5	14.9	19.9	20.8	21.7	25.2	28.1	23.4	17.4	13.4	5.7	(20)
(21)		2%	DB	8.2	13.6	21.3	26.0	30.8	35.4	35.0	33.2	30.2	26.1	18.5	9.7	(21)
(22)			MCWB	2.8	7.3	12.8	17.8	20.5	21.8	26.1	27.0	21.9	16.9	11.6	4.6	(22)
(23)		5%	DB	6.2	11.6	18.8	24.2	29.0	33.9	33.7	32.0	28.8	24.0	16.2	7.8	(23)
(24)			MCWB	1.5	5.8	11.3	16.7	20.0	21.9	26.1	26.0	21.3	15.9	10.3	3.5	(24)
(25)		10%	DB	4.4	9.5	16.3	22.2	27.4	32.4	32.5	30.8	27.4	22.1	14.1	6.3	(25)
(26)			MCWB	0.5	4.6	9.7	15.4	19.2	21.7	25.9	25.5	20.7	15.2	9.2	2.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	10.3	16.5	21.5	24.0	26.8	29.4	29.2	26.4	20.4	14.3	7.3	(27)
(28)			MCDWB	9.8	14.9	22.2	27.0	29.4	31.7	32.6	32.8	29.5	25.1	19.2	9.7	(28)
(29)		2%	WB	3.4	8.1	14.0	19.1	22.5	25.3	28.5	28.3	24.2	18.8	12.7	5.8	(29)
(30)			MCDWB	7.3	12.1	19.4	24.3	27.9	30.8	32.3	31.8	27.4	22.6	16.9	8.2	(30)
(31)		5%	WB	2.1	6.6	12.2	17.7	21.5	24.3	27.7	27.5	23.0	17.5	11.3	4.5	(31)
(32)			MCDWB	5.4	10.7	17.9	22.6	26.7	29.8	31.5	30.8	26.8	21.4	14.8	7.0	(32)
(33)		10%	WB	0.9	5.0	10.4	16.4	20.4	23.3	27.0	26.7	21.9	16.4	10.0	3.2	(33)
(34)			MCDWB	3.7	9.1	15.6	21.1	25.6	29.2	30.8	29.7	25.7	20.3	13.5	5.8	(34)
(35)	Mean Daily Temperature Range	MDBR	8.8	9.3	10.2	10.6	10.7	10.6	7.9	7.7	9.5	10.2	9.3	8.5	(35)	
(36)		5% DB	MCDBR	11.9	12.4	13.1	12.8	13.4	13.3	9.9	8.9	11.5	13.0	12.3	11.2	(36)
(37)			MCWBR	7.6	7.4	6.9	6.6	5.8	4.1	3.3	3.5	4.5	5.4	6.6	7.0	(37)
(38)			5% WB	MCDBR	10.4	11.1	12.1	11.4	10.9	9.9	8.0	7.5	8.9	9.9	10.1	9.3
(39)		MCWBR		6.9	7.2	6.9	6.8	6.1	4.2	3.7	3.6	4.4	4.8	6.0	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.545	0.622	0.624	0.647	0.670	0.812	0.786	0.765	0.710	0.702	0.611	0.543	(40)	
(41)		taud	1.709	1.588	1.607	1.591	1.594	1.404	1.490	1.511	1.562	1.533	1.639	1.733	(41)	
(42)		Ebn at Noon	591	598	656	674	669	579	590	587	587	529	527	557	(42)	
(43)		Edh at Noon	182	231	246	263	266	321	293	282	255	241	195	168	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.22	2.80	4.18	4.97	5.57	5.26	4.66	4.42	3.88	3.12	2.38	2.08	(44)	
(45)		RadStd	0.28	0.46	0.37	0.36	0.42	0.40	0.36	0.53	0.45	0.35	0.38	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.52	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page