

TAI SHAN, China

WMO: 548260

Lat: 36.2556N

Lon: 117.1056E

Elev: 1536

StdP: 84.18

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.7	-14.6	-33.6	0.2	-9.5	-30.5	0.3	-9.5	19.3	-10.1	17.9	-6.9	9.8	0	0.752

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.6	22.9	17.5	21.9	17.6	21.1	17.9	21.1	21.4	20.4	20.8	19.7	20.2	3.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.9	21.2	20.3	18.1	20.6	19.6	17.3	20.0	69.6	21.4	67.0	20.8	64.1	20.4	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	17.5	15.5	13.9	DB	-20.0	25.1	2.5	1.3	-21.9	26.1	-23.3	26.8	-24.7	27.6	-26.6	28.6
(5)				WB	-20.8	22.0	2.5	0.8	-22.5	22.6	-24.0	23.0	-25.3	23.5	-27.1	24.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-7.2	-5.0	0.4	6.7	12.3	16.3	18.5	17.4	13.4	7.9	1.0	-5.4
	DBStd	9.76	4.39	4.38	4.80	4.48	3.34	2.58	2.00	2.31	3.00	3.75	4.60	4.48
	HDD10.0	2224	532	419	300	116	16	1	0	0	7	85	272	477
	HDD18.3	4399	790	653	557	349	188	67	22	43	150	324	521	735
	CDD10.0	919	0	0	1	17	87	191	264	230	109	19	1	0
	CDD18.3	53	0	0	0	0	1	8	28	15	1	0	0	0
	CDH23.3	23	0	0	0	1	1	7	12	2	1	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	6.5	7.2	6.7	7.1	7.4	7.0	5.7	5.2	5.2	5.4	6.1	7.2	7.5
Precipitation	PrecAvg	1086	14	17	27	49	67	124	329	228	118	64	28	13
	PrecMax	1848	56	71	67	143	188	356	666	544	272	283	114	63
	PrecMin	554	0	0	5	2	7	9	102	35	6	2	0	0
	PrecStd	310	15	17	16	37	49	89	134	126	71	62	25	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	8.3	13.4	19.1	21.7	24.2	24.7	23.5	21.5	17.5	12.4	5.8
		MCWB	1.1	4.2	6.8	11.7	12.9	15.9	16.7	19.5	14.9	10.5	5.7	-0.8
	2%	DB	2.3	4.9	10.9	16.2	19.7	22.3	23.1	22.1	19.7	15.4	10.0	3.9
		MCWB	-2.2	0.6	5.6	10.9	11.8	15.1	18.0	19.1	15.7	9.7	5.2	-1.2
	5%	DB	0.4	2.5	8.8	14.4	18.3	21.2	22.0	21.2	18.4	14.1	8.7	2.2
		MCWB	-3.8	-1.1	3.7	9.5	11.4	14.9	18.8	19.1	14.3	8.9	3.9	-2.0
	10%	DB	-1.4	0.9	7.1	12.8	17.1	20.2	21.2	20.4	17.4	12.7	7.0	0.7
		MCWB	-4.8	-2.4	2.5	8.2	11.1	14.6	18.9	18.6	13.6	8.5	2.8	-3.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.6	4.8	10.2	15.2	16.2	19.8	22.0	21.9	19.6	14.3	8.9	2.8
		MCDB	3.2	5.7	11.4	15.6	17.2	20.5	22.2	22.4	19.8	14.8	10.3	3.3
	2%	WB	-1.5	1.4	6.7	12.6	14.9	18.6	21.3	21.0	17.4	12.2	7.0	0.0
		MCDB	1.1	3.9	9.2	14.8	16.7	19.8	21.5	21.3	18.2	13.3	8.4	1.9
	5%	WB	-3.3	-0.4	4.9	10.9	13.9	17.5	20.7	20.2	16.1	10.7	5.2	-1.5
		MCDB	0.0	1.8	7.5	13.5	16.3	19.1	21.1	20.6	17.2	12.5	7.5	1.1
	10%	WB	-4.8	-1.9	3.3	9.2	12.8	16.5	20.1	19.5	14.9	9.6	3.5	-2.7
		MCDB	-1.8	0.6	6.4	11.8	15.6	18.4	20.5	19.9	16.3	11.6	6.1	0.3
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.1	5.8	6.0	5.7	5.2	3.6	3.6	4.5	4.9	4.9	4.8
		MCDBR	5.8	6.3	6.9	7.0	6.3	6.4	4.6	4.3	5.1	5.5	5.4	5.5
		MCWBR	4.4	5.1	5.5	5.5	5.2	4.7	4.5	4.5	5.0	4.7	4.5	4.2
	5% WB	MCDBR	5.6	5.9	6.8	6.5	5.5	4.9	3.2	3.4	4.3	4.7	5.3	5.0
		MCWBR	4.9	5.4	6.1	5.8	5.4	4.7	3.5	3.5	5.0	4.6	5.5	4.9
Clear-Sky Solar Irradiance	taub	0.378	0.429	0.442	0.459	0.474	0.567	0.551	0.526	0.479	0.481	0.425	0.381	
	taud	2.035	1.930	1.933	1.940	1.947	1.753	1.857	1.904	1.966	1.873	1.949	2.034	
	Ebn at Noon	777	781	816	827	819	742	751	760	772	716	713	742	
	Edh at Noon	129	162	176	185	186	226	203	190	169	169	140	121	
All-Sky Solar Radiation	RadAvg	2.33	2.92	4.25	5.04	5.63	5.24	4.65	4.44	3.96	3.22	2.45	2.15	
	RadStd	0.27	0.43	0.36	0.30	0.40	0.43	0.39	0.50	0.41	0.34	0.36	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	+1.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+102	+59

Nomenclature: See separate page