

YANZHOU, China

WMO: 549160

Lat: 35.5630N

Lon: 116.8424E

Elev: 53

StdP: 100.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.1	-7.4	-20.3	0.6	-0.3	-17.8	0.8	-1.3	7.0	3.3	6.2	2.1	1.3	90	0.401

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	34.7	24.8	33.5	24.9	32.3	24.6	28.4	31.9	27.6	31.2	26.8	30.2	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.5	23.5	30.7	26.6	22.3	30.1	25.8	21.3	29.2	92.3	31.9	88.6	31.4	85.0	30.3	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.5	5.6	4.9	-11.9	36.9	1.5	1.3	-12.9	37.8	-13.8	38.6	-14.7	39.3	-15.7	40.2		
			-12.6	29.4	1.5	0.8	-13.7	30.0	-14.6	30.4	-15.4	30.8	-16.5	31.4		

Monthly Climatic Design Conditions

			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.6	-0.2	3.0	9.0	15.2	20.5	25.4	27.6	26.3	21.7	15.7	8.0	1.6	(6)
(7)		DBStd	10.13	2.99	3.59	4.06	3.84	3.01	2.53	2.23	2.43	2.87	3.43	4.00	3.13	(7)
(8)		HDD10.0	930	315	196	69	4	0	0	0	0	0	2	83	260	(8)
(9)		HDD18.3	2341	573	429	291	108	13	0	0	5	94	309	518	(9)	
(10)		CDD10.0	2591	0	1	37	159	327	463	544	504	352	179	24	0	(10)
(11)		CDD18.3	961	0	0	1	13	81	213	286	246	107	13	0	0	(11)
(12)		CDH23.3	9580	0	0	6	123	766	2257	3172	2382	784	90	1	0	(12)
(13)		CDH26.7	3746	0	0	1	22	221	994	1372	908	218	9	0	0	(13)
(14)	Wind	WSAvg	2.2	2.0	2.3	2.7	2.8	2.5	2.4	2.1	1.9	1.8	1.8	2.0	2.0	(14)
(15)	Precipitation	PrecAvg	689	9	9	19	38	43	83	220	138	75	35	16	9	(15)
(16)		PrecMax	1179	40	38	60	165	137	216	404	366	184	153	99	50	(16)
(17)		PrecMin	406	0	0	0	1	0	4	79	6	3	0	0	0	(17)
(18)		PrecStd	180	11	11	15	38	37	56	98	83	48	32	19	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	16.5	23.9	29.2	33.4	36.3	36.2	34.7	32.6	28.0	21.6	12.8	(19)
(20)			MCWB	4.8	9.8	15.4	20.4	20.7	22.1	26.0	28.1	23.4	17.8	14.3	8.5	(20)
(21)		2%	DB	8.7	13.8	21.3	26.5	30.8	34.6	34.7	33.2	30.6	25.8	18.6	10.5	(21)
(22)			MCWB	3.8	7.4	13.0	18.2	20.3	22.0	26.3	27.2	22.5	17.4	12.3	6.7	(22)
(23)		5%	DB	7.0	11.8	18.8	24.4	29.1	33.2	33.6	32.1	29.1	24.1	16.7	8.8	(23)
(24)			MCWB	2.7	6.0	11.7	17.0	19.6	21.8	26.5	26.2	21.4	16.5	11.3	5.1	(24)
(25)		10%	DB	5.4	9.8	16.5	22.4	27.5	31.9	32.4	31.0	27.7	22.2	14.7	7.2	(25)
(26)			MCWB	1.7	5.0	10.0	15.6	19.0	21.7	26.2	25.6	20.6	15.9	10.4	4.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	11.2	16.7	22.2	23.3	26.7	29.5	29.5	26.5	20.7	15.6	9.7	(27)
(28)			MCDWB	9.0	15.0	21.9	27.4	28.3	31.4	32.8	32.8	29.8	23.6	19.1	11.4	(28)
(29)		2%	WB	4.7	8.6	14.3	19.8	22.2	25.5	28.6	28.4	24.5	19.2	14.0	7.6	(29)
(30)			MCDWB	7.4	12.5	19.5	24.6	27.7	30.3	32.3	31.7	28.1	23.4	17.0	9.6	(30)
(31)		5%	WB	3.3	6.9	12.4	18.1	21.1	24.5	27.8	27.6	23.3	18.1	12.6	6.0	(31)
(32)			MCDWB	6.4	10.4	17.7	22.8	27.0	29.5	31.7	30.8	26.8	22.0	15.5	8.2	(32)
(33)		10%	WB	2.1	5.5	10.7	16.6	20.1	23.5	27.1	26.8	22.3	16.9	10.9	4.5	(33)
(34)			MCDWB	4.7	9.1	15.6	21.3	25.7	28.6	31.0	29.8	25.7	20.6	14.1	6.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.4	10.0	10.7	11.0	11.3	10.6	7.8	7.9	9.9	10.7	10.1	9.3	(35)
(36)			MCDBR	12.3	13.1	13.7	13.2	13.8	13.2	9.6	8.8	11.8	13.3	12.8	12.0	(36)
(37)			MCWBR	7.9	7.8	7.2	6.6	5.6	4.1	3.2	3.5	4.3	5.6	6.9	7.8	(37)
(38)		5% WB	MCDWB	10.6	11.0	12.6	12.1	11.4	9.6	8.0	7.5	9.4	9.9	10.3	9.8	(38)
(39)	MCWBR		7.2	7.2	7.2	7.0	5.7	3.9	3.5	3.5	4.4	4.9	6.5	7.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.543	0.618	0.631	0.646	0.663	0.797	0.767	0.738	0.680	0.685	0.616	0.550	(40)	
(41)		taud	1.710	1.604	1.602	1.607	1.614	1.430	1.527	1.566	1.625	1.561	1.633	1.727	(41)	
(42)		Ebn at Noon	599	607	654	677	675	588	602	607	611	546	530	559	(42)	
(43)		Edh at Noon	184	229	249	259	261	313	283	267	240	236	198	172	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.29	2.83	4.16	4.95	5.47	5.21	4.67	4.44	3.91	3.20	2.43	2.12	(44)	
(45)		RadStd	0.27	0.42	0.34	0.34	0.39	0.44	0.43	0.54	0.43	0.33	0.34	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page