

FEIXIAN, China

WMO: 549290

Lat: 35.2607N

Lon: 117.9612E

Elev: 120

StdP: 99.89

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.0	-6.3	-21.0	0.6	-2.7	-18.7	0.7	-2.0	6.7	-1.3	5.8	-0.4	1.2	290	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	34.2	24.4	33.1	23.9	31.8	23.8	27.5	31.7	26.8	30.8	26.2	29.7	2.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.2	30.1	25.7	21.3	29.5	25.1	20.5	28.8	88.4	32.0	85.4	30.8	82.4	30.0	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.9	5.0	4.3	-10.6	36.8	2.1	1.5	-12.1	37.8	-13.3	38.7	-14.5	39.6	-16.0	40.7		
(5)			-11.9	28.5	2.0	0.7	-13.3	29.0	-14.5	29.4	-15.6	29.8	-17.1	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	0.2	3.0	9.1	15.7	21.0	25.0	27.3	26.3	22.2	16.3	8.7	2.1
	DBStd	9.98	3.10	3.55	4.13	3.82	3.25	2.69	2.34	2.46	2.66	3.21	3.96	3.29
	HDD10.0	882	302	196	67	3	0	0	0	0	0	1	69	244
	HDD18.3	2255	561	428	288	97	11	1	0	0	3	78	288	502
	CDD10.0	2639	0	1	38	173	342	449	535	506	366	197	31	1
	CDD18.3	972	0	0	1	17	96	200	277	248	119	16	0	0
	CDH23.3	8970	0	0	9	164	849	1874	2891	2349	754	78	1	0
	CDH26.7	3247	0	0	1	36	272	761	1164	825	179	8	0	0
Wind	WSAvg	1.8	1.7	1.9	2.3	2.4	2.2	2.0	1.8	1.7	1.5	1.5	1.6	1.7
Precipitation	PrecAvg	821	10	19	21	35	70	107	212	205	66	32	29	14
	PrecMax	1182	53	61	83	88	175	260	446	406	257	90	117	42
	PrecMin	414	0	1	0	6	3	12	53	47	1	0	0	0
	PrecStd	166	13	13	20	20	41	65	94	98	51	29	32	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	15.9	24.3	30.2	34.0	35.7	36.0	34.8	32.1	27.5	22.0	13.6
		MCWB	5.0	9.3	14.1	18.7	18.8	22.2	25.4	26.8	22.4	17.7	13.6	8.3
	2%	DB	8.7	13.2	21.5	27.2	31.5	33.8	34.4	33.2	29.9	25.4	18.9	11.1
		MCWB	3.7	6.7	12.3	16.9	18.8	20.8	26.1	26.3	21.6	16.7	11.9	6.9
	5%	DB	7.0	11.2	18.9	25.0	29.5	32.5	33.2	31.8	28.6	23.6	16.8	9.1
		MCWB	2.8	5.8	11.1	15.6	18.4	21.2	26.0	25.5	20.8	16.2	11.3	5.2
	10%	DB	5.5	9.4	16.5	22.9	27.8	31.0	31.7	30.6	27.4	22.0	15.1	7.5
		MCWB	2.1	4.9	9.3	14.5	17.7	21.1	25.5	24.7	20.1	15.6	10.6	4.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	10.6	15.7	20.8	22.6	26.2	28.4	28.2	25.7	20.4	15.7	10.5
		MCDB	10.0	14.2	22.2	27.7	27.0	31.2	33.0	32.2	28.9	23.0	18.4	11.9
	2%	WB	5.1	8.3	13.7	18.7	21.2	25.0	27.7	27.4	23.7	19.1	14.1	7.5
		MCDB	7.1	11.8	19.8	24.8	27.2	29.7	32.1	31.3	27.0	22.1	17.1	9.7
	5%	WB	3.6	6.6	11.9	17.2	20.1	23.9	27.1	26.8	22.7	17.9	12.6	6.1
		MCDB	6.4	10.0	17.4	22.9	26.8	28.5	31.4	30.4	26.1	21.8	15.8	8.2
	10%	WB	2.3	5.3	10.2	15.6	19.2	22.9	26.4	26.2	21.8	16.9	11.0	4.7
		MCDB	5.0	8.8	15.5	21.4	25.5	27.9	30.4	29.4	25.4	20.8	14.7	7.2
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.5	9.9	10.4	10.1	9.1	7.0	6.9	8.3	9.4	9.1	8.3
		MCDBR	10.8	11.6	13.5	13.4	12.9	11.8	8.9	8.1	10.1	11.7	11.8	10.9
		MCWBR	6.8	6.9	6.6	6.1	4.5	3.8	2.9	2.8	3.2	4.6	6.1	6.8
	5% WB	MCDBR	9.3	10.0	12.6	11.8	10.6	8.9	7.6	7.1	7.5	8.7	9.4	8.8
		MCWBR	6.4	6.6	6.9	6.4	4.9	3.8	3.2	3.1	3.3	4.3	5.9	6.3
Clear-Sky Solar Irradiance	taub	0.532	0.604	0.630	0.641	0.656	0.780	0.745	0.705	0.645	0.658	0.603	0.539	
	taud	1.720	1.619	1.596	1.615	1.623	1.448	1.560	1.621	1.683	1.594	1.643	1.730	
	Ebn at Noon	613	621	656	682	680	599	616	630	639	568	543	572	
	Edh at Noon	183	226	251	258	259	308	274	253	227	229	197	172	
All-Sky Solar Radiation	RadAvg	2.37	2.89	4.19	4.99	5.46	5.12	4.58	4.44	3.97	3.31	2.50	2.19	
	RadStd	0.28	0.40	0.34	0.33	0.40	0.45	0.46	0.54	0.40	0.35	0.33	0.22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.62	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page