

LINYI, China

WMO: 549380

Lat: 35.050N

Lon: 118.350E

Elev: 282

StdP: 14.55

Time Zone: 8.00 (E08)

Period: 90-97

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 20.1	(c) 22.7	(d) -5.4	(e) 4.2	(f) 30.4	(g) -0.5	(h) 5.4	(i) 32.7	(j) 20.7	(k) 30.9	(l) 16.8	(m) 33.5	(n) 5.9	(o) 40	(p) 0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	92.8	76.7	90.4	76.0	88.2	75.8	81.7	88.4	80.6	87.0	79.4	85.0	8.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.0	157.1	85.7	78.9	151.4	84.4	77.8	146.0	83.3	45.9	88.2	44.6	87.5	43.4	85.0	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 18.0	(b) 15.6	(c) 13.6	(e) 15.3	(f) 97.1	(g) 3.8	(h) 1.9	(i) 12.6	(j) 98.5	(k) 10.4	(l) 99.6	(m) 8.3	(n) 100.6	(o) 5.6	(p) 102.0		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			12.7	83.5	2.6	1.1	10.8	84.3	9.3	85.0	7.8	85.6	5.9	86.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.8	32.2	36.9	45.6	57.6	67.7	76.1	80.6	79.1	71.3	60.9	48.0	36.7		
	DBStd	17.66	4.68	5.85	5.82	6.55	5.61	4.60	4.51	3.67	4.66	5.45	7.54	5.35		
	HDD50	1635	553	369	161	12	0	0	0	0	0	2	125	413		
	HDD65	4222	1018	787	600	236	38	1	0	0	5	148	511	878		
	CDD50	4492	0	2	26	239	549	782	948	902	640	340	64	0		
	CDD65	1607	0	0	0	13	123	334	483	437	195	22	0	0		
	CDH74	13749	0	0	0	125	959	2798	4897	3843	1030	97	0	0		
	CDH80	4624	0	0	0	16	248	1043	1945	1164	204	4	0	0		
(14) Wind	WSAvg	6.7	6.2	6.7	7.7	7.9	7.2	6.6	6.2	6.5	5.9	6.0	6.6	6.4		
(15) Precipitation	PrecAvg	34.3	0.4	0.6	0.9	1.9	2.3	4.3	10.1	6.9	3.8	1.7	0.9	0.4		
	PrecMax	55.8	2.2	1.9	2.4	5.6	7.0	12.2	25.3	21.7	11.9	7.5	4.2	2.0		
	PrecMin	20.9	0.0	0.0	0.0	0.0	0.0	0.6	2.9	2.0	0.4	0.0	0.0	0.0		
	PrecStd	8.2	0.6	0.6	0.6	1.5	1.9	3.0	4.6	5.0	3.2	1.6	0.9	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.1	63.5	68.6	82.0	90.3	95.9	96.0	91.9	88.2	80.0	68.7	56.1		
		MCWB	38.7	48.6	51.6	66.5	65.2	70.5	78.5	80.3	78.4	60.7	55.0	47.3		
	2%	DB	45.4	54.8	63.8	77.6	85.6	91.6	93.6	89.7	84.8	76.8	65.3	50.9		
		MCWB	37.2	45.6	50.2	61.4	65.3	69.1	78.7	78.5	73.7	60.9	53.4	45.0		
	5%	DB	42.6	50.1	59.9	73.7	82.4	88.8	91.6	87.9	82.0	74.0	62.3	47.9		
		MCWB	35.6	39.7	47.7	59.0	64.7	69.7	78.5	77.9	71.4	59.4	52.5	41.8		
	10%	DB	40.1	46.6	56.3	70.0	79.6	86.0	89.1	86.0	79.6	70.9	59.1	45.4		
		MCWB	34.1	38.4	45.4	56.5	63.6	69.2	78.6	76.6	68.3	58.8	51.8	39.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.1	53.4	55.2	69.5	73.2	78.6	83.3	82.8	81.4	67.3	60.5	49.8		
		MCDB	45.6	62.0	63.7	78.2	81.1	86.1	89.3	89.4	86.5	70.3	63.3	53.3		
	2%	WB	39.4	45.7	51.4	64.3	70.2	77.0	82.2	81.0	77.0	64.6	57.8	46.1		
		MCDB	42.9	52.8	60.4	75.4	78.6	82.9	89.2	86.8	81.2	71.3	61.4	50.3		
	5%	WB	37.4	42.8	49.1	61.1	67.7	75.1	81.2	79.8	74.1	62.2	55.5	43.1		
		MCDB	41.0	47.3	57.8	70.6	77.3	81.5	88.1	85.0	78.7	69.6	58.2	47.0		
	10%	WB	34.9	39.9	47.0	58.2	66.0	72.9	80.3	78.8	71.8	60.5	52.9	40.6		
		MCDB	39.3	45.1	54.8	66.6	75.6	80.6	86.9	83.4	77.5	68.2	57.8	44.1		
(35) Mean Daily Temperature Range	MDBR		12.7	14.6	15.9	17.4	17.7	16.5	12.5	11.8	14.0	16.7	14.8	13.5		
	5% DB	MCDBR	16.7	19.6	21.5	23.1	22.9	21.5	15.8	13.1	15.7	19.7	18.9	17.4		
		MCWBR	11.0	12.1	11.9	11.4	9.4	6.1	5.1	4.5	6.3	7.4	10.0	11.3		
	5% WB	MCDBR	14.6	15.6	19.8	20.3	18.8	15.7	13.5	11.5	13.0	15.8	13.4	14.6		
		MCWBR	10.9	11.2	11.8	11.5	9.9	6.6	6.2	4.6	7.0	7.5	9.7	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.534	0.602	0.630	0.638	0.653	0.773	0.737	0.697	0.633	0.652	0.603	0.541		
	taud		1.722	1.625	1.598	1.624	1.633	1.462	1.579	1.641	1.712	1.609	1.646	1.728		
	Ebn at Noon		194	198	208	217	217	191	197	202	206	182	173	181		
	Edh at Noon		58	71	79	81	81	96	85	79	70	72	62	55		
(44) All-Sky Solar Radiation	RadAvg		752	917	1320	1570	1707	1599	1435	1399	1254	1051	797	701		
	RadStd		90	128	106	109	131	142	149	173	130	113	105	68		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page