

LINYI, China

WMO: 549380

Lat: 35.050N

Lon: 118.350E

Elev: 86

StdP: 100.30

Time Zone: 8.00 (E08)

Period: 90-97

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.6	(c) -5.2	(d) -20.8	(e) 0.6	(f) -0.9	(g) -18.0	(h) 0.8	(i) 0.4	(j) 9.2	(k) -0.6	(l) 7.5	(m) 0.9	(n) 2.6	(o) 40	(p) 0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	33.8	24.8	32.4	24.4	31.2	24.3	27.6	31.3	27.0	30.5	26.3	29.5	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.6	22.4	29.8	26.0	21.6	29.1	25.4	20.9	28.5	88.9	31.2	85.9	30.8	83.1	29.4	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.0	(b) 7.0	(c) 6.1	(e) -9.2	(f) 36.2	(g) 2.1	(h) 1.1	(i) -10.8	(j) 36.9	(k) -12.0	(l) 37.5	(m) -13.2	(n) 38.1	(o) -14.7	(p) 38.9		
(a) 8.0	(b) 7.0	(c) 6.1	(e) -10.7	(f) 28.6	(g) 1.5	(h) 0.6	(i) -11.8	(j) 29.1	(k) -12.6	(l) 29.4	(m) -13.4	(n) 29.8	(o) -14.5	(p) 30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	0.1	2.7	7.6	14.2	19.8	24.5	27.0	26.2	21.9	16.1	8.9	2.6	
	DBStd	9.81	2.60	3.25	3.23	3.64	3.12	2.56	2.51	2.04	2.59	3.03	4.19	2.97	
	HDD10.0	908	307	205	89	7	0	0	0	0	0	1	69	229	
	HDD18.3	2346	566	437	333	131	21	1	0	0	3	82	284	488	
	CDD10.0	2496	0	1	14	133	305	434	527	501	356	189	36	0	
	CDD18.3	893	0	0	0	7	68	186	268	243	108	12	0	0	
	CDH23.3	7638	0	0	0	69	533	1554	2721	2135	572	54	0	0	
	CDH26.7	2569	0	0	0	9	138	579	1081	647	113	2	0	0	
Wind	WSAvg	3.0	2.8	3.0	3.4	3.5	3.2	3.0	2.8	2.9	2.6	2.7	3.0	2.9	
Precipitation	PrecAvg	870	11	15	24	47	59	109	257	175	96	43	22	11	
	PrecMax	1417	55	47	61	142	179	310	642	551	301	190	107	50	
	PrecMin	530	0	0	0	0	1	15	73	51	10	0	0	0	
	PrecStd	209	14	14	16	37	48	76	118	126	81	40	24	12	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	17.5	20.3	27.8	32.4	35.5	35.6	33.3	31.2	26.7	20.4	13.4	
		MCWB	3.7	9.2	10.9	19.2	18.4	21.4	25.8	26.8	25.8	16.0	12.8	8.5	
	2%	DB	7.5	12.6	17.7	25.3	29.8	33.1	34.2	32.0	29.3	24.9	18.5	10.5	
		MCWB	2.9	7.6	10.1	16.3	18.5	20.6	25.9	25.8	23.2	16.1	11.9	7.2	
	5%	DB	5.9	10.1	15.5	23.1	28.0	31.5	33.1	31.0	27.8	23.4	16.8	8.8	
		MCWB	2.0	4.3	8.7	15.0	18.2	20.9	25.8	25.5	21.9	15.2	11.4	5.4	
	10%	DB	4.5	8.1	13.5	21.1	26.5	30.0	31.7	30.0	26.5	21.6	15.0	7.4	
		MCWB	1.2	3.5	7.5	13.6	17.5	20.7	25.9	24.8	20.2	14.9	11.0	4.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	11.9	12.9	20.8	22.9	25.9	28.5	28.2	27.5	19.6	15.9	9.9
			MCDB	7.5	16.7	17.6	25.7	27.3	30.0	31.8	31.9	30.3	21.3	17.4	11.8
2%		WB	4.1	7.6	10.8	17.9	21.2	25.0	27.9	27.2	25.0	18.1	14.3	7.9	
		MCDB	6.1	11.6	15.8	24.1	25.9	28.3	31.8	30.5	27.3	21.8	16.3	10.2	
5%		WB	3.0	6.0	9.5	16.2	19.8	23.9	27.3	26.6	23.4	16.8	13.1	6.2	
		MCDB	5.0	8.5	14.3	21.4	25.2	27.5	31.2	29.4	25.9	20.9	14.6	8.3	
10%		WB	1.6	4.4	8.4	14.5	18.9	22.7	26.8	26.0	22.1	15.8	11.6	4.8	
		MCDB	4.1	7.3	12.7	19.2	24.2	27.0	30.5	28.5	25.3	20.1	14.3	6.7	
Mean Daily Temperature Range	5% DB	MDBR	7.1	8.1	8.8	9.7	9.9	9.2	7.0	6.5	7.8	9.3	8.2	7.5	
		MCDBR	9.3	10.9	11.9	12.9	12.7	11.9	8.8	7.3	8.7	10.9	10.5	9.7	
		MCWBR	6.1	6.7	6.6	6.3	5.2	3.4	2.8	2.5	3.5	4.1	5.5	6.3	
	5% WB	MCDBR	8.1	8.7	11.0	11.3	10.5	8.7	7.5	6.4	7.2	8.8	7.5	8.1	
		MCWBR	6.1	6.2	6.6	6.4	5.5	3.7	3.5	2.6	3.9	4.1	5.4	5.9	
Clear-Sky Solar Irradiance	taub	0.534	0.602	0.630	0.638	0.653	0.773	0.737	0.697	0.633	0.652	0.603	0.541		
	taud	1.722	1.625	1.598	1.624	1.633	1.462	1.579	1.641	1.712	1.609	1.646	1.728		
	Ebn at Noon	613	624	657	684	683	603	622	636	649	575	545	572		
	Edh at Noon	183	225	250	255	256	304	269	248	221	226	197	173		
All-Sky Solar Radiation	RadAvg	2.37	2.89	4.16	4.95	5.38	5.04	4.53	4.41	3.95	3.31	2.51	2.21		
	RadStd	0.28	0.40	0.34	0.34	0.41	0.45	0.47	0.55	0.41	0.36	0.33	0.21		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page