

NAGQU, China

WMO: 552990

Lat: 31.4795N

Lon: 92.0612E

Elev: 14790

StdP: 8.36

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.4	(c) -5.0	(d) -31.9	(e) 1.6	(f) 12.3	(g) -28.8	(h) 1.9	(i) 14.2	(j) 32.3	(k) 31.7	(l) 27.9	(m) 28.1	(n) 1.4	(o) 20	(p) 0.772

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.7	(c) 64.8	(d) 44.5	(e) 62.6	(f) 44.6	(g) 60.6	(h) 44.2	(i) 48.5	(j) 58.9	(k) 47.6	(l) 57.7	(m) 46.7	(n) 56.5	(o) 7.7	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 44.4	(b) 76.4	(c) 52.3	(d) 43.5	(e) 73.8	(f) 51.6	(g) 42.7	(h) 71.5	(i) 51.0	(j) 25.4	(k) 59.3	(l) 24.7	(m) 58.1	(n) 24.1	(o) 56.9	(p) 61.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	19.0	16.1	-14.8	68.9	3.9	2.0	-17.7	70.4	-19.9	71.5	-22.1	72.7	-25.0	74.2
			-15.9	50.5	3.7	2.5	-18.5	52.3	-20.7	53.7	-22.7	55.1	-25.4	56.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.9	13.2	17.2	23.8	31.8	40.2	48.1	50.7	50.0	45.2	34.4	22.7	15.9		
	DBStd	14.34	6.31	5.62	5.55	4.69	5.11	4.77	2.85	3.14	3.98	6.30	5.32	5.80		
	HDD50	6385	1140	917	812	545	306	88	26	38	149	485	820	1059		
	HDD65	11734	1605	1337	1277	995	768	507	443	464	594	950	1270	1524		
	CDD50	126	0	0	0	0	3	31	48	39	5	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.2	5.5	6.3	6.6	6.3	5.8	5.3	4.7	4.3	4.3	4.6	4.4	4.8		
(15) Precipitation	PrecAvg	16.7	0.1	0.1	0.1	0.4	1.0	3.3	4.1	3.8	2.8	0.7	0.1	0.1		
	PrecMax	23.2	0.5	0.4	0.4	1.2	2.6	5.7	8.1	8.3	5.2	2.4	0.6	0.5		
	PrecMin	11.8	0.0	0.0	0.0	0.0	0.0	1.0	1.5	0.5	1.1	0.0	0.0	0.0		
	PrecStd	2.9	0.1	0.1	0.1	0.3	0.6	1.2	1.4	1.7	1.1	0.6	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.6	41.6	50.4	54.9	65.0	68.8	66.4	66.3	63.0	58.4	45.9	42.9		
		MCWB	25.8	25.0	29.7	32.7	39.0	43.0	46.1	45.9	43.6	37.2	27.5	25.4		
	2%	DB	36.2	37.8	44.4	51.3	60.1	64.6	63.6	63.8	59.9	53.7	41.7	38.0		
		MCWB	22.1	23.0	27.2	31.4	37.7	43.6	46.2	45.8	43.0	36.0	25.8	23.1		
	5%	DB	31.2	34.7	40.5	47.8	56.0	61.8	61.4	61.4	57.4	50.0	38.7	34.0		
		MCWB	19.5	21.3	25.2	29.7	36.0	43.5	45.6	45.5	42.7	34.1	24.6	21.2		
	10%	DB	27.4	31.4	37.6	44.7	52.3	59.0	59.2	59.1	54.9	46.6	35.8	30.3		
		MCWB	17.2	19.5	23.7	28.6	34.9	43.4	45.6	45.0	42.0	32.5	23.4	19.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	26.5	31.1	35.3	43.0	48.6	50.1	49.4	47.1	40.4	29.2	26.6		
		MCDB	40.5	39.5	47.2	48.7	56.8	60.0	59.8	60.3	57.8	51.5	41.2	40.4		
	2%	WB	22.7	23.6	28.1	32.9	40.5	47.1	48.6	48.2	45.6	38.6	27.1	23.5		
		MCDB	34.8	36.2	42.4	46.3	52.1	58.7	58.6	58.8	55.9	49.2	38.6	36.8		
	5%	WB	19.9	21.7	26.1	31.3	38.8	45.9	47.8	47.3	44.4	36.7	25.5	21.4		
		MCDB	30.7	33.7	38.7	44.4	50.4	57.2	57.7	57.4	54.3	46.3	36.6	33.3		
	10%	WB	17.4	19.7	24.3	29.8	37.1	44.9	47.0	46.4	43.2	34.6	23.9	19.3		
		MCDB	26.8	30.4	35.8	42.1	47.9	55.3	56.4	56.0	52.2	43.2	34.5	29.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	27.6	26.2	24.7	22.8	19.8	18.5	16.7	17.2	18.8	20.8	25.6	29.0		
		MCDBR	34.0	32.5	30.0	29.0	26.6	23.7	20.6	21.9	22.4	25.9	30.2	34.6		
		MCWBR	23.3	21.4	18.0	14.4	10.6	8.4	7.8	8.0	8.7	10.9	17.5	22.9		
	5% WB	MCDBR	32.9	30.6	27.6	25.2	19.7	18.6	16.4	16.7	18.4	21.5	27.2	33.4		
		MCWBR	23.0	20.7	17.2	13.6	9.2	7.8	7.1	6.9	8.0	9.5	16.4	22.6		
(40) Clear-Sky Solar Irradiance	taub		0.175	0.191	0.230	0.267	0.278	0.269	0.268	0.263	0.247	0.215	0.180	0.166		
	taud		2.672	2.617	2.500	2.424	2.470	2.601	2.652	2.654	2.669	2.699	2.721	2.764		
	Ebn at Noon		351	350	338	325	319	320	320	322	327	336	346	353		
	Edh at Noon		23	26	32	37	36	31	29	29	27	24	21	19		
(44) All-Sky Solar Radiation	RadAvg		1189	1478	1797	1989	2073	2020	1891	1807	1637	1496	1334	1186		
	RadStd		121	89	120	114	129	104	119	112	80	117	72	70		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+1.13	+1.73	-4.28	N/A	+0.49	N/A	-446	-490	+63	N/A
Regional (2 neighbors)	+1.06	N/A	-4.32	N/A	N/A	N/A	-446	-490	+63	N/A

Nomenclature: See separate page