

XAINZA, China

WMO: 554720

Lat: 30.950N

Lon: 88.633E

Elev: 15322

StdP: 8.19

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.7	(c) -0.1	(d) -38.1	(e) 1.1	(f) 22.9	(g) -33.6	(h) 1.5	(i) 21.5	(j) 44.0	(k) 32.6	(l) 40.5	(m) 31.5	(n) 0.7	(o) 180	(p) 0.809

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	64.8	41.7	62.6	41.3	60.5	41.4	46.6	57.7	45.7	56.5	44.9	55.5	9.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.9	70.7	51.6	41.0	68.4	51.0	40.2	66.3	50.3	24.2	57.9	23.6	56.9	23.1	55.7	49.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
33.1	28.4	24.0	-11.2	68.9	4.4	2.3	-14.3	70.5	-16.9	71.9	-19.4	73.1	-22.5	74.8		
			-13.1	48.6	4.1	0.6	-16.1	49.0	-18.4	49.3	-20.7	49.7	-23.7	50.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.0	16.3	19.3	24.4	32.3	40.5	48.8	50.9	49.6	46.0	34.9	24.9	19.6		
	DBStd	13.44	6.97	5.88	5.48	4.60	4.98	4.65	2.78	2.78	3.70	6.17	5.09	6.68		
	HDD50	5952	1044	861	793	531	298	74	22	40	126	468	752	943		
	HDD65	11302	1509	1281	1258	981	761	485	437	477	570	933	1202	1408		
	CDD50	125	0	0	0	0	2	39	50	28	6	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	8.4	10.7	11.4	10.6	9.5	8.1	7.2	6.5	5.9	6.1	7.0	8.3	9.5		
	PrecAvg	11.2	0.0	0.0	0.0	0.1	0.4	1.7	3.4	3.5	1.9	0.2	0.0	0.0		
(15) Precipitation	PrecMax	17.4	0.1	0.2	0.2	0.6	1.7	4.1	7.7	7.7	5.6	0.9	0.2	0.3		
	PrecMin	6.9	0.0	0.0	0.0	0.0	0.0	0.5	1.0	1.3	0.6	0.0	0.0	0.0		
	PrecStd	2.4	0.0	0.0	0.0	0.2	0.4	0.9	1.3	1.3	1.1	0.2	0.1	0.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.0	42.2	48.1	53.1	63.2	68.8	66.9	65.1	62.6	57.3	45.2	44.1		
		MCWB	23.1	24.3	27.6	30.3	36.5	41.3	42.6	42.4	40.2	33.8	26.0	24.9		
	2%	DB	36.5	37.4	43.0	49.9	58.9	65.5	64.1	62.4	59.6	53.4	41.9	38.7		
		MCWB	20.9	21.4	25.0	29.3	34.4	40.6	43.4	42.3	39.9	33.4	24.4	22.0		
	5%	DB	32.7	34.4	39.3	47.1	55.5	62.9	61.7	60.2	57.3	50.2	39.3	35.6		
		MCWB	18.8	19.8	23.1	28.2	33.3	40.2	43.2	42.7	40.0	31.9	23.0	20.5		
	10%	DB	29.0	31.3	36.4	44.0	52.3	60.3	59.4	57.8	55.1	46.8	36.6	32.1		
		MCWB	16.7	18.1	21.6	26.6	32.2	39.9	43.4	42.7	39.7	30.4	21.8	18.6		
	0.4%	WB	22.5	24.4	27.7	31.5	39.3	46.0	48.0	47.3	45.0	38.1	27.9	25.8		
		MCDB	38.3	41.4	46.1	49.3	49.7	57.9	59.7	57.8	56.4	50.7	44.0	44.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	20.0	21.6	25.2	30.3	37.2	44.5	46.9	46.2	43.9	36.2	25.5	22.9		
		MCDB	33.9	36.7	40.6	47.9	48.2	57.1	58.4	56.6	55.1	47.6	41.3	39.6		
	5%	WB	18.1	20.2	23.5	29.0	35.8	43.4	46.1	45.5	42.8	34.2	24.1	21.1		
		MCDB	30.7	34.2	37.4	45.4	47.5	56.2	57.3	55.6	53.5	45.4	39.5	36.1		
	10%	WB	16.1	18.5	22.0	27.7	34.5	42.5	45.4	44.7	41.5	32.0	22.6	19.3		
		MCDB	27.5	31.2	35.1	42.5	46.9	55.3	56.2	54.6	52.1	43.8	37.3	32.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	22.1	21.7	21.7	20.5	19.4	19.2	16.6	15.9	17.6	20.0	22.6	23.0		
		MCDBR	26.2	26.0	25.6	25.3	24.6	23.7	20.8	20.4	20.7	23.7	25.4	25.6		
		MCWBR	17.4	16.0	13.4	11.2	9.7	7.5	6.3	6.6	6.6	9.5	14.3	15.9		
		MCDBR	26.0	25.4	22.9	23.3	18.4	18.8	16.3	15.5	16.6	19.4	25.1	25.8		
	5% WB	MCWBR	16.8	15.7	12.5	10.6	7.7	6.8	6.7	6.6	6.6	7.4	13.8	15.6		
(40) Clear-Sky Solar Irradiance	taub		0.166	0.180	0.212	0.253	0.266	0.263	0.269	0.263	0.241	0.200	0.170	0.158		
	taud		2.697	2.642	2.553	2.467	2.490	2.595	2.627	2.646	2.680	2.749	2.755	2.790		
	Ebn at Noon		356	356	345	330	323	322	320	323	330	343	352	357		
	Edh at Noon		22	26	31	35	35	31	30	29	27	23	21	19		
(44) All-Sky Solar Radiation	RadAvg		1249	1506	1842	2034	2205	2242	1997	1867	1849	1702	1440	1270		
	RadStd		117	137	124	125	129	135	123	108	94	117	82	59		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-218	+184	+5

Nomenclature: See separate page