

XAINZA, China

WMO: 554720

Lat: 30.950N

Lon: 88.633E

Elev: 4670

StdP: 56.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.8	-17.8	-38.9	0.2	-5.1	-36.4	0.2	-5.8	19.7	0.3	18.1	-0.3	0.3	180	0.809

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	18.2	5.4	17.0	5.2	15.8	5.2	8.1	14.3	7.6	13.6	7.2	13.0	4.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.5	10.1	10.9	5.0	9.8	10.6	4.6	9.5	10.2	38.5	14.4	37.1	13.8	35.8	13.1	9.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.8	12.7	10.7	DB	-24.0	20.5	2.4	1.3	-25.7	21.4	-27.2	22.1	-28.5	22.8	-30.3	23.8	(4)
			WB	-25.1	9.2	2.3	0.3	-26.7	9.4	-28.0	9.6	-29.3	9.8	-30.9	10.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-8.7	-7.1	-4.2	0.2	4.7	9.3	10.5	9.8	7.8	1.6	-3.9	-6.9
	DBStd	7.47	3.87	3.27	3.05	2.56	2.77	2.58	1.54	1.54	2.06	3.43	2.83	3.71
	HDD10.0	3307	580	478	441	295	166	41	12	22	70	260	418	524
	HDD18.3	6279	838	712	699	545	423	269	243	265	317	518	668	782
	CDD10.0	69	0	0	0	0	1	22	28	16	3	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.7	4.8	5.1	4.7	4.2	3.6	3.2	2.9	2.6	2.7	3.1	3.7	4.3
Precipitation	PrecAvg	285	1	1	1	3	11	42	86	88	47	6	1	1
	PrecMax	442	3	5	4	15	42	105	196	196	141	22	6	7
	PrecMin	176	0	0	0	0	0	12	25	33	16	0	0	0
	PrecStd	62	1	1	1	4	9	24	33	32	27	6	2	1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.5	5.7	9.0	11.7	17.4	20.5	19.4	18.4	17.0	14.1	7.3	6.7
		MCWB	-5.0	-4.3	-2.5	-0.9	2.5	5.1	5.9	5.8	4.6	1.0	-3.3	-3.9
	2%	DB	2.5	3.0	6.1	9.9	14.9	18.6	17.8	16.9	15.3	11.9	5.5	3.7
		MCWB	-6.2	-5.9	-3.9	-1.5	1.3	4.8	6.3	5.7	4.4	0.8	-4.2	-5.6
	5%	DB	0.4	1.4	4.1	8.4	13.1	17.2	16.5	15.7	14.1	10.1	4.0	2.0
		MCWB	-7.3	-6.8	-4.9	-2.1	0.7	4.5	6.2	5.9	4.4	0.0	-5.0	-6.4
	10%	DB	-1.7	-0.4	2.5	6.6	11.3	15.7	15.2	14.4	12.8	8.2	2.5	0.1
		MCWB	-8.5	-7.7	-5.8	-3.0	0.1	4.4	6.4	6.0	4.3	-0.9	-5.7	-7.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.3	-4.2	-2.4	-0.3	4.0	7.8	8.9	8.5	7.2	3.4	-2.3	-3.4
		MCDB	3.5	5.2	7.8	9.6	9.8	14.4	15.4	14.4	13.6	10.4	6.7	6.8
	2%	WB	-6.7	-5.8	-3.8	-1.0	2.9	7.0	8.3	7.9	6.6	2.3	-3.6	-5.0
		MCDB	1.0	2.6	4.8	8.8	9.0	13.9	14.7	13.6	12.8	8.7	5.2	4.2
	5%	WB	-7.7	-6.6	-4.7	-1.7	2.1	6.3	7.8	7.5	6.0	1.2	-4.4	-6.1
		MCDB	-0.7	1.2	3.0	7.4	8.6	13.4	14.1	13.1	11.9	7.4	4.2	2.3
	10%	WB	-8.8	-7.5	-5.5	-2.4	1.4	5.8	7.4	7.0	5.3	0.0	-5.2	-7.0
		MCDB	-2.5	-0.4	1.7	5.9	8.3	12.9	13.4	12.5	11.2	6.5	3.0	0.5
Mean Daily Temperature Range	5% DB	MDBR	12.3	12.0	12.0	11.4	10.8	10.7	9.2	8.9	9.8	11.1	12.5	12.8
		MCDBR	14.5	14.4	14.2	14.1	13.7	13.2	11.6	11.3	11.5	13.2	14.1	14.2
		MCWBR	9.7	8.9	7.5	6.2	5.4	4.2	3.5	3.7	3.7	5.3	7.9	8.8
	5% WB	MCDBR	14.4	14.1	12.7	12.9	10.2	10.4	9.1	8.6	9.2	10.8	14.0	14.3
		MCWBR	9.3	8.7	7.0	5.9	4.3	3.8	3.7	3.7	3.6	4.1	7.7	8.7
Clear-Sky Solar Irradiance	taub	0.166	0.180	0.212	0.253	0.266	0.263	0.269	0.263	0.241	0.200	0.170	0.158	
	taud	2.697	2.642	2.553	2.467	2.490	2.595	2.627	2.646	2.680	2.749	2.755	2.790	
	Ebn at Noon	1123	1121	1087	1041	1019	1015	1009	1017	1040	1082	1111	1127	
	Edh at Noon	69	82	97	111	110	98	95	92	85	73	65	60	
All-Sky Solar Radiation	RadAvg	3.94	4.75	5.81	6.41	6.95	7.07	6.29	5.89	5.83	5.36	4.54	4.00	
	RadStd	0.37	0.43	0.39	0.39	0.41	0.43	0.39	0.34	0.29	0.37	0.26	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-121	+102	+3

Nomenclature: See separate page